

ZANDERIJ, Suriname

WMO: 812250

Lat: 5.453N

Lon: 55.188W

Elev: 18

StdP: 101.11

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.8	21.4	18.4	13.3	28.9	19.2	14.0	28.6	8.0	28.3	7.2	28.6	0.3	220	0.293

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	10.3	34.2	24.6	33.9	24.7	33.2	24.8	26.5	30.0	26.2	29.8	26.1	29.7	3.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.7	21.0	27.8	25.2	20.4	27.2	25.1	20.3	27.1	82.8	30.1	81.6	30.1	80.6	30.0	31.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.0	6.2	5.4	19.4	35.5	0.7	0.5	18.9	35.8	18.5	36.1	18.1	36.4	17.6	36.8		
(5)			18.7	27.9	1.3	1.1	17.7	28.7	16.9	29.3	16.2	30.0	15.2	30.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.3	26.3	26.3	26.6	27.1	27.1	27.2	27.3	27.9	28.4	28.4	27.9	26.9		
	DBStd	1.07	0.79	0.87	0.88	0.90	0.88	0.75	0.77	0.66	0.64	0.74	0.81	0.93		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6311	505	456	516	513	531	514	536	555	552	570	538	526		
	CDD18.3	3269	247	222	257	263	272	264	278	297	302	312	288	267		
	CDH23.3	27408	1774	1621	2042	2164	2136	1999	2194	2702	2989	3086	2629	2072		
	CDH26.7	10385	544	499	702	718	636	637	818	1174	1387	1436	1118	717		
(14) Wind	WSAvg	2.1	2.3	2.4	2.4	2.2	2.0	1.7	1.6	1.8	2.1	2.3	2.1	2.2		
(15) Precipitation	PrecAvg	2245	197	161	144	215	300	303	227	175	104	99	122	192		
	PrecMax	2925	403	549	333	623	484	487	361	291	319	279	243	457		
	PrecMin	1416	37	12	14	23	55	181	31	15	30	0	21	12		
	PrecStd	345	96	102	82	122	90	66	75	68	58	65	49	72		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.2	32.8	33.1	33.2	33.0	33.0	33.2	34.2	34.9	35.1	34.9	33.4		
		MCWB	24.5	24.1	24.5	24.7	25.3	25.0	24.9	24.9	24.7	24.3	24.2	24.7		
	2%	DB	31.2	31.7	32.0	32.2	32.1	32.1	32.2	33.2	34.1	34.2	34.0	32.3		
		MCWB	24.4	24.1	24.5	24.7	25.2	25.0	24.9	24.8	24.7	24.6	24.6	24.8		
	5%	DB	30.7	30.8	31.1	31.8	31.1	31.2	31.9	32.9	33.8	33.9	33.1	31.8		
		MCWB	24.4	24.1	24.5	24.8	25.3	25.2	24.9	24.8	24.7	24.6	24.8	24.9		
	10%	DB	29.9	29.9	30.2	30.8	30.1	30.2	31.0	32.1	33.0	33.0	32.1	30.5		
		MCWB	24.4	24.2	24.4	25.0	25.3	25.3	25.1	24.9	24.8	24.8	24.9	25.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.2	26.2	26.2	26.7	26.7	26.6	26.5	26.5	26.6	26.5	26.5	26.2		
		MCDB	29.0	28.9	29.2	29.5	29.6	29.7	30.3	30.9	31.2	31.0	30.4	29.4		
	2%	WB	25.6	25.7	25.7	26.2	26.3	26.1	26.0	26.1	26.1	26.1	26.1	26.0		
		MCDB	28.6	28.5	29.0	29.2	29.3	29.3	29.7	30.6	30.8	30.7	30.2	29.2		
	5%	WB	25.2	25.3	25.4	25.8	26.0	25.8	25.6	25.7	25.7	25.7	25.7	25.6		
		MCDB	28.3	28.3	28.8	28.9	29.0	29.0	29.4	30.2	30.4	30.3	29.8	29.0		
	10%	WB	24.9	24.9	25.0	25.5	25.7	25.5	25.3	25.4	25.4	25.5	25.5	25.3		
		MCDB	28.1	27.9	28.6	28.5	28.6	28.7	29.1	29.9	30.1	30.1	29.6	28.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.9	7.8	8.4	7.9	7.4	7.9	8.8	9.6	10.3	10.3	9.6	8.3		
		MCDBR	9.3	9.6	9.5	9.5	8.5	8.7	9.5	10.2	10.8	11.0	10.5	9.6		
	5% WB	MCWBR	3.5	3.5	3.3	3.2	3.0	3.1	3.2	3.1	2.9	2.8	3.0	3.1		
		MCWBR	7.6	7.3	8.0	7.5	7.4	7.9	8.8	9.5	10.2	10.2	9.5	8.1		
(40) Clear-Sky Solar Irradiance	taub	taub	0.425	0.457	0.458	0.477	0.452	0.399	0.399	0.400	0.412	0.405	0.394	0.446		
		taud	2.426	2.314	2.317	2.256	2.355	2.527	2.515	2.502	2.450	2.485	2.516	2.362		
	Ebn at Noon	Ebn at Noon	895	873	871	839	840	876	881	894	897	910	918	867		
		Edh at Noon	118	135	135	141	125	103	105	109	117	112	107	124		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	4.44	4.50	4.84	4.74	4.53	4.86	5.39	5.99	6.28	6.00	5.27	4.43		
	RadStd	RadStd	0.31	0.29	0.21	0.33	0.27	0.24	0.18	0.22	0.15	0.23	0.29	0.33		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page