

TERESINA, Brazil

WMO: 825790

Lat: 5.060S

Lon: 42.823W

Elev: 67

StdP: 100.53

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	21.9	22.6	11.2	8.4	36.3	12.8	9.3	35.6	5.5	26.9	4.8	27.6	0.9	180	0.362

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	12.7	39.0	22.3	38.1	22.6	37.2	22.9	27.2	31.0	26.9	30.8	26.6	30.6	2.5	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.8	28.5	26.1	21.6	28.4	25.8	21.3	28.2	86.5	30.8	84.9	31.3	83.5	30.8	32.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 5.4	4.8	4.2	DB	19.7	39.9	1.0	1.0	19.0	40.6	18.5	41.3	17.9	41.8	17.2	42.6	(4)
(5)			WB	17.6	28.8	0.9	1.1	16.9	29.6	16.4	30.2	15.9	30.8	15.3	31.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	29.4	28.7	28.3	28.2	28.4	28.6	28.5	28.8	29.6	30.8	31.4	31.0	30.2	(6)
(7)		DBStd	1.58	1.51	1.26	1.07	0.93	0.83	0.84	0.99	1.02	0.85	0.99	1.32	1.57	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	7069	579	512	565	551	577	556	581	609	624	662	629	624	(10)
(11)		CDD18.3	4027	321	279	307	301	319	306	323	351	374	404	379	366	(11)
(12)		CDH23.3	48813	3529	2889	3066	3063	3544	3482	3833	4544	5178	5715	5237	4733	(12)
(13)		CDH26.7	25001	1626	1259	1280	1260	1519	1591	1914	2526	3050	3420	3017	2538	(13)
(14)	Wind	WSAvg	1.6	1.5	1.4	1.3	1.2	1.4	1.6	1.7	1.7	1.8	2.0	1.9	1.7	(14)
(15)	Precipitation	PrecAvg	1392	207	227	306	268	120	19	12	11	15	22	67	125	(15)
(16)		PrecMax	2568	505	506	626	650	308	98	72	78	83	91	215	414	(16)
(17)		PrecMin	706	62	41	0	56	0	0	0	0	0	0	3	4	(17)
(18)		PrecStd	368	113	101	142	157	91	21	18	21	20	25	55	96	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.1	35.6	35.2	34.6	35.0	35.1	36.3	37.9	39.2	40.0	39.8	38.8	(19)
(20)			MCWB	23.8	25.5	26.3	26.5	25.6	23.8	22.5	22.2	22.1	22.5	22.0	22.5	(20)
(21)		2%	DB	35.7	34.2	34.0	33.8	34.0	34.2	35.2	37.0	38.2	39.0	38.7	37.2	(21)
(22)			MCWB	24.4	25.5	26.2	26.3	25.5	23.9	22.7	22.1	22.3	22.3	22.6	23.4	(22)
(23)		5%	DB	34.2	33.4	33.0	33.0	33.1	33.6	34.8	36.1	37.3	38.1	37.8	36.3	(23)
(24)			MCWB	25.0	25.5	25.9	26.0	25.5	24.0	22.7	22.2	22.5	22.6	22.9	23.8	(24)
(25)		10%	DB	33.1	32.5	32.1	32.1	32.6	32.9	33.9	35.2	36.8	37.1	36.8	35.2	(25)
(26)			MCWB	25.1	25.5	25.8	25.9	25.4	24.0	22.7	22.4	22.6	23.0	23.3	24.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.0	27.4	27.6	27.7	27.6	26.6	26.0	25.4	25.4	26.0	26.4	26.6	(27)
(28)			MCD B	31.4	30.8	31.3	31.1	30.8	30.1	29.7	31.2	32.7	32.1	32.0	31.9	(28)
(29)		2%	WB	26.5	26.7	27.0	27.2	27.0	26.0	25.3	24.9	24.9	25.4	25.8	26.1	(29)
(30)			MCD B	31.0	30.8	31.1	30.9	30.5	29.7	29.6	30.7	32.1	32.0	31.7	31.6	(30)
(31)		5%	WB	26.1	26.5	26.6	26.8	26.6	25.6	24.8	24.4	24.5	25.0	25.4	25.7	(31)
(32)			MCD B	30.8	30.6	30.7	30.6	30.2	29.6	29.4	30.3	31.5	32.0	31.4	31.2	(32)
(33)		10%	WB	25.8	26.1	26.3	26.5	26.2	25.3	24.4	24.0	24.2	24.6	25.0	25.4	(33)
(34)			MCD B	30.4	30.4	30.3	30.2	29.9	29.4	29.2	29.9	30.9	31.5	31.1	30.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.3	8.9	8.7	8.5	8.6	9.6	11.0	12.5	12.9	12.7	11.6	10.4	(35)
(36)			MCD BR	10.7	9.7	9.5	9.2	9.2	10.3	11.8	13.1	13.5	13.6	13.1	11.8	(36)
(37)			MCWBR	2.7	3.0	3.2	3.1	2.7	2.7	2.8	2.9	2.8	2.8	2.6	2.4	(37)
(38)		5% WB	MCD BR	9.2	8.9	8.8	8.6	8.5	9.3	10.3	12.0	12.6	12.1	10.8	10.2	(38)
(39)			MCWBR	3.2	3.4	3.4	3.3	3.0	2.8	2.9	3.1	2.7	2.7	2.7	2.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.423	0.410	0.413	0.404	0.399	0.384	0.373	0.383	0.442	0.474	0.469	0.454	(40)	
(41)		taud	2.417	2.466	2.462	2.492	2.488	2.524	2.548	2.482	2.300	2.227	2.245	2.306	(41)	
(42)		Ebn at Noon	915	926	911	894	872	872	889	901	871	857	866	882	(42)	
(43)		Edh at Noon	124	118	117	110	105	99	98	109	136	148	146	137	(43)	
(44)	All-Sky Solar Radiation	RadAvg	5.31	5.38	5.41	5.26	5.35	5.46	5.78	6.42	6.67	6.47	6.04	5.55	(44)	
(45)		RadStd	0.32	0.35	0.23	0.23	0.24	0.18	0.19	0.16	0.23	0.19	0.31	0.24	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.41	+0.25	-2.42	+0.83	N/A	N/A	N/A	N/A	+128	+128	(46)
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page