

SALVADOR, Brazil

WMO: 832480

Lat: 12.911S

Lon: 38.331W

Elev: 64

StdP: 14.66

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	69.4	70.2	61.0	80.3	75.3	62.7	85.4	75.4	21.6	74.6	19.6	75.8	5.4	180	0.423

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	10.2	90.0	79.9	89.5	79.6	88.1	79.0	81.4	87.5	80.6	87.0	80.0	86.2	11.5	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.4	152.7	85.1	78.9	150.4	84.8	78.3	147.4	84.5	45.1	88.0	44.3	87.5	43.6	86.7	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.8	18.1	16.5	DB	65.9	91.9	2.4	3.6	64.2	94.5	62.8	96.6	61.5	98.7	59.7	101.3	(4)
(5)			WB	63.5	82.6	2.7	1.8	61.6	83.8	60.0	84.9	58.5	85.9	56.5	87.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	79.8	82.1	82.4	82.3	81.3	79.6	78.0	76.9	76.9	77.8	79.3	80.3	81.3
	DBStd	2.96	2.11	2.16	2.30	2.24	2.43	2.40	2.31	2.06	2.08	2.09	2.20	1.94
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10890	994	907	1002	939	916	841	835	833	835	909	910	969
	CDD65	5415	529	487	537	489	451	391	370	368	385	444	460	504
	CDH74	52802	5985	5699	6388	5431	4330	3151	2578	2461	2923	3950	4533	5373
CDH80	13984	2003	2035	2333	1697	999	459	288	244	410	776	1165	1575	
Wind	WSAvg	9.2	9.4	9.0	8.4	7.9	8.1	8.6	9.1	9.4	10.0	10.5	10.4	9.8
Precipitation	PrecAvg	65.2	2.7	3.1	4.2	10.1	11.2	8.4	6.7	4.6	3.5	3.1	4.6	2.4
	PrecMax	91.8	13.0	11.3	10.6	21.0	23.5	14.6	17.7	11.9	8.0	7.8	10.1	8.3
	PrecMin	39.7	0.2	0.4	0.5	2.4	6.1	4.3	2.6	1.7	0.9	0.3	1.4	0.3
	PrecStd	12.1	2.6	2.7	2.7	5.4	4.6	2.8	3.0	2.1	1.9	2.4	2.5	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.3	91.6	91.8	90.6	89.4	86.4	86.1	85.8	86.3	87.9	89.4	90.0
		MCWB	80.1	80.4	81.0	80.3	80.3	78.6	78.2	77.9	77.6	78.9	79.4	79.7
	2%	DB	89.6	89.8	90.0	88.3	87.1	84.6	84.1	83.8	84.6	86.2	87.8	88.2
		MCWB	79.3	79.7	80.2	79.3	79.1	76.5	76.0	75.8	76.4	77.8	78.7	78.9
	5%	DB	88.1	88.2	89.2	87.5	85.8	83.9	82.6	82.4	83.8	84.6	86.2	87.4
		MCWB	78.8	78.9	79.6	78.8	77.7	75.8	74.3	74.3	75.8	76.5	77.7	78.5
	10%	DB	86.4	87.5	87.7	86.1	84.4	82.5	81.5	81.0	82.4	83.9	84.8	86.0
		MCWB	77.9	78.5	78.6	77.7	76.6	74.9	73.8	73.5	74.6	76.0	76.8	77.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.8	82.0	82.6	81.6	80.9	79.7	78.3	78.1	78.6	79.7	80.4	80.9
		MCDB	87.5	87.7	88.9	87.4	86.6	84.7	83.9	83.6	84.3	85.9	86.6	87.3
	2%	WB	80.5	80.9	81.4	80.3	79.7	78.3	77.4	76.9	77.5	78.6	79.4	79.9
		MCDB	86.8	87.5	87.8	86.2	85.4	83.2	82.3	82.0	83.2	84.5	85.6	86.4
	5%	WB	79.8	80.0	80.3	79.7	78.8	77.4	76.4	75.9	76.5	77.8	78.6	79.2
		MCDB	86.0	86.5	86.7	85.4	84.0	81.9	80.9	80.6	82.0	83.4	84.7	85.4
	10%	WB	79.0	79.3	79.6	78.9	78.0	76.5	75.5	75.0	75.7	76.9	77.9	78.4
		MCDB	85.3	85.5	85.8	84.5	82.9	80.7	79.8	79.6	80.9	82.1	83.7	84.3
Mean Daily Temperature Range	5% DB	MDBR	9.9	9.9	10.2	9.3	9.0	8.6	8.9	8.8	9.0	8.7	9.4	9.6
		MCDBR	10.5	10.6	11.2	10.2	10.1	9.6	9.7	9.7	10.1	9.6	10.4	10.6
		MCWBR	4.8	4.9	5.1	4.7	5.1	5.0	5.3	5.3	5.2	4.7	4.9	5.0
	5% WB	MCDBR	10.4	10.1	10.6	9.7	9.5	9.0	9.5	9.2	9.5	9.3	9.8	10.1
		MCWBR	5.2	5.1	5.4	5.2	5.5	5.2	6.0	5.7	5.4	5.0	5.3	5.2
Clear-Sky Solar Irradiance	taub	0.393	0.390	0.394	0.390	0.388	0.376	0.373	0.382	0.422	0.425	0.415	0.408	
	taud	2.514	2.532	2.527	2.552	2.552	2.567	2.563	2.507	2.381	2.393	2.441	2.459	
	Ebn at Noon	301	300	293	284	274	273	277	282	280	286	292	296	
	Edh at Noon	36	35	35	32	30	29	30	33	39	40	38	38	
All-Sky Solar Radiation	RadAvg	2069	2008	1877	1631	1391	1312	1386	1569	1760	1908	1968	2034	
	RadStd	147	125	107	118	95	59	65	73	86	109	128	115	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	-2.14	N/A	-0.77	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page