

CUIABA, Brazil

WMO: 833620

Lat: 15.653S

Lon: 56.117W

Elev: 617

StdP: 14.37

Time Zone: -4.00 (SAC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	55.5	59.0	40.7	38.2	82.7	43.6	42.7	82.2	18.4	80.8	16.2	80.7	7.3	200	0.345

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	22.6	101.2	71.2	99.3	71.6	97.8	72.2	82.2	88.8	80.7	87.7	79.3	87.1	7.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.7	163.3	85.2	79.1	154.3	83.9	77.4	145.7	82.8	46.7	88.3	45.0	86.7	43.5	86.9	88.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.9	14.3	12.5	51.6	104.0	3.5	1.7	49.1	105.2	47.0	106.1	45.1	107.1	42.5	108.3		
(5)			47.8	82.0	4.0	2.8	44.9	84.0	42.5	85.6	40.3	87.2	37.3	89.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.5	82.4	82.5	82.9	82.2	78.6	77.3	76.9	80.8	84.0	84.6	83.4	82.9
	DBStd	5.44	2.97	2.99	2.99	4.53	5.55	5.68	6.55	6.61	6.63	4.28	3.61	2.81
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	22	0	0	0	1	1	4	11	3	2	0	0	0
	CDD50	11506	1005	910	1019	965	885	820	833	955	1019	1073	1003	1019
	CDD65	6052	540	490	554	516	421	374	378	493	571	608	553	554
	CDH74	64568	5183	4716	5416	5173	3954	3640	4074	6120	7447	7202	6051	5592
	CDH80	31024	2092	1908	2270	2327	1787	1784	2109	3510	4299	3757	2833	2348
Wind	WSAvg	5.4	6.0	5.4	4.9	4.5	4.6	4.7	5.1	5.6	6.0	6.0	6.2	6.1
Precipitation	PrecAvg	55.0	9.0	9.0	7.6	5.0	1.9	0.5	0.5	0.6	2.1	5.0	7.0	8.0
	PrecMax	83.3	17.4	20.0	14.4	11.9	5.6	3.1	3.6	4.0	7.6	12.0	17.6	16.8
	PrecMin	39.3	1.7	1.4	0.0	0.7	0.0	0.0	0.0	0.0	0.0	1.0	1.5	3.5
	PrecStd	8.9	3.3	3.7	3.1	2.2	1.5	0.7	0.8	0.9	1.7	2.2	3.0	3.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	97.1	96.7	98.2	98.3	96.9	96.7	97.1	102.1	103.9	103.6	98.9	97.0
		MCWB	77.9	78.2	78.4	77.5	77.0	72.0	70.6	70.4	69.2	74.6	76.5	77.0
	2%	DB	94.7	93.6	95.0	95.3	93.7	93.6	95.1	100.0	102.0	100.4	96.8	94.7
		MCWB	77.1	77.5	77.7	76.9	74.1	70.7	69.1	68.9	70.3	73.9	76.4	76.5
	5%	DB	92.0	91.8	92.8	93.3	91.7	91.7	93.3	98.3	100.2	97.5	94.8	92.8
		MCWB	77.0	77.0	77.5	76.7	73.5	70.5	68.5	68.6	70.4	74.4	76.0	76.2
	10%	DB	89.7	89.7	89.9	91.2	89.7	89.9	91.4	96.2	98.1	95.0	92.2	90.3
		MCWB	76.4	76.5	76.9	76.3	73.3	70.2	68.2	68.2	71.1	74.6	75.7	76.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	83.6	83.6	81.5	81.5	79.9	76.7	75.8	76.3	79.6	81.8	83.3	82.9
		MCDB	89.9	89.9	88.6	90.6	89.5	86.9	89.2	90.9	91.7	90.6	91.1	89.8
	2%	WB	80.9	81.4	79.9	79.9	77.9	74.9	73.7	73.9	77.5	79.6	80.9	80.4
		MCDB	85.9	86.6	88.0	88.5	86.8	85.9	87.6	89.5	90.3	88.1	87.4	85.9
	5%	WB	78.8	79.1	78.7	78.4	76.6	73.6	72.2	72.5	75.7	77.8	78.2	78.2
		MCDB	86.1	85.7	87.3	86.7	86.0	85.4	85.7	87.7	89.8	88.7	87.5	86.2
	10%	WB	77.4	77.7	77.8	77.5	75.4	72.5	70.8	71.0	74.3	76.2	76.9	77.1
		MCDB	86.2	85.6	86.6	86.5	84.6	84.2	83.9	86.3	89.1	88.4	87.8	86.5
Mean Daily Temperature Range	5% DB	MDBR	15.2	15.4	15.7	17.0	18.4	21.1	23.8	25.3	22.6	19.4	17.0	15.9
		MCDBR	18.4	18.0	18.3	19.1	21.1	24.4	26.7	27.7	26.1	23.1	20.2	18.5
		MCWBR	5.8	5.8	5.5	5.7	6.1	6.7	7.1	7.1	6.5	5.7	5.8	5.6
	5% WB	MCDBR	16.5	16.1	16.4	17.5	18.3	21.0	22.9	23.2	20.9	19.9	17.7	16.4
		MCWBR	6.2	6.4	6.0	6.4	6.4	7.2	7.9	7.6	6.5	6.4	6.4	6.0
Clear-Sky Solar Irradiance	taub	0.414	0.418	0.401	0.392	0.381	0.393	0.382	0.471	0.671	0.564	0.453	0.434	
	taud	2.430	2.421	2.477	2.473	2.475	2.428	2.428	2.140	1.665	1.962	2.289	2.360	
	Ebn at Noon	295	292	290	281	273	264	270	254	216	249	282	289	
	Edh at Noon	39	39	36	34	32	32	33	47	80	62	45	42	
All-Sky Solar Radiation	RadAvg	1694	1703	1675	1621	1457	1430	1525	1689	1617	1672	1752	1742	
	RadStd	159	114	109	96	95	73	105	99	125	104	115	121	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	-3.51	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page