

BRASILIA, Brazil

WMO: 833780

Lat: 15.863S

Lon: 47.913W

Elev: 3479

StdP: 12.94

Time Zone: -3.00 (SAB)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	50.2	52.2	33.8	32.3	80.6	37.3	37.1	78.3	19.8	70.8	17.9	71.3	1.4	270	0.297

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	20.7	91.0	63.4	89.3	63.7	87.5	64.6	71.9	79.7	71.1	79.1	70.5	78.5	8.3	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.0	125.8	74.3	69.2	122.4	73.7	68.2	118.1	73.1	38.2	80.3	37.4	78.7	36.8	78.4	81.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.6	14.5	13.1	DB	46.3	93.7	2.0	2.0	44.9	95.1	43.7	96.3	42.6	97.4	41.1	98.8	(4)
(5)			WB	43.3	74.4	1.9	2.3	41.9	76.0	40.8	77.4	39.7	78.7	38.3	80.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	72.0	73.9	74.1	73.6	72.9	69.8	67.2	66.8	69.5	73.7	75.3	73.8	73.8
	DBStd	3.89	2.46	2.20	2.17	2.21	3.02	2.68	2.76	3.03	3.22	3.17	2.87	2.55
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	29	0	0	0	0	3	10	14	2	0	0	0	0
	CDD50	8031	740	674	732	686	615	515	520	604	710	783	713	739
	CDD65	2586	275	254	268	236	153	75	69	140	260	318	264	274
	CDH74	19048	1607	1539	1445	1463	1144	792	919	1721	2661	2765	1506	1486
	CDH80	5255	432	409	330	303	181	72	114	468	1046	1112	414	374
Wind	WSAvg	5.2	5.4	5.1	4.9	4.9	4.5	4.7	5.2	5.6	5.9	5.6	5.5	5.5
Precipitation	PrecAvg	59.3	8.9	7.8	8.0	5.2	1.5	0.2	0.3	0.6	1.8	6.2	9.3	9.7
	PrecMax	78.5	23.7	18.1	15.7	14.8	7.0	1.7	3.7	3.7	4.7	20.7	17.7	18.4
	PrecMin	39.6	0.8	1.5	0.8	0.4	0.0	0.0	0.0	0.0	0.0	0.3	2.9	0.9
	PrecStd	9.2	4.8	3.8	3.6	2.9	1.4	0.4	0.7	0.9	1.3	3.8	3.3	3.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.0	89.2	87.9	87.2	86.0	84.2	84.6	89.5	92.8	93.3	91.1	88.8
		MCWB	67.3	67.7	67.9	67.6	65.0	62.1	60.7	61.5	62.4	63.2	64.9	66.8
	2%	DB	86.3	86.4	85.8	84.8	83.9	82.2	82.6	86.4	90.0	91.2	87.4	86.2
		MCWB	67.0	67.4	67.8	66.9	65.0	62.6	60.4	60.5	61.9	63.3	66.3	67.4
	5%	DB	84.5	84.5	83.9	83.6	82.3	80.5	80.9	84.6	88.2	89.3	84.4	84.2
		MCWB	67.0	67.2	68.0	67.0	65.3	61.8	60.2	60.0	62.0	63.6	66.9	67.7
	10%	DB	82.4	82.5	81.9	81.9	80.4	78.8	79.1	82.6	86.2	86.3	82.2	82.1
		MCWB	67.6	67.9	68.2	67.2	64.6	61.5	59.8	59.8	62.1	64.4	67.6	68.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.0	72.5	72.6	72.0	70.9	67.4	65.6	66.4	69.3	71.1	72.0	72.5
		MCDB	79.9	79.7	80.3	79.8	79.1	77.4	77.9	80.7	80.4	80.6	80.0	80.1
	2%	WB	71.5	71.1	71.1	70.9	69.2	65.6	63.7	63.9	67.7	69.8	70.6	71.1
		MCDB	78.8	79.0	79.4	79.0	77.8	76.9	76.8	78.4	78.6	79.6	78.8	78.9
	5%	WB	70.5	70.2	70.2	69.9	67.9	64.2	62.4	62.7	66.5	68.7	69.6	70.2
		MCDB	77.8	78.2	78.6	78.4	76.8	76.0	76.6	77.8	77.4	78.3	77.7	77.9
	10%	WB	69.4	69.3	69.3	69.0	66.6	63.2	61.3	61.5	65.3	67.7	68.9	69.3
		MCDB	76.6	77.2	77.3	77.2	75.8	74.9	75.5	77.5	77.3	77.1	76.4	76.7
Mean Daily Temperature Range	5% DB	MDBR	16.6	17.5	16.9	18.5	21.4	24.1	25.6	26.6	24.5	20.7	16.5	15.9
		MCDBR	21.0	21.1	20.4	21.1	23.1	26.1	27.8	29.2	28.2	26.2	20.8	20.2
		MCWBR	6.9	6.9	7.0	7.6	8.6	10.2	10.2	9.4	8.6	7.4	6.3	6.7
	5% WB	MCDBR	16.5	17.0	17.0	17.6	19.5	23.1	24.6	25.0	20.6	18.2	16.2	16.1
		MCWBR	6.6	6.6	6.8	7.3	8.0	9.9	10.0	9.2	7.3	6.3	6.2	6.5
Clear-Sky Solar Irradiance	taub	0.372	0.373	0.364	0.354	0.334	0.310	0.311	0.348	0.460	0.442	0.400	0.382	
	taud	2.494	2.478	2.532	2.517	2.549	2.622	2.585	2.440	2.132	2.235	2.390	2.452	
	Ebn at Noon	308	305	301	293	289	291	293	291	268	281	298	305	
	Edh at Noon	37	37	34	33	30	26	28	35	50	47	41	38	
All-Sky Solar Radiation	RadAvg	1814	1846	1735	1705	1584	1533	1622	1832	1896	1869	1678	1739	
	RadStd	214	151	132	111	75	59	61	100	150	200	139	161	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page