

ANAPOLIS, Brazil

WMO: 834190

Lat: 16.229S

Lon: 48.964W

Elev: 3728

StdP: 12.82

Time Zone: -3.00 (SAB)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	55.3	57.2	33.4	32.1	76.9	37.1	37.1	75.5	18.3	69.5	16.6	69.6	8.4	100	0.295

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	21.5	91.2	64.6	89.3	65.2	87.5	66.0	74.7	81.3	73.9	80.8	73.1	80.1	7.4	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.2	141.8	78.1	71.8	135.4	77.1	71.3	133.1	76.7	41.1	81.8	40.3	81.0	39.4	80.5	79.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.1	14.8	13.1	DB	50.0	94.3	2.4	1.3	48.3	95.2	46.9	95.9	45.5	96.6	43.8	97.5	(4)
(5)			WB	45.3	74.7	3.3	2.1	42.9	76.2	41.0	77.4	39.1	78.6	36.8	80.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	72.8	73.3	73.8	73.4	72.9	71.0	69.7	69.5	72.2	75.6	75.6	73.5	72.7
	DBStd	3.75	3.09	2.87	2.92	3.02	3.06	2.99	3.37	3.44	3.76	4.05	3.08	3.03
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	17	0	0	0	0	2	5	7	1	1	1	0	0
	CDD50	8311	722	667	726	687	650	590	606	689	769	794	706	705
	CDD65	2852	257	247	261	237	187	145	148	224	320	330	256	240
	CDH74	17599	1354	1301	1220	1230	1066	856	1038	1826	2831	2505	1317	1055
	CDH80	4868	358	319	275	262	170	105	168	525	1146	970	344	226
Wind	WSAvg	6.3	5.8	5.4	5.3	5.9	6.4	6.5	7.3	7.5	7.5	6.7	5.8	5.6
Precipitation	PrecAvg	59.8	10.1	8.6	9.1	4.1	1.0	0.2	0.1	0.4	1.8	5.0	9.0	10.5
	PrecMax	84.3	17.4	14.9	14.5	7.7	2.9	2.5	0.9	1.5	4.1	12.8	13.3	16.5
	PrecMin	48.0	3.3	5.6	3.3	0.0	0.1	0.0	0.0	0.0	0.2	1.7	6.0	5.6
	PrecStd	7.9	3.6	2.4	2.8	1.9	0.7	0.5	0.2	0.5	1.1	2.4	1.9	2.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.4	88.1	87.8	87.7	86.2	84.6	86.1	89.7	93.3	93.6	89.7	87.7
		MCWB	67.4	71.6	71.2	71.0	68.7	64.6	64.4	64.4	64.6	65.4	68.3	70.7
	2%	DB	86.2	86.0	85.6	85.6	83.9	82.6	83.9	87.5	91.3	91.3	86.3	84.5
		MCWB	69.0	70.1	70.8	71.2	67.6	65.0	62.8	62.8	63.1	65.2	69.1	69.4
	5%	DB	84.2	84.0	82.8	82.8	82.1	80.8	82.1	85.5	89.4	88.2	84.1	82.5
		MCWB	68.9	69.8	70.9	70.6	66.6	63.8	61.8	61.5	63.0	65.0	69.4	69.8
	10%	DB	81.0	82.1	80.8	80.7	80.3	79.0	80.3	82.7	86.4	85.9	81.0	80.4
		MCWB	69.4	69.8	70.4	69.5	65.8	62.9	61.3	60.9	62.7	65.8	69.3	69.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.8	76.1	75.5	74.9	72.2	68.9	68.8	68.6	72.5	74.2	74.5	74.9
		MCDB	81.5	82.3	81.5	81.9	80.2	79.2	79.3	80.0	81.7	82.7	81.6	81.1
	2%	WB	73.6	74.4	74.4	73.8	70.5	67.0	66.2	65.8	70.4	72.6	73.2	73.5
		MCDB	80.6	80.8	80.7	81.1	79.4	77.5	78.4	80.0	80.3	81.4	80.6	79.7
	5%	WB	72.6	73.2	73.3	72.6	69.1	65.9	64.4	64.3	68.6	71.1	72.0	72.4
		MCDB	79.2	79.9	79.8	79.8	77.8	77.0	76.9	80.1	78.4	80.0	79.6	78.3
	10%	WB	71.2	71.8	72.1	71.4	67.7	64.6	63.0	62.8	66.9	69.8	70.8	71.0
		MCDB	77.2	78.2	77.8	78.1	76.0	76.1	76.3	78.8	77.6	78.8	77.9	76.5
Mean Daily Temperature Range	5% DB	MDBR	15.6	16.4	15.6	16.8	18.6	19.7	21.2	22.0	21.5	18.8	16.3	14.7
		MCDBR	19.6	18.8	18.1	18.6	20.2	21.0	22.3	23.4	24.0	22.3	19.8	18.4
		MCWBR	7.6	7.7	7.5	7.7	8.0	8.0	8.4	8.5	8.1	7.5	7.3	7.4
	5% WB	MCDBR	15.6	16.5	15.9	17.1	18.6	19.8	21.2	22.0	19.2	18.2	17.0	14.9
		MCWBR	7.9	8.6	8.2	8.1	8.5	8.2	8.9	9.1	8.0	7.9	8.1	7.9
Clear-Sky Solar Irradiance	taub	0.369	0.368	0.360	0.349	0.323	0.308	0.312	0.352	0.460	0.438	0.395	0.382	
	taud	2.494	2.488	2.529	2.528	2.575	2.614	2.565	2.411	2.118	2.238	2.393	2.443	
	Ebn at Noon	309	306	302	294	292	292	293	289	268	282	299	305	
	Edh at Noon	37	37	34	32	29	27	29	36	51	47	41	39	
All-Sky Solar Radiation	RadAvg	1776	1820	1734	1718	1588	1525	1613	1820	1859	1846	1693	1725	
	RadStd	209	129	130	109	66	57	64	97	152	169	125	149	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page