

ANAPOLIS, Brazil

WMO: 834190

Lat: 16.229S

Lon: 48.964W

Elev: 1136

StdP: 88.40

Time Zone: -3.00 (SAB)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	12.9	14.0	0.8	4.6	24.9	2.8	5.3	24.1	8.2	20.8	7.4	20.9	3.7	100	0.295

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	12.0	32.9	18.1	31.8	18.4	30.8	18.9	23.7	27.4	23.3	27.1	22.8	26.7	3.3	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.9	20.3	25.6	22.1	19.3	25.1	21.9	19.0	24.8	77.6	27.6	75.9	27.2	73.9	26.9	26.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.7	6.6	5.9	DB	10.0	34.6	1.3	0.7	9.0	35.1	8.3	35.5	7.5	35.9	6.5	36.4	(4)
(5)			WB	7.4	23.7	1.8	1.2	6.1	24.5	5.0	25.2	4.0	25.9	2.6	26.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	22.6	22.9	23.2	23.0	22.7	21.6	20.9	20.9	22.3	24.2	24.2	23.1	22.6	(6)
(7)		DBStd	2.08	1.72	1.59	1.62	1.68	1.70	1.66	1.87	1.91	2.09	2.25	1.71	1.68	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	9	0	0	0	0	1	3	4	1	1	1	0	0	(9)
(10)		CDD10.0	4617	401	371	403	382	361	328	337	383	427	441	392	392	(10)
(11)		CDD18.3	1584	143	137	145	132	104	81	82	124	178	183	142	133	(11)
(12)		CDH23.3	9777	752	723	678	683	592	476	577	1014	1573	1392	732	586	(12)
(13)		CDH26.7	2704	199	177	153	146	94	58	93	292	637	539	191	126	(13)
(14)	Wind	WSAvg	2.8	2.6	2.4	2.4	2.7	2.9	2.9	3.3	3.4	3.4	3.0	2.6	2.5	(14)
(15)	Precipitation	PrecAvg	1520	256	218	231	104	26	6	2	10	45	127	229	266	(15)
(16)		PrecMax	2141	441	378	368	195	73	64	24	38	104	324	338	418	(16)
(17)		PrecMin	1220	85	142	84	1	3	0	0	0	5	44	152	142	(17)
(18)		PrecStd	200	92	61	71	49	17	12	5	13	27	61	48	67	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.9	31.2	31.0	31.0	30.1	29.2	30.0	32.1	34.1	34.2	32.0	30.9	(19)
(20)			MCWB	19.7	22.0	21.8	21.7	20.4	18.1	18.0	18.0	18.1	18.6	20.1	21.5	(20)
(21)		2%	DB	30.1	30.0	29.8	29.8	28.8	28.1	28.8	30.8	33.0	32.9	30.2	29.2	(21)
(22)			MCWB	20.5	21.2	21.5	21.8	19.8	18.3	17.1	17.1	17.3	18.5	20.6	20.8	(22)
(23)		5%	DB	29.0	28.9	28.2	28.2	27.8	27.1	27.9	29.7	31.9	31.2	28.9	28.0	(23)
(24)			MCWB	20.5	21.0	21.6	21.5	19.2	17.6	16.6	16.4	17.2	18.3	20.8	21.0	(24)
(25)		10%	DB	27.2	27.8	27.1	27.1	26.8	26.1	26.9	28.2	30.2	30.0	27.2	26.9	(25)
(26)			MCWB	20.8	21.0	21.3	20.8	18.8	17.2	16.3	16.1	17.1	18.8	20.7	20.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.8	24.5	24.2	23.8	22.3	20.5	20.5	20.4	22.5	23.5	23.6	23.8	(27)
(28)			MCD B	27.5	27.9	27.5	27.7	26.8	26.2	26.3	26.7	27.6	28.2	27.5	27.3	(28)
(29)		2%	WB	23.1	23.6	23.5	23.2	21.4	19.5	19.0	18.8	21.3	22.5	22.9	23.1	(29)
(30)			MCD B	27.0	27.1	27.1	27.3	26.3	25.3	25.8	26.6	26.8	27.4	27.0	26.5	(30)
(31)		5%	WB	22.5	22.9	22.9	22.6	20.6	18.8	18.0	17.9	20.3	21.7	22.2	22.4	(31)
(32)			MCD B	26.2	26.6	26.6	26.6	25.4	25.0	25.0	26.7	25.8	26.7	26.4	25.7	(32)
(33)		10%	WB	21.8	22.1	22.3	21.9	19.9	18.1	17.2	17.1	19.4	21.0	21.6	21.7	(33)
(34)			MCD B	25.1	25.7	25.5	25.6	24.5	24.5	24.6	26.0	25.3	26.0	25.5	24.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.7	9.1	8.7	9.3	10.3	11.0	11.8	12.2	12.0	10.5	9.0	8.2	(35)
(36)			MCDBR	10.9	10.4	10.1	10.3	11.2	11.7	12.4	13.0	13.3	12.4	11.0	10.2	(36)
(37)			MCWBR	4.2	4.3	4.2	4.3	4.4	4.5	4.7	4.7	4.5	4.2	4.1	4.1	(37)
(38)		5% WB	MCD BR	8.7	9.1	8.8	9.5	10.3	11.0	11.8	12.2	10.7	10.1	9.4	8.3	(38)
(39)			MCWBR	4.4	4.8	4.5	4.5	4.7	4.6	4.9	5.0	4.5	4.4	4.5	4.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.369	0.368	0.360	0.349	0.323	0.308	0.312	0.352	0.460	0.438	0.395	0.382	(40)	
(41)		taud	2.494	2.488	2.529	2.528	2.575	2.614	2.565	2.411	2.118	2.238	2.393	2.443	(41)	
(42)		Ebn at Noon	975	966	952	928	921	919	923	911	845	890	943	961	(42)	
(43)		Edh at Noon	116	116	108	101	90	84	90	112	160	147	128	122	(43)	
(44)	All-Sky Solar Radiation	RadAvg	5.60	5.74	5.47	5.42	5.01	4.81	5.08	5.74	5.86	5.82	5.34	5.44	(44)	
(45)		RadStd	0.66	0.41	0.41	0.34	0.21	0.18	0.20	0.31	0.48	0.53	0.39	0.47	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page