

BAURU, BrazilWMO: **837220**Lat: **22.345S**Lon: **49.054W**Elev: **617**StdP: **94.13**Time Zone: **-3.00 (SAB)**Period: **95-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	11.3	4.1	5.5	16.5	6.2	6.3	17.5	11.6	14.8	10.4	15.0	5.0	120	0.369

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	9.4	35.0	23.2	33.9	22.8	33.0	22.8	25.9	30.9	25.4	30.3	25.0	29.7	3.4	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.8	21.5	28.7	24.1	20.5	27.7	23.8	20.2	27.4	84.5	31.0	81.7	30.5	79.7	30.0	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.2	9.3	8.1	6.4	36.7	2.1	1.4	4.9	37.7	3.6	38.6	2.5	39.4	0.9	40.4		
(5)			5.5	27.1	2.1	1.1	4.0	27.9	2.7	28.5	1.6	29.1	0.0	29.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.4	25.5	26.1	25.4	23.8	20.9	20.2	20.1	21.8	23.3	24.0	24.5	25.3
	DBStd	3.38	2.31	2.11	1.98	2.28	2.95	2.95	3.32	3.20	3.37	2.89	2.21	2.05
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	64	0	0	0	1	11	16	22	9	3	1	0	0
	CDD10.0	4886	479	449	477	413	338	306	313	366	399	436	436	474
	CDD18.3	1909	221	216	218	164	91	72	78	117	152	178	186	216
	CDH23.3	15809	1769	1878	1767	1238	566	409	542	1033	1517	1667	1604	1818
CDH26.7	5965	708	771	669	388	123	66	116	357	682	739	634	712	
Wind	WSAvg	3.7	3.4	3.2	3.6	3.7	3.5	3.2	3.8	4.1	4.3	4.2	3.8	3.5
Precipitation	PrecAvg	1352	237	218	159	71	69	44	28	26	78	111	121	181
	PrecMax	1571	384	421	252	166	128	151	65	80	172	178	195	301
	PrecMin	954	88	121	72	3	6	6	0	0	0	27	57	16
	PrecStd	183	86	92	56	46	31	41	21	28	50	41	51	67
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.6	35.8	34.1	32.2	31.0	30.0	30.8	33.8	36.1	36.8	34.6	34.9
		MCWB	25.4	23.9	24.5	22.9	22.8	20.9	18.6	19.4	21.0	22.7	23.4	24.1
	2%	DB	33.8	33.9	32.9	31.2	29.2	28.2	29.2	31.8	34.1	34.9	33.0	33.2
		MCWB	24.7	23.8	24.4	22.6	21.4	19.9	18.7	19.0	20.3	22.7	23.0	23.5
	5%	DB	32.1	32.4	31.8	30.2	28.0	27.1	28.0	30.1	32.8	33.0	31.9	32.0
		MCWB	24.3	23.9	23.9	22.4	20.7	19.5	18.5	18.5	19.9	22.2	22.4	23.2
	10%	DB	30.8	31.1	30.2	29.1	26.8	25.9	26.8	28.8	30.9	30.9	30.2	30.6
		MCWB	24.0	23.7	23.6	22.1	20.1	19.1	18.0	18.3	19.8	21.9	22.3	23.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.9	26.4	26.5	25.5	24.5	23.2	21.7	21.6	24.2	25.4	25.7	26.2
		MCDB	33.1	31.1	31.2	29.2	28.7	26.9	26.7	29.2	30.6	32.0	31.1	31.1
	2%	WB	25.8	25.5	25.6	24.6	22.8	21.9	20.3	20.4	22.9	24.3	24.8	25.4
		MCDB	31.1	30.3	30.3	28.4	27.3	26.0	25.5	28.0	28.5	31.2	29.7	30.1
	5%	WB	25.1	25.0	25.0	23.9	21.7	20.9	19.4	19.6	22.0	23.4	24.1	24.7
		MCDB	30.0	29.7	29.5	27.8	26.0	24.6	25.1	27.1	28.3	29.7	29.0	29.3
	10%	WB	24.6	24.5	24.4	23.1	20.9	20.0	18.8	18.9	21.1	22.7	23.5	24.1
		MCDB	29.0	29.0	28.5	27.0	25.0	23.7	24.5	26.2	27.3	28.5	28.2	28.4
Mean Daily Temperature Range	5% DB	MDBR	9.0	9.4	9.4	9.8	9.4	9.6	10.9	12.1	12.1	11.3	10.7	9.8
		MCDBR	11.4	11.1	10.9	10.8	10.5	10.8	11.9	13.5	14.1	14.4	12.9	12.0
		MCWBR	4.4	4.1	4.1	4.2	4.6	4.7	4.6	5.0	4.8	5.0	5.0	4.6
	5% WB	MCDBR	10.2	9.8	9.7	9.4	9.5	9.1	10.5	12.5	12.3	12.1	10.4	9.9
		MCWBR	4.5	4.4	4.4	4.3	4.6	4.7	4.9	5.6	5.6	5.2	4.8	4.5
Clear-Sky Solar Irradiance	taub		0.394	0.395	0.388	0.374	0.349	0.353	0.359	0.403	0.496	0.450	0.413	0.399
	taud		2.445	2.424	2.445	2.457	2.495	2.479	2.446	2.288	2.026	2.226	2.340	2.405
	Ebn at Noon		951	936	916	887	871	845	851	844	803	875	926	947
	Edh at Noon		122	123	115	105	93	91	97	122	172	148	135	127
All-Sky Solar Radiation	RadAvg		5.58	5.82	5.44	4.95	4.03	3.72	3.94	4.76	5.23	5.74	6.03	6.06
	RadStd		0.72	0.43	0.44	0.34	0.28	0.31	0.34	0.35	0.47	0.44	0.39	0.43

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page