

IQUITOS, Peru

WMO: 843770

Lat: 3.785S

Lon: 73.309W

Elev: 306

StdP: 14.53

Time Zone: -5.00 (W05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	66.6	69.4	64.0	90.3	70.3	66.2	97.6	72.7	13.2	78.6	10.9	79.0	2.0	170	0.255

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	16.8	93.6	79.3	92.9	79.3	91.5	79.1	81.0	90.3	80.7	89.7	80.1	88.7	6.0	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.6	150.4	87.9	77.6	145.1	86.5	77.3	143.9	86.2	45.2	91.2	44.5	90.7	44.0	89.9	90.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.1	9.9	8.7	62.5	96.3	4.4	1.3	59.4	97.3	56.8	98.0	54.3	98.8	51.1	99.7		
(5)			61.2	82.9	4.0	1.9	58.3	84.3	56.0	85.4	53.7	86.4	50.8	87.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.3	80.7	80.6	80.5	80.2	79.7	79.0	78.7	80.0	80.9	81.2	81.1	80.7	
	DBStd	2.47	2.30	2.18	2.08	2.38	2.30	2.65	2.79	2.39	2.56	2.17	2.25	2.00	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD50	11050	953	856	945	906	921	870	891	929	926	967	934	952	
	CDD65	5575	488	436	480	456	456	420	426	464	476	502	484	487	
	CDH74	44045	3915	3477	3777	3554	3402	2936	3044	3741	4028	4229	4035	3907	
	CDH80	16506	1454	1249	1331	1223	1099	954	1081	1561	1770	1752	1597	1435	
Wind	WSAvg	2.8	3.0	2.9	2.8	2.6	2.7	2.5	2.4	2.6	2.8	3.0	3.0	3.0	
Precipitation	PrecAvg	111.0	11.5	10.4	12.0	11.5	10.6	7.7	7.3	6.8	7.5	9.6	10.8	12.3	
	PrecMax	169.2	25.4	22.9	27.8	20.9	29.6	14.8	18.2	18.5	13.5	25.1	25.1	35.7	
	PrecMin	60.7	0.3	2.5	1.3	3.8	4.4	2.4	0.9	2.4	2.4	0.0	3.0	2.5	
	PrecStd	23.5	6.2	4.8	5.7	4.4	5.3	3.2	3.4	3.3	3.2	5.0	5.4	6.1	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	94.1	93.5	93.1	92.3	91.6	91.3	91.5	93.4	95.2	95.1	94.7	93.2	
		MCWB	79.2	78.7	80.0	79.9	79.3	79.0	78.6	78.7	78.5	80.0	80.3	79.7	
	2%	DB	91.8	91.5	91.1	90.4	89.8	89.5	89.7	91.6	93.3	93.1	92.6	91.4	
		MCWB	79.3	78.8	79.5	79.2	78.9	78.8	78.1	78.3	78.9	79.5	79.8	79.3	
	5%	DB	89.9	89.6	89.4	89.2	88.0	87.7	88.0	89.9	91.5	91.3	91.0	89.7	
		MCWB	79.1	78.7	79.0	78.9	78.6	78.4	77.8	78.2	78.8	79.1	79.5	79.0	
	10%	DB	87.8	87.5	87.4	87.2	86.1	85.8	86.1	88.1	89.6	89.3	88.5	87.8	
		MCWB	78.8	78.6	78.6	78.5	78.0	77.8	77.4	78.0	78.4	78.8	79.0	78.7	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.6	80.9	81.0	81.1	80.8	80.5	80.5	80.9	81.3	81.7	81.7	81.0
			MCDB	91.4	89.9	89.9	89.6	89.0	88.5	88.8	90.1	91.2	92.0	91.4	89.9
2%		WB	80.4	80.0	80.1	80.0	79.7	79.5	79.4	80.0	80.4	80.5	80.6	80.1	
		MCDB	89.4	88.3	88.4	88.0	87.3	86.9	87.0	88.8	90.0	90.3	90.1	88.6	
5%		WB	79.5	79.2	79.3	79.2	79.0	78.8	78.7	79.2	79.6	79.7	79.8	79.4	
		MCDB	87.6	86.8	86.9	86.6	86.2	85.8	85.8	87.6	88.8	88.9	88.6	87.5	
10%		WB	78.7	78.6	78.7	78.7	78.3	78.0	77.7	78.4	78.8	78.9	79.1	78.7	
		MCDB	86.1	85.7	85.9	85.6	84.9	84.5	84.5	86.4	87.6	87.5	87.0	86.3	
Mean Daily Temperature Range	5% DB	MDBR	15.0	14.9	14.5	14.3	13.9	14.2	15.6	17.3	17.8	16.8	16.0	15.1	
		MCDBR	18.0	17.7	17.4	17.0	16.4	16.7	18.1	19.7	20.7	19.8	18.8	17.8	
		MCWBR	7.7	7.6	7.8	7.6	7.5	7.8	8.6	8.8	8.7	8.6	8.3	7.9	
	5% WB	MCDBR	16.7	16.1	16.1	15.8	15.1	15.5	16.8	18.4	19.1	18.3	17.5	16.6	
		MCWBR	7.9	7.7	7.8	7.7	7.5	8.0	9.1	9.2	9.0	8.7	8.5	8.0	
Clear-Sky Solar Irradiance	taub	0.399	0.402	0.396	0.391	0.377	0.382	0.404	0.471	0.496	0.440	0.433	0.405		
	taud	2.510	2.497	2.524	2.529	2.588	2.565	2.484	2.262	2.193	2.366	2.389	2.482		
	Ebn at Noon	297	296	294	288	284	278	274	261	262	281	285	294		
	Edh at Noon	36	36	35	34	30	30	33	43	48	41	40	36		
All-Sky Solar Radiation	RadAvg	1392	1385	1380	1363	1300	1287	1328	1470	1574	1542	1482	1420		
	RadStd	100	97	67	64	67	80	87	74	96	56	83	78		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.31	+0.77	N/A	N/A	N/A	N/A	N/A	+117	+117
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page