

PIURA, Peru

WMO: 844010

Lat: 5.206S

Lon: 80.616W

Elev: 116

StdP: 14.63

Time Zone: -5.00 (W05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	60.6	61.6	55.2	65.2	62.1	56.3	67.8	63.1	19.7	74.6	18.4	73.6	3.2	150	0.328

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	16.8	93.3	77.6	91.9	76.9	90.9	76.4	79.4	89.9	78.6	89.2	77.6	88.2	9.3	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.7	139.5	84.8	75.5	134.3	84.6	74.5	129.6	84.7	43.0	89.7	42.3	89.6	41.2	88.0	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.7	17.1	15.7	DB	59.0	96.6	3.1	1.3	56.8	97.5	55.0	98.3	53.2	99.0	51.0	99.9	(4)
(5)			WB	55.7	80.5	2.7	2.0	53.8	81.9	52.2	83.1	50.7	84.3	48.7	85.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	76.9	81.5	83.1	82.7	80.4	77.2	74.1	72.5	72.6	72.9	73.6	75.0	78.0
	DBStd	4.59	1.95	1.80	1.90	2.27	2.75	2.98	2.70	2.30	2.59	2.39	2.59	2.71
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	9832	978	926	1015	911	844	723	696	700	688	731	751	869
	CDD65	4357	513	506	550	461	379	273	231	235	238	266	301	404
	CDH74	32730	4664	5178	5569	4025	2663	1435	963	992	1169	1396	1754	2922
CDH80	11555	1894	2144	2328	1585	841	305	151	158	243	327	503	1076	
Wind	WSAvg	6.7	6.7	5.7	5.5	6.1	6.7	6.3	6.5	7.0	7.4	7.6	7.3	7.2
Precipitation	PrecAvg	1.8	0.2	0.6	0.9	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1
	PrecMax	6.1	2.1	3.5	6.6	2.6	0.3	0.7	0.4	0.0	0.1	0.4	0.3	0.8
	PrecMin	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	1.6	0.4	0.8	1.5	0.4	0.1	0.1	0.1	0.0	0.0	0.1	0.1	0.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.6	95.2	95.2	92.9	90.6	87.9	86.2	86.3	87.5	87.6	89.4	91.7
		MCWB	77.2	78.6	78.4	77.3	75.9	74.7	74.4	73.8	74.5	74.5	75.3	76.2
	2%	DB	92.0	93.2	93.3	91.2	88.7	85.6	83.7	83.6	84.7	85.3	86.8	89.7
		MCWB	76.4	77.7	77.7	76.4	75.0	73.3	72.1	71.5	72.3	72.6	73.3	75.0
	5%	DB	90.6	91.6	91.8	89.9	86.9	83.5	81.4	81.5	82.7	83.6	85.0	88.0
		MCWB	75.8	77.0	77.1	75.9	74.4	72.2	70.7	70.1	70.9	71.4	72.3	73.9
	10%	DB	89.2	90.1	90.2	88.3	85.0	81.5	79.2	79.6	80.7	81.6	83.0	86.1
		MCWB	75.2	76.5	76.5	75.4	73.6	71.2	69.7	69.2	69.9	70.2	71.1	73.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.2	80.7	80.9	80.1	77.6	76.5	76.2	75.4	76.3	75.8	77.0	78.0
		MCDB	90.1	91.3	91.0	89.6	87.3	85.7	84.2	84.8	85.7	85.9	87.6	89.3
	2%	WB	78.1	79.2	79.5	78.1	76.4	74.5	73.4	72.8	73.6	73.6	74.7	76.6
		MCDB	89.2	90.1	89.9	88.5	86.5	83.7	81.6	81.6	83.2	84.0	85.2	87.2
	5%	WB	77.0	78.3	78.6	77.0	75.2	72.9	71.5	71.0	71.6	72.0	72.9	75.2
		MCDB	88.4	89.2	89.0	87.8	85.5	81.9	79.8	80.0	81.5	82.3	83.6	85.9
	10%	WB	75.9	77.2	77.5	75.9	73.8	71.7	70.1	69.6	70.1	70.5	71.5	73.7
		MCDB	87.0	87.9	87.5	86.4	84.0	80.4	78.3	78.7	79.7	80.5	82.2	84.5
Mean Daily Temperature Range	5% DB	MDBR	17.7	16.8	17.4	18.2	17.5	16.5	16.3	17.6	18.6	18.9	19.0	18.9
		MCDBR	19.1	18.2	18.9	19.2	18.9	18.0	18.2	19.0	20.0	20.2	20.2	19.9
		MCWBR	8.9	8.4	8.6	9.3	9.6	9.3	9.7	10.0	10.8	10.9	10.6	9.6
	5% WB	MCDBR	18.1	17.0	17.3	18.3	18.4	16.9	17.2	18.4	19.5	19.8	19.9	19.5
		MCWBR	9.4	8.5	8.6	10.0	10.5	10.0	10.8	11.3	11.8	11.8	11.6	10.9
Clear-Sky Solar Irradiance	taub	0.455	0.447	0.445	0.477	0.488	0.475	0.470	0.515	0.552	0.493	0.489	0.475	
	taud	2.275	2.313	2.324	2.217	2.158	2.204	2.217	2.059	1.956	2.137	2.133	2.196	
	Ebn at Noon	281	283	280	263	251	250	253	249	247	267	269	274	
	Edh at Noon	45	44	43	46	47	43	43	53	61	51	52	49	
All-Sky Solar Radiation	RadAvg	1809	1721	1807	1853	1678	1477	1513	1689	1926	1999	2024	1947	
	RadStd	176	109	105	80	132	175	149	132	82	75	105	111	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page