

CHICLAYO, Peru

WMO: 844520

Lat: 6.787S

Lon: 79.828W

Elev: 30

StdP: 100.97

Time Zone: -5.00 (W05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.9	15.2	12.8	9.2	17.0	12.9	9.3	16.9	10.5	20.5	10.0	20.4	3.9	170	0.465

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.8	32.2	24.2	31.2	23.8	30.7	23.5	25.6	29.8	24.9	29.2	24.2	29.2	5.0	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.2	19.2	28.1	23.6	18.5	27.9	22.7	17.4	27.4	78.7	29.4	76.0	29.2	73.0	29.2	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.4	9.7	9.0	14.3	33.6	1.2	1.5	13.4	34.6	12.7	35.5	12.1	36.4	11.2	37.5		
			13.1	26.0	1.2	1.4	12.2	27.0	11.5	27.8	10.8	28.6	9.9	29.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	22.7	25.3	26.6	26.4	24.5	22.9	21.4	20.5	20.1	20.2	20.6	21.5	23.2	(6)
	DBStd	2.75	1.58	1.26	1.46	1.62	1.71	1.76	1.51	1.42	1.41	1.28	1.40	1.55	(7)
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD18.3	1	0	0	0	0	0	0	1	1	0	0	0	0	(9)
	CDD10.0	4651	474	464	508	436	399	341	324	314	307	329	345	409	(10)
	CDD18.3	1611	216	231	249	186	141	91	67	56	58	71	95	151	(11)
	CDH23.3	8440	1372	1749	1871	1062	606	261	135	101	118	156	296	712	(12)
	CDH26.7	2366	431	638	669	301	107	31	11	8	11	8	23	128	(13)
(14) Wind	WSAvg	5.0	5.0	4.3	4.2	4.9	5.3	4.9	4.8	4.9	5.4	5.5	5.4	5.4	(14)
(15) Precipitation	PrecAvg	20	3	3	8	2	1	0	0	0	0	1	1	1	(15)
	PrecMax	73	32	14	69	11	35	13	5	10	10	7	23	6	(16)
	PrecMin	4	0	0	0	0	0	0	0	0	0	0	0	0	(17)
	PrecStd	16	6	3	12	3	5	2	1	2	2	2	4	2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.9	33.2	33.2	32.1	30.2	29.2	28.2	27.9	28.2	27.9	28.9	31.0	(19)
		MCWB	24.8	24.5	24.5	24.0	22.7	22.7	22.0	21.8	21.9	21.0	22.4	24.0	(20)
	2%	DB	31.2	32.1	32.1	30.9	29.1	27.2	26.0	25.6	25.8	26.0	27.1	29.1	(21)
		MCWB	23.6	24.2	24.2	23.4	22.2	21.5	20.4	20.0	20.0	19.6	20.7	22.2	(22)
	5%	DB	30.1	31.2	31.2	29.8	27.9	26.0	24.8	24.2	24.5	25.0	26.0	28.1	(23)
		MCWB	23.1	23.8	23.9	22.7	21.6	20.5	19.6	19.2	19.2	19.3	20.1	21.7	(24)
	10%	DB	29.1	30.2	30.2	28.4	26.8	24.8	23.8	23.2	23.8	24.0	25.0	27.0	(25)
		MCWB	22.6	23.4	23.5	22.1	21.0	20.0	19.1	18.6	18.8	18.7	19.6	21.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.0	26.5	26.2	25.1	23.5	23.1	22.2	22.1	22.1	21.2	22.6	24.6	(27)
		MCDB	31.6	30.4	30.5	30.5	29.5	28.6	27.4	27.0	27.7	27.0	27.8	29.3	(28)
	2%	WB	24.9	25.7	25.5	24.0	22.6	22.1	21.0	20.9	20.7	20.1	21.3	23.4	(29)
		MCDB	29.1	29.4	29.7	29.3	28.1	26.3	24.8	24.6	24.6	25.2	25.9	27.7	(30)
	5%	WB	23.9	24.9	24.8	23.1	21.9	21.3	20.0	19.7	19.7	19.5	20.5	22.2	(31)
		MCDB	28.8	28.9	29.2	28.6	26.9	25.0	24.0	23.8	23.8	24.3	25.2	27.2	(32)
	10%	WB	23.0	24.1	24.1	22.4	21.2	20.4	19.2	18.7	18.8	18.9	19.8	21.3	(33)
		MCDB	28.4	29.4	29.1	27.6	25.4	24.0	23.3	22.9	23.2	23.5	24.6	26.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.8	8.8	8.8	8.9	8.1	7.2	7.1	7.3	7.8	8.0	8.2	8.5	(35)
		MCDBR	9.3	9.4	9.4	9.8	9.0	8.2	8.0	8.2	8.5	8.6	8.9	9.2	(36)
	5% WB	MCWBR	3.8	3.7	3.9	4.2	4.0	3.8	3.8	4.0	4.0	4.0	4.1	3.9	(37)
		MCWBR	8.9	8.3	8.4	9.3	8.3	7.4	7.6	7.9	8.1	8.3	8.5	8.7	(38)
(40) Clear-Sky Solar Irradiance	taub		0.431	0.427	0.433	0.452	0.449	0.431	0.426	0.462	0.499	0.461	0.456	0.447	(40)
		taud	2.404	2.421	2.411	2.346	2.343	2.405	2.414	2.282	2.170	2.299	2.298	2.343	(41)
	Ebn at Noon		909	911	892	848	822	823	835	827	822	869	880	891	(42)
		Edh at Noon	126	124	123	126	121	111	112	133	155	138	139	133	(43)
(44) All-Sky Solar Radiation	RadAvg		5.75	5.53	5.56	5.64	5.08	4.36	4.43	4.79	5.44	5.87	6.14	5.99	(44)
	RadStd		0.41	0.30	0.30	0.28	0.47	0.54	0.43	0.38	0.33	0.32	0.40	0.38	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page