

TRUJILLO, Peru

WMO: 845010

Lat: 8.081S

Lon: 79.109W

Elev: 32

StdP: 100.94

Time Zone: -5.00 (W05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	14.4	14.8	12.6	9.1	15.4	12.8	9.3	15.6	7.3	18.9	6.9	18.7	3.1	160	0.348

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.1	28.1	23.6	27.1	23.2	26.2	22.6	24.2	27.1	23.6	26.6	23.0	26.1	4.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.1	17.9	26.3	22.2	17.0	26.1	21.8	16.5	25.9	72.9	27.0	70.5	26.8	68.2	26.2	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.7	6.3	6.0	13.5	28.4	1.7	1.2	12.3	29.2	11.3	29.9	10.4	30.6	9.1	31.5		
			12.6	23.4	1.6	1.5	11.5	24.4	10.6	25.3	9.7	26.1	8.6	27.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.0	22.0	22.9	22.7	20.8	20.1	19.4	18.6	18.0	17.9	18.1	18.9	20.2
	DBStd	2.48	1.95	1.97	2.04	1.71	1.72	1.95	1.79	1.75	1.69	1.42	1.42	1.87
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	116	0	0	0	1	4	10	17	26	27	23	7	2
	CDD10.0	3634	373	362	392	325	313	283	266	248	238	250	268	317
	CDD18.3	709	115	129	134	76	58	43	24	16	14	14	25	60
	CDH23.3	1527	299	462	466	93	32	31	17	13	6	4	14	89
	CDH26.7	126	26	49	46	3	0	0	0	0	0	0	0	2
Wind	WSAvg	3.6	3.5	3.4	3.5	3.6	3.7	3.5	3.6	3.7	4.0	3.9	3.7	3.6
Precipitation	PrecAvg	35	4	7	10	2	1	1	1	0	1	2	2	3
	PrecMax	97	37	19	40	6	12	4	5	1	4	3	9	44
	PrecMin	14	0	0	3	0	0	0	0	0	0	0	0	0
	PrecStd	18	7	5	9	1	2	1	1	0	1	1	2	8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.6	29.1	29.0	27.1	25.1	25.3	25.0	24.7	24.2	24.0	25.0	26.9
		MCWB	23.5	24.2	24.6	22.8	20.5	20.3	20.1	20.2	20.2	19.3	20.6	22.6
	2%	DB	27.4	28.1	27.9	25.5	24.1	24.2	23.6	23.4	22.9	22.8	23.5	25.5
		MCWB	23.1	23.8	23.8	21.8	20.3	20.2	19.8	19.8	19.5	19.4	20.0	21.7
	5%	DB	26.2	27.1	27.0	24.2	23.4	23.1	22.2	22.2	21.6	21.2	22.1	24.2
		MCWB	22.4	23.4	23.3	20.9	20.0	19.8	19.0	19.2	18.8	18.4	18.9	20.9
	10%	DB	25.0	26.1	25.9	23.3	22.7	22.2	21.1	20.2	20.2	20.2	21.1	23.0
		MCWB	21.7	22.9	22.7	20.3	19.7	19.3	18.1	17.3	17.6	17.5	18.1	19.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.0	24.9	25.3	23.0	21.2	21.1	20.6	20.6	20.6	20.0	20.7	22.7
		MCDB	27.4	27.6	28.0	26.5	24.0	23.7	24.3	23.8	23.6	22.9	24.4	26.3
	2%	WB	23.3	24.2	24.4	22.2	20.7	20.4	19.9	20.0	19.8	19.5	20.0	22.0
		MCDB	26.8	27.1	27.1	25.1	23.3	23.2	23.4	23.3	22.7	22.2	23.2	25.2
	5%	WB	22.7	23.7	23.5	21.3	20.3	19.9	19.3	19.4	19.0	18.7	19.3	21.1
		MCDB	26.0	26.7	26.4	23.7	22.8	22.8	22.3	22.5	21.3	21.2	21.9	23.7
	10%	WB	21.9	23.1	22.9	20.6	19.9	19.5	18.2	17.6	17.7	17.7	18.4	20.3
		MCDB	24.5	26.1	25.9	22.8	22.3	22.1	20.5	19.8	20.0	19.8	20.7	22.6
Mean Daily Temperature Range	5% DB	MDBR	4.2	4.1	4.1	4.0	3.9	3.5	3.5	3.4	3.5	3.8	4.0	4.0
		MCDBR	4.3	4.4	4.8	4.6	4.2	4.4	4.8	4.7	4.5	4.7	4.2	3.8
		MCWBR	2.0	2.2	2.4	2.3	2.1	2.1	2.4	2.3	2.3	2.3	1.9	1.9
	5% WB	MCDBR	3.8	4.1	4.4	4.3	4.1	3.9	4.5	4.1	4.5	5.0	3.8	3.6
		MCWBR	1.9	2.2	2.3	2.3	2.1	1.9	2.3	2.0	2.3	2.5	1.8	1.9
Clear-Sky Solar Irradiance	taub	0.447	0.447	0.457	0.470	0.453	0.432	0.423	0.456	0.498	0.477	0.467	0.457	
	taud	2.376	2.383	2.360	2.304	2.336	2.409	2.433	2.310	2.183	2.262	2.282	2.330	
	Ebn at Noon	896	893	870	831	815	819	836	831	822	856	871	883	
	Edh at Noon	130	129	130	131	121	110	109	129	152	144	141	135	
All-Sky Solar Radiation	RadAvg	5.98	5.79	5.62	5.65	5.05	4.30	4.38	4.70	5.14	5.60	6.00	5.95	
	RadStd	0.38	0.25	0.30	0.26	0.43	0.41	0.36	0.32	0.35	0.37	0.46	0.38	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page