

PUCALLPA, Peru

WMO: 845150

Lat: 8.378S

Lon: 74.574W

Elev: 156

StdP: 99.46

Time Zone: -5.00 (W05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	18.1	19.8	15.2	11.0	19.8	17.1	12.4	21.1	6.8	23.3	5.8	23.5	1.8	140	0.274

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	9.8	34.8	26.2	34.1	26.1	33.4	26.0	27.0	32.6	26.7	32.2	26.5	31.9	3.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.5	21.2	29.6	25.2	20.7	29.4	25.0	20.5	29.2	86.2	32.9	85.0	32.7	83.6	32.1	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.2	5.2	4.4	16.0	36.1	1.6	0.9	14.8	36.7	13.9	37.3	13.0	37.8	11.8	38.5		
(5)			14.9	28.1	1.5	0.8	13.9	28.7	13.0	29.1	12.2	29.6	11.1	30.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.0	27.2	26.9	26.9	27.1	26.7	26.2	27.1	27.6	27.6	27.5	27.3	(6)	
(7)		DBStd	1.71	1.57	1.49	1.35	1.51	1.53	1.86	2.01	1.76	1.88	1.58	1.63	1.39	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0	(9)
(10)		CDD10.0	6208	532	473	524	512	518	485	501	529	527	546	526	535	(10)
(11)		CDD18.3	3167	274	240	266	262	260	235	243	271	277	288	276	277	(11)
(12)		CDH23.3	28130	2413	1997	2141	2268	2180	1918	2120	2622	2719	2702	2597	2452	(12)
(13)	CDH26.7	10913	877	666	694	814	785	697	863	1189	1251	1131	1042	903	(13)	
(14)	Wind	WSAvg	1.4	1.6	1.5	1.3	1.3	1.2	1.1	1.4	1.4	1.5	1.6	1.7	(14)	
(15)	Precipitation	PrecAvg	1564	158	170	204	156	93	78	40	55	96	153	171	156	(15)
(16)		PrecMax	2110	353	502	497	535	259	232	156	174	353	435	401	438	(16)
(17)		PrecMin	757	21	20	33	19	10	4	0	0	17	3	10	8	(17)
(18)		PrecStd	355	89	95	106	94	58	66	30	42	64	93	96	86	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.2	33.9	33.4	33.9	33.8	33.1	34.0	35.0	35.8	35.2	34.9	34.1	(19)
MCWB			26.4	26.4	26.4	26.5	26.2	25.9	25.8	26.0	26.4	26.2	26.6	26.3	(20)	
2%		DB	33.2	32.7	32.2	32.8	32.8	32.2	32.9	34.1	34.9	34.1	33.9	33.1	(21)	
		MCWB	26.1	26.0	25.9	26.0	25.9	25.6	25.4	25.7	26.1	26.1	26.4	26.0	(22)	
5%		DB	32.1	31.8	31.3	31.9	31.9	31.4	32.0	33.2	33.9	33.1	33.0	32.1	(23)	
		MCWB	25.8	25.8	25.7	25.8	25.6	25.4	25.2	25.5	26.0	25.9	26.0	25.8	(24)	
(25)	10%	DB	31.0	30.6	30.2	31.0	30.9	30.6	31.1	32.2	32.9	32.1	32.0	31.1	(25)	
(26)		MCWB	25.6	25.5	25.5	25.5	25.5	25.1	24.9	25.2	25.7	25.6	25.8	25.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.0	26.9	27.0	27.1	26.8	26.6	26.7	26.7	27.2	27.2	27.2	27.0	(27)
MCD B			32.5	31.9	31.7	32.0	31.9	31.5	32.5	33.2	34.0	33.1	32.8	32.0	(28)	
2%		WB	26.5	26.4	26.4	26.6	26.3	26.1	26.1	26.4	26.7	26.6	26.7	26.5	(29)	
		MCD B	31.7	31.2	31.0	31.2	31.2	31.1	31.7	32.8	33.3	32.4	32.3	31.5	(30)	
5%		WB	26.1	26.0	26.0	26.1	26.0	25.7	25.6	26.0	26.3	26.2	26.3	26.1	(31)	
		MCD B	31.1	30.6	30.5	30.6	30.8	30.4	30.9	32.3	32.7	31.9	31.7	31.2	(32)	
10%		WB	25.7	25.6	25.6	25.7	25.6	25.3	25.2	25.5	25.8	25.8	26.0	25.7	(33)	
		MCD B	30.2	29.7	29.6	29.8	29.9	29.7	30.2	31.4	31.9	31.2	31.2	30.4	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.6	7.1	7.2	7.7	8.1	8.4	9.5	10.1	9.8	8.9	8.4	7.8	(35)
MCDBR			9.2	8.7	8.7	9.1	9.6	9.6	10.7	11.2	11.4	10.4	9.9	9.3	(36)	
MCWBR			3.4	3.3	3.4	3.5	3.8	4.0	4.5	4.3	4.3	3.7	3.7	3.6	(37)	
5% WB		MCDBR	8.6	8.1	8.2	8.5	8.9	9.1	10.1	10.8	10.9	9.8	9.2	8.7	(38)	
		MCWBR	3.4	3.4	3.5	3.5	3.8	4.0	4.6	4.5	4.4	3.9	3.8	3.7	(39)	
(40)	Clear-Sky Solar Irradiance	taub		0.397	0.402	0.394	0.395	0.380	0.373	0.382	0.458	0.524	0.437	0.433	0.406	(40)
taud		2.500	2.484	2.524	2.486	2.534	2.564	2.511	2.261	2.097	2.360	2.373	2.466	(41)		
Ebn at Noon		943	935	927	897	883	875	873	828	801	892	903	932	(42)		
Edh at Noon		115	116	110	109	99	94	100	135	166	130	129	118	(43)		
(44)	All-Sky Solar Radiation	RadAvg		4.61	4.21	4.23	4.44	4.30	4.34	4.66	5.10	5.05	4.94	4.82	4.62	(44)
(45)		RadStd		0.36	0.21	0.21	0.27	0.25	0.23	0.35	0.22	0.37	0.30	0.25	0.29	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page