

CUSCO, Peru

WMO: 846860

Lat: 13.536S

Lon: 71.939W

Elev: 3310

StdP: 67.39

Time Zone: -5.00 (W05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.2	1.2	-14.6	1.6	15.4	-11.3	2.1	15.3	8.1	17.2	7.3	17.2	0.2	290	0.486

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	13.1	23.1	8.6	22.2	8.5	21.8	8.5	11.7	18.8	11.2	18.3	10.9	17.9	3.4	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.1	10.9	13.2	8.8	10.6	13.0	8.2	10.2	12.5	44.1	18.9	42.7	18.4	41.5	17.9	14.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.4	6.4	5.6	DB	-2.0	25.2	1.1	1.0	-2.8	26.0	-3.4	26.6	-4.1	27.1	-4.9	27.9	(4)
(5)			WB	-5.2	13.0	1.6	0.6	-6.4	13.4	-7.3	13.8	-8.2	14.1	-9.3	14.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.0	13.8	13.7	13.7	13.3	12.1	11.0	10.7	11.8	13.1	14.0	14.6	14.0	(6)	
	DBStd	1.74	1.27	1.29	1.19	1.18	1.11	1.13	1.24	1.37	1.34	1.32	1.15	1.22	(7)	
	HDD10.0	14	0	0	0	0	1	4	7	2	0	0	0	0	(8)	
	HDD18.3	1953	140	129	142	151	193	219	237	203	158	134	113	133	(9)	
	CDD10.0	1103	118	105	116	99	66	34	28	57	92	124	137	125	(10)	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH23.3	19	1	1	1	1	0	0	0	1	2	5	6	2	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	1.6	1.6	1.6	1.5	1.4	1.4	1.3	1.4	1.7	1.9	1.9	2.0	1.8	(14)	
(15) Precipitation	PrecAvg	674	152	128	104	43	7	3	4	6	21	47	70	118	(15)	
	PrecMax	954	360	253	190	88	22	27	31	35	51	109	180	250	(16)	
	PrecMin	423	8	63	48	8	0	0	0	0	0	6	0	31	(17)	
	PrecStd	130	59	44	36	22	6	5	6	8	13	23	35	51	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.7	22.5	22.4	22.9	22.5	22.1	22.2	23.1	23.2	24.1	24.1	23.2	(19)	
		MCWB	10.9	10.8	10.8	9.3	8.1	7.2	6.8	7.2	8.0	8.6	9.1	9.3	(20)	
	2%	DB	21.0	20.9	21.0	21.2	21.3	21.0	21.1	22.0	22.1	22.6	22.9	21.8	(21)	
		MCWB	10.5	10.8	10.5	9.5	8.1	7.1	6.5	6.8	8.0	8.8	9.0	9.8	(22)	
	5%	DB	19.8	19.5	19.8	20.2	20.7	20.1	20.1	20.9	21.1	21.2	21.8	20.2	(23)	
		MCWB	10.4	10.5	10.3	9.6	8.1	7.0	6.4	6.8	7.8	8.9	9.3	9.8	(24)	
	10%	DB	18.2	18.1	18.2	19.1	19.6	19.1	19.0	19.8	19.9	20.0	20.2	19.0	(25)	
		MCWB	10.1	10.4	10.2	9.4	8.1	7.0	6.4	7.0	8.0	8.9	9.5	9.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.1	12.3	12.1	11.6	10.4	9.3	8.8	9.2	9.9	10.7	11.4	11.7	(27)	
		MCDB	19.2	19.4	19.4	19.2	19.1	19.0	18.5	19.3	19.6	19.5	19.7	19.0	(28)	
	2%	WB	11.4	11.6	11.4	10.8	9.7	8.7	8.1	8.5	9.3	10.2	10.8	11.1	(29)	
		MCDB	18.2	18.3	18.5	18.4	18.3	17.6	18.5	18.8	18.9	19.3	19.3	18.6	(30)	
	5%	WB	10.9	11.1	10.9	10.3	9.3	8.2	7.6	8.1	8.9	9.7	10.3	10.6	(31)	
		MCDB	17.5	17.6	17.8	17.7	17.9	17.6	17.1	17.9	18.2	18.1	18.7	17.7	(32)	
	10%	WB	10.5	10.6	10.5	9.9	8.8	7.7	7.1	7.6	8.4	9.3	9.9	10.2	(33)	
		MCDB	16.7	16.7	16.9	17.0	17.2	17.0	16.6	17.2	17.4	17.5	18.1	16.9	(34)	
(35) Mean Daily Temperature Range	MDBR		10.6	10.4	11.0	13.2	16.1	17.5	17.7	17.0	15.1	13.4	13.1	11.5	(35)	
	5% DB	MCDBR	12.4	12.3	12.8	14.8	17.8	18.9	19.4	18.9	16.8	15.5	15.1	13.5	(36)	
		MCWBR	4.3	4.6	4.8	5.7	7.1	7.6	7.8	7.3	6.0	5.1	4.8	4.7	(37)	
	5% WB	MCDBR	10.7	10.7	11.2	13.0	15.4	17.0	17.1	16.6	14.8	13.4	13.1	11.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.304	0.292	0.291	0.276	0.270	0.265	0.269	0.313	0.352	0.329	0.313	0.305	(40)	
	taud		2.575	2.650	2.652	2.705	2.685	2.707	2.661	2.461	2.350	2.444	2.509	2.568	(41)	
	Ebn at Noon		1039	1044	1025	1009	985	975	978	955	948	993	1023	1037	(42)	
	Edh at Noon		107	99	96	86	82	78	83	108	127	120	113	107	(43)	
(44) All-Sky Solar Radiation	RadAvg		4.74	4.59	4.64	4.78	4.90	4.79	4.88	5.17	5.14	5.22	5.47	4.92	(44)	
	RadStd		0.27	0.29	0.25	0.29	0.31	0.28	0.36	0.29	0.40	0.31	0.36	0.30	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	-0.60	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page