

LA PAZ EL ALTO, Bolivia

WMO: 852010

Lat: 16.513S

Lon: 68.192W

Elev: 13325

StdP: 8.87

Time Zone: -4.00 (W04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.9	24.9	-5.5	6.8	42.7	-0.6	8.8	45.2	25.8	51.3	21.9	50.9	4.7	20	0.667

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	22.9	64.5	42.3	62.8	42.1	61.2	41.9	48.3	56.9	47.5	55.9	46.8	55.0	10.7	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
44.9	73.5	50.0	44.5	72.1	49.6	43.2	68.7	48.5	24.5	56.9	23.9	56.1	23.3	55.6	56.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.9	16.7	14.7	DB	17.7	68.3	1.4	2.2	16.7	69.8	15.9	71.1	15.1	72.3	14.1	73.9	(4)
(5)			WB	12.9	50.8	1.6	1.7	11.8	52.0	10.9	53.0	10.0	53.9	8.8	55.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	46.0	48.5	48.5	48.1	46.7	43.8	41.7	41.2	42.9	45.3	47.7	49.2	49.3	(6)
(7)		DBStd	3.74	2.39	2.21	2.21	2.12	2.46	2.49	2.56	2.58	2.55	2.45	2.30	2.39	(7)
(8)		HDD50	1514	57	52	67	100	194	250	272	220	142	78	41	41	(8)
(9)		HDD65	6914	510	463	524	549	658	700	737	685	591	537	474	486	(9)
(10)		CDD50	73	11	10	8	1	0	0	0	0	1	6	16	20	(10)
(11)		CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	7.0	7.0	6.9	6.6	6.2	6.5	6.6	7.1	7.1	7.6	7.6	7.4	(14)	
(15)	Precipitation	PrecAvg	21.1	4.7	3.5	3.0	1.2	0.4	0.2	0.2	0.5	1.2	1.4	1.9	3.4	(15)
(16)		PrecMax	31.4	8.7	6.7	7.0	2.8	1.5	1.7	1.1	2.4	3.4	4.3	4.5	6.3	(16)
(17)		PrecMin	14.0	0.5	0.4	0.6	0.0	0.0	0.0	0.0	0.0	0.1	0.3	1.1	(17)	
(18)		PrecStd	4.6	1.8	1.5	1.6	0.7	0.4	0.4	0.2	0.6	0.8	0.9	1.1	1.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.0	63.0	64.2	62.8	62.4	60.9	61.1	62.7	64.4	64.8	66.6	66.1	(19)
(20)			MCWB	44.7	45.8	45.4	41.8	39.9	38.1	37.7	38.2	40.1	40.9	42.0	42.7	(20)
(21)		2%	DB	60.8	60.6	61.0	60.8	60.4	59.1	59.1	60.8	61.9	62.8	64.4	62.9	(21)
(22)			MCWB	45.4	46.1	45.1	42.7	39.4	37.8	37.3	38.2	39.8	41.0	41.9	43.7	(22)
(23)		5%	DB	58.6	57.6	58.8	59.0	58.8	57.4	57.3	59.1	59.9	61.0	62.4	60.7	(23)
(24)			MCWB	45.7	46.0	45.3	42.4	39.1	37.4	36.9	38.0	39.4	41.2	42.2	44.5	(24)
(25)		10%	DB	55.8	55.6	56.2	57.1	57.0	55.6	55.4	57.2	57.5	59.0	60.4	58.3	(25)
(26)			MCWB	45.5	45.8	45.0	42.4	38.8	36.7	36.3	37.3	39.3	41.5	42.6	44.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.3	49.5	48.6	47.8	45.5	43.0	42.0	43.3	45.7	46.6	47.7	48.4	(27)
(28)			MADB	57.4	58.1	57.6	56.4	55.4	54.8	54.5	55.1	56.2	57.3	58.1	57.7	(28)
(29)		2%	WB	48.0	48.2	47.6	46.5	43.8	41.1	40.3	41.8	44.0	45.3	46.5	47.3	(29)
(30)			MADB	56.0	56.3	56.4	55.2	54.0	53.3	52.9	54.2	54.7	56.0	56.8	56.2	(30)
(31)		5%	WB	47.0	47.3	46.7	45.5	42.5	39.6	39.0	40.5	42.9	44.4	45.6	46.5	(31)
(32)			MADB	54.6	54.8	55.0	54.2	52.8	52.1	51.9	53.1	53.8	54.9	55.9	55.1	(32)
(33)		10%	WB	46.2	46.4	45.9	44.5	41.0	38.5	37.7	39.3	41.8	43.5	44.7	45.7	(33)
(34)			MADB	53.5	53.4	53.7	53.1	51.7	51.0	50.9	51.9	52.5	53.7	55.0	54.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	16.3	16.4	17.9	22.1	28.0	29.6	29.6	26.3	23.7	22.9	19.2	(35)	
(36)			MCDBR	20.1	19.7	22.2	25.8	30.6	31.9	32.5	32.7	30.1	27.5	27.5	23.4	(36)
(37)			MCWBR	8.5	8.8	9.8	11.8	15.2	16.3	16.5	15.9	13.9	11.8	11.2	9.5	(37)
(38)		5% WB	MCDBR	16.7	16.9	18.1	20.2	24.9	28.1	28.4	27.7	23.9	22.4	21.2	18.4	(38)
(39)			MCWBR	8.4	8.5	9.1	10.3	13.2	15.1	15.4	14.4	11.8	10.4	9.6	8.7	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.274	0.270	0.263	0.248	0.239	0.234	0.240	0.274	0.323	0.294	0.277	0.278	(40)
(41)		taud		2.636	2.672	2.704	2.753	2.717	2.746	2.681	2.514	2.364	2.481	2.561	2.590	(41)
(42)		Ebn at Noon		340	338	334	328	322	318	318	314	309	326	337	338	(42)
(43)		Edh at Noon		32	30	29	25	24	23	25	32	40	36	34	33	(43)
(44)	All-Sky Solar Radiation	RadAvg		1757	1762	1751	1715	1666	1576	1615	1765	1853	1970	2063	1861	(44)
(45)		RadStd		101	83	101	94	82	80	79	87	142	128	126	101	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.68	N/A	-4.79	+1.37	N/A	N/A	-189	-230	+36	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page