

IQUIQUE, Chile

WMO: 854180

Lat: 20.5397S

Lon: 70.1786W

Elev: 157

StdP: 14.61

Time Zone: -4.00 (CHL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	53.8	55.2	44.5	43.5	56.8	46.0	46.2	57.9	22.3	62.2	20.3	62.1	5.6	160	0.413

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	10.4	80.2	68.2	78.6	67.3	77.1	66.6	69.8	77.3	68.6	76.3	67.6	75.4	15.2	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.5	98.3	75.0	65.4	94.4	74.2	64.4	90.9	73.4	33.9	77.0	32.8	76.7	32.1	75.6	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.2	20.2	18.4	DB	51.0	83.2	1.8	1.9	49.6	84.6	48.6	85.7	47.5	86.7	46.2	88.1	(4)
(5)			WB	46.7	71.2	2.3	3.1	45.0	73.4	43.6	75.2	42.3	76.9	40.7	79.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.3	71.5	72.1	70.2	66.7	63.8	61.5	60.1	60.1	61.2	62.9	65.4	68.6	(6)	
	DBStd	4.81	2.50	2.46	2.48	2.57	2.79	2.30	2.24	2.14	2.16	2.13	1.90	2.21	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	684	0	0	1	11	57	108	152	152	116	69	17	1	(9)	
	CDD50	5591	666	619	627	501	428	344	315	315	336	401	463	576	(10)	
	CDD65	798	201	199	162	62	20	2	1	2	2	5	30	112	(11)	
	CDH74	1479	481	585	298	45	5	0	0	3	0	0	0	62	(12)	
	CDH80	44	13	23	7	0	0	0	0	1	0	0	0	0	(13)	
(14) Wind	WSAvg	8.5	9.9	10.4	9.7	8.6	7.5	6.9	7.1	7.4	8.1	8.5	8.8	9.3	(14)	
(15) Precipitation	PrecAvg	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0	0.0	0.0	(15)	
	PrecMax	3.4	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.4	3.1	0.0	0.0	0.0	(16)	
	PrecMin	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	0.7	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.7	0.0	0.0	0.0	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.3	82.5	80.8	77.3	73.8	69.8	68.1	68.3	69.3	70.1	73.1	77.3	(19)	
		MCWB	69.5	68.4	68.1	66.1	64.1	61.1	59.9	61.7	61.8	60.5	62.4	66.6	(20)	
	2%	DB	79.2	80.5	78.7	75.3	71.7	68.0	66.3	66.2	66.6	68.3	71.5	75.6	(21)	
		MCWB	68.4	67.9	67.2	65.1	62.9	60.2	59.0	59.6	59.5	59.8	61.6	65.3	(22)	
	5%	DB	78.2	78.8	77.0	73.4	69.9	66.4	64.7	64.5	65.8	67.6	70.1	74.1	(23)	
		MCWB	67.6	67.0	66.7	63.9	61.9	58.9	57.6	57.5	58.8	59.4	61.1	64.1	(24)	
	10%	DB	76.8	77.2	75.4	71.7	68.3	64.8	63.6	63.0	64.5	66.3	69.5	73.3	(25)	
		MCWB	66.6	66.5	65.6	63.1	60.6	57.8	57.1	56.6	57.6	58.6	60.8	63.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.8	70.8	70.1	67.9	65.5	62.3	61.1	63.5	62.7	61.9	63.9	68.4	(27)	
		MCDB	79.3	78.6	77.1	74.6	72.8	67.7	66.1	68.2	67.4	67.5	70.6	75.4	(28)	
	2%	WB	70.1	69.3	68.5	66.3	63.7	60.6	59.7	59.9	60.8	60.8	62.8	67.0	(29)	
		MCDB	77.3	77.9	76.2	73.3	70.0	66.4	64.8	64.9	65.8	66.4	69.3	73.8	(30)	
	5%	WB	69.0	68.3	67.4	65.1	62.6	59.6	58.7	58.3	59.4	60.1	62.0	65.5	(31)	
		MCDB	76.2	76.5	75.3	71.9	68.2	65.2	63.8	63.3	64.5	65.8	68.5	72.5	(32)	
	10%	WB	67.7	67.3	66.5	63.8	61.3	58.8	57.6	57.3	58.3	59.4	61.1	64.5	(33)	
		MCDB	75.2	75.6	74.3	70.4	67.1	64.3	62.6	62.3	63.5	65.3	67.8	71.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.8	10.4	10.4	9.4	8.0	6.3	5.7	5.7	6.1	6.6	7.8	9.0	(35)	
		MCDBR	10.5	11.3	11.4	10.8	9.2	7.3	6.5	6.8	6.8	7.2	8.3	9.6	(36)	
	5% WB	MCWBR	5.6	5.5	5.7	5.9	5.4	4.7	4.5	4.6	4.4	4.5	4.9	5.4	(37)	
		MCWBR	9.7	10.6	11.0	10.4	9.3	7.4	6.1	6.6	6.7	6.9	8.2	9.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.461	0.453	0.421	0.404	0.373	0.362	0.368	0.367	0.379	0.374	0.377	0.419	(40)	
		taud	2.202	2.244	2.323	2.317	2.364	2.386	2.370	2.356	2.316	2.332	2.345	2.262	(41)	
	Ebn at Noon		282	281	282	273	270	267	269	281	290	300	305	294	(42)	
		Edh at Noon	49	47	42	39	34	32	34	36	41	42	43	47	(43)	
(44) All-Sky Solar Radiation	RadAvg		2556	2399	2200	1788	1404	1171	1203	1433	1797	2186	2486	2597	(44)	
	RadStd		99	126	88	118	72	53	69	71	87	87	105	63	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page