

ANTOFAGASTA, Chile

WMO: 854420

Lat: 23.4503S

Lon: 70.4411W

Elev: 113

StdP: 99.97

Time Zone: -4.00 (CHL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	10.9	5.9	5.8	12.3	6.9	6.2	12.8	9.6	14.6	8.7	14.8	2.5	70	0.441

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.5	24.2	19.0	23.8	18.6	23.0	18.1	20.2	23.2	19.4	22.5	18.7	21.9	5.6	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.0	14.0	22.4	18.1	13.2	21.4	17.2	12.5	20.6	58.7	23.2	55.8	22.6	53.5	22.1	22.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.5	8.0	7.3	8.1	27.0	1.0	1.5	7.4	28.1	6.8	29.0	6.2	29.8	5.5	30.9
			6.1	20.4	1.5	0.9	5.0	21.1	4.1	21.6	3.3	22.2	2.2	22.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.9	20.4	20.3	19.3	17.3	15.8	14.5	14.0	14.4	14.9	15.9	17.3	18.8	(6)
(7)		DBStd	2.54	1.25	1.10	1.18	1.33	1.49	1.38	1.31	1.22	1.16	1.00	0.96	1.18	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	711	0	0	3	37	81	114	136	123	102	74	33	7	(9)
(10)		CDD10.0	2516	322	289	287	218	179	136	123	136	148	184	219	273	(10)
(11)		CDD18.3	184	63	57	32	5	2	0	0	0	0	0	2	23	(11)
(12)		CDH23.3	112	54	37	13	1	2	0	0	1	0	0	0	6	(12)
(13)		CDH26.7	3	2	1	1	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	3.6	3.8	3.6	3.4	3.2	3.0	3.2	3.4	3.8	4.1	4.2	4.1	4.0	(14)
(15)	Precipitation	PrecAvg	23	0	0	0	0	0	2	3	9	6	1	1	0	(15)
(16)		PrecMax	142	4	0	5	0	0	12	25	91	50	15	12	5	(16)
(17)		PrecMin	0	0	0	0	0	0	0	0	0	0	0	0	0	(17)
(18)		PrecStd	34	1	0	1	0	0	4	7	21	12	3	3	1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.2	25.5	24.7	22.8	22.0	20.1	19.2	19.8	19.7	20.5	21.7	24.1	(19)
(20)			MCWB	20.3	19.8	18.8	17.0	16.2	15.4	14.4	14.9	15.0	15.1	16.4	18.7	(20)
(21)		2%	DB	24.8	24.2	23.2	21.4	20.0	18.6	17.8	17.9	18.1	19.1	20.8	22.9	(21)
(22)			MCWB	19.7	18.9	18.1	16.6	15.7	14.4	13.7	13.9	14.0	14.5	16.0	17.5	(22)
(23)		5%	DB	23.8	23.8	22.8	20.8	19.0	17.4	16.8	16.8	17.2	18.2	20.0	22.0	(23)
(24)			MCWB	18.8	18.6	17.9	16.4	14.8	13.8	13.2	13.1	13.4	14.0	15.4	17.1	(24)
(25)		10%	DB	23.0	23.0	22.0	20.0	18.1	16.9	16.0	16.1	16.8	17.9	19.3	21.2	(25)
(26)			MCWB	18.2	18.1	17.5	15.9	14.3	13.5	12.7	12.8	13.2	13.8	15.0	16.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.6	20.9	20.0	18.1	17.4	16.4	15.4	16.2	16.1	15.8	17.1	19.5	(27)
(28)			MCDWB	24.7	23.8	23.0	21.0	20.5	18.9	17.9	18.3	18.2	18.8	20.3	22.9	(28)
(29)		2%	WB	20.7	20.0	19.2	17.4	16.2	15.2	14.3	14.6	14.9	15.1	16.4	18.3	(29)
(30)			MCDWB	23.7	23.0	22.1	20.2	19.0	17.6	16.8	17.1	17.1	18.1	19.5	21.7	(30)
(31)		5%	WB	19.6	19.3	18.5	16.9	15.5	14.2	13.4	13.4	14.0	14.6	15.9	17.6	(31)
(32)			MCDWB	22.6	22.4	21.5	19.6	18.1	16.7	15.9	16.1	16.7	17.5	19.0	21.1	(32)
(33)		10%	WB	18.7	18.7	18.0	16.3	14.9	13.7	12.9	12.9	13.5	14.2	15.5	17.1	(33)
(34)			MCDWB	22.0	21.9	21.1	19.1	17.4	16.2	15.4	15.4	16.1	17.1	18.6	20.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.5	5.7	5.8	5.5	5.0	4.6	4.3	4.1	4.0	4.1	4.5	5.1	(35)
(36)			MCDBR	5.9	6.0	6.2	6.1	5.6	5.3	5.2	4.8	4.4	4.5	4.9	5.5	(36)
(37)			MCWBR	3.0	2.9	2.9	3.1	3.0	2.9	2.8	2.5	2.4	2.3	2.4	2.7	(37)
(38)		5% WB	MCDWB	5.5	5.5	5.8	5.6	5.6	5.2	5.0	4.6	4.3	4.5	4.7	5.3	(38)
(39)			MCWBR	3.1	2.8	3.0	3.1	3.2	3.3	3.0	2.6	2.5	2.4	2.5	2.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.399	0.390	0.368	0.360	0.345	0.334	0.337	0.336	0.346	0.341	0.341	0.367	(40)	
(41)		taud	2.339	2.376	2.430	2.420	2.436	2.455	2.446	2.445	2.396	2.418	2.443	2.379	(41)	
(42)		Ebn at Noon	945	940	934	897	869	859	869	909	940	977	995	978	(42)	
(43)		Edh at Noon	136	128	116	108	97	91	95	103	118	122	122	131	(43)	
(44)	All-Sky Solar Radiation	RadAvg	8.54	7.99	6.97	5.58	4.24	3.57	3.79	4.68	6.06	7.27	8.24	8.78	(44)	
(45)		RadStd	0.13	0.24	0.23	0.23	0.22	0.14	0.20	0.15	0.21	0.26	0.27	0.23	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page