

ISLA DE PASCUA, Chile

WMO: 854690

Lat: 27.1606S

Lon: 109.4272W

Elev: 564

StdP: 14.40

Time Zone: -6.00 (PCE)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	55.2	57.1	44.2	43.8	61.4	46.0	46.8	62.0	27.5	65.1	24.9	66.4	4.1	130	0.352

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	11.0	82.0	72.2	80.8	71.5	80.3	71.2	73.8	78.9	73.0	78.3	72.4	77.8	12.2	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.0	120.6	76.6	71.5	118.6	76.5	70.2	113.3	76.1	37.7	79.2	37.0	78.9	36.4	77.6	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.9	20.7	18.7	DB	50.6	83.5	2.2	0.9	49.0	84.1	47.8	84.6	46.6	85.1	45.0	85.7	(4)
(5)			WB	48.0	75.2	1.4	1.3	47.0	76.1	46.2	76.8	45.3	77.6	44.3	78.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	69.4	73.7	75.1	74.5	72.3	68.8	66.5	65.2	65.1	65.2	66.5	68.8	71.3	(6)	
	DBStd	4.34	1.61	1.82	1.79	2.62	2.56	2.70	2.53	2.81	2.52	2.43	2.28	2.11	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	123	0	0	0	0	3	15	29	34	28	13	1	0	(9)	
	CDD50	7066	733	703	760	669	582	494	470	468	455	510	563	659	(10)	
	CDD65	1716	268	283	295	219	120	59	34	37	33	59	115	194	(11)	
	CDH74	5119	1057	1511	1329	626	71	11	0	0	1	11	72	430	(12)	
	CDH80	205	22	102	70	9	0	0	0	0	0	0	0	2	(13)	
(14) Wind	WSAvg	9.2	8.8	8.6	8.7	8.5	8.6	10.0	9.7	9.0	9.8	9.3	10.0	9.3	(14)	
(15) Precipitation	PrecAvg	51.1	3.5	2.8	4.7	4.8	4.5	5.8	5.2	4.5	5.7	4.0	2.5	2.5	(15)	
	PrecMax	79.6	12.6	10.9	17.6	14.2	13.5	12.2	11.2	11.9	16.2	14.0	10.5	8.0	(16)	
	PrecMin	31.4	0.5	0.4	1.3	1.2	0.6	1.5	1.7	0.4	0.3	0.6	0.0	0.0	(17)	
	PrecStd	11.4	3.0	2.2	3.1	3.4	3.1	2.5	2.4	2.7	3.6	3.1	2.4	2.2	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.0	82.8	82.8	80.9	77.1	75.4	73.2	73.4	73.8	75.4	77.2	79.6	(19)	
		MCWB	71.4	72.7	72.5	72.0	69.4	67.9	65.3	65.7	66.8	67.5	67.8	69.0	(20)	
	2%	DB	80.6	82.3	81.7	79.4	75.5	73.6	71.8	71.9	72.2	73.7	75.6	78.7	(21)	
		MCWB	71.4	72.6	71.9	71.0	68.1	66.9	65.1	65.3	65.2	65.9	67.5	69.4	(22)	
	5%	DB	79.2	81.0	80.6	78.7	74.9	72.1	71.2	71.4	71.5	73.0	74.9	77.3	(23)	
		MCWB	70.4	71.7	71.3	70.5	67.8	66.1	64.9	65.1	64.4	65.4	67.2	68.7	(24)	
	10%	DB	78.8	80.5	79.2	77.3	73.6	71.4	69.8	70.0	70.0	71.6	73.5	76.7	(25)	
		MCWB	70.0	71.4	70.6	69.6	67.1	65.6	64.2	64.2	63.5	64.6	66.1	68.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.3	74.6	74.6	74.7	73.1	69.3	68.1	67.9	69.0	69.4	70.6	72.1	(27)	
		MCDB	78.7	80.6	80.3	78.0	74.6	72.8	70.8	70.8	72.2	73.4	74.4	76.6	(28)	
	2%	WB	73.1	73.8	73.4	73.3	71.0	68.3	67.1	67.1	67.3	68.1	69.5	71.1	(29)	
		MCDB	77.7	79.9	78.9	77.3	73.5	71.9	70.1	70.3	70.8	72.1	73.4	76.0	(30)	
	5%	WB	72.3	73.0	72.5	72.0	69.7	67.4	66.0	66.2	66.0	67.1	68.6	70.0	(31)	
		MCDB	77.4	79.2	78.2	76.9	72.8	71.1	69.4	69.7	69.7	71.0	72.6	75.2	(32)	
	10%	WB	71.5	72.3	71.8	71.1	68.5	66.5	65.2	65.3	64.9	65.7	67.5	69.2	(33)	
		MCDB	77.0	78.6	77.7	76.1	72.5	70.3	68.8	69.0	69.0	69.8	71.7	74.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.6	11.0	10.7	10.1	9.8	8.4	9.0	9.3	9.5	9.7	9.3	10.5	(35)	
		MCDBR	11.5	11.5	12.0	10.5	10.2	9.7	9.6	10.0	10.5	11.1	10.0	11.4	(36)	
	5% WB	MCWBR	5.8	5.5	5.8	5.3	6.6	6.1	6.2	6.3	6.3	6.1	5.2	5.9	(37)	
		MCWBR	10.3	10.8	10.9	9.4	8.7	8.5	8.2	7.9	8.1	8.7	8.4	9.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.337	0.338	0.336	0.337	0.333	0.329	0.329	0.332	0.334	0.332	0.337	0.334	(40)	
		taud	2.691	2.699	2.707	2.696	2.688	2.673	2.668	2.653	2.634	2.628	2.659	2.679	(41)	
	Ebn at Noon		319	314	305	290	278	272	276	288	301	312	317	320	(42)	
		Edh at Noon	30	29	28	25	23	23	23	26	29	31	31	31	(43)	
(44) All-Sky Solar Radiation	RadAvg		2410	2274	1921	1486	1107	952	1035	1294	1612	1943	2148	2390	(44)	
	RadStd		139	108	90	69	86	46	47	72	92	111	187	161	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page