

ISLA DE PASCUA, Chile

WMO: 854690

Lat: 27.1606S

Lon: 109.4272W

Elev: 172

StdP: 99.28

Time Zone: -6.00 (PCE)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.9	13.9	6.8	6.3	16.3	7.8	6.7	16.7	12.3	18.4	11.1	19.1	1.8	130	0.352

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.1	27.8	22.3	27.1	21.9	26.8	21.8	23.2	26.0	22.8	25.7	22.5	25.5	5.5	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.2	17.2	24.8	21.9	16.9	24.7	21.2	16.2	24.5	69.7	26.2	68.3	26.1	66.9	25.4	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.3	9.2	8.4	DB	10.3	28.6	1.2	0.5	9.5	29.0	8.8	29.2	8.1	29.5	7.2	29.8	(4)
(5)			WB	8.9	24.0	0.8	0.7	8.3	24.5	7.9	24.9	7.4	25.3	6.8	25.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.8	23.1	24.0	23.6	22.4	20.4	19.2	18.4	18.4	18.4	19.1	20.4	21.8	(6)	
	DBStd	2.41	0.89	1.01	0.99	1.46	1.42	1.50	1.41	1.56	1.40	1.35	1.27	1.17	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	68	0	0	0	0	2	8	16	19	16	7	1	0	(9)	
	CDD10.0	3926	407	391	422	372	323	274	261	260	253	283	313	366	(10)	
	CDD18.3	953	149	157	164	122	67	33	19	21	18	33	64	108	(11)	
	CDH23.3	2844	587	839	738	348	39	6	0	0	1	6	40	239	(12)	
(13)	CDH26.7	114	12	57	39	5	0	0	0	0	0	0	0	1	(13)	
(14)	Wind	WSAvg	4.1	3.9	3.9	3.9	3.8	3.8	4.5	4.3	4.0	4.4	4.2	4.5	4.2	(14)
(15) Precipitation	PrecAvg	1298	88	71	119	122	115	148	131	114	146	102	63	64	(15)	
	PrecMax	2021	321	276	448	361	344	311	285	302	412	355	267	203	(16)	
	PrecMin	797	13	10	34	31	15	37	42	9	8	14	0	0	(17)	
	PrecStd	290	75	56	79	87	80	63	61	68	91	79	61	57	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.2	28.2	28.2	27.2	25.1	24.1	22.9	23.0	23.2	24.1	25.1	26.4	(19)	
		MCWB	21.9	22.6	22.5	22.2	20.8	19.9	18.5	18.7	19.4	19.7	19.9	20.6	(20)	
	2%	DB	27.0	28.0	27.6	26.3	24.2	23.1	22.1	22.2	22.3	23.2	24.2	25.9	(21)	
		MCWB	21.9	22.5	22.1	21.7	20.1	19.4	18.4	18.5	18.4	18.8	19.7	20.8	(22)	
	5%	DB	26.2	27.2	27.0	26.0	23.8	22.3	21.8	21.9	21.9	22.8	23.8	25.2	(23)	
		MCWB	21.3	22.1	21.8	21.4	19.9	18.9	18.3	18.4	18.0	18.6	19.5	20.4	(24)	
	10%	DB	26.0	26.9	26.2	25.2	23.1	21.9	21.0	21.1	21.1	22.0	23.1	24.8	(25)	
		MCWB	21.1	21.9	21.4	20.9	19.5	18.7	17.9	17.9	17.5	18.1	18.9	20.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.5	23.7	23.7	23.7	22.8	20.7	20.0	19.9	20.5	20.8	21.5	22.3	(27)	
		MCDB	26.0	27.0	26.8	25.6	23.7	22.7	21.6	21.6	22.3	23.0	23.5	24.8	(28)	
	2%	WB	22.8	23.2	23.0	22.9	21.7	20.2	19.5	19.5	19.6	20.1	20.8	21.7	(29)	
		MCDB	25.4	26.6	26.0	25.1	23.0	22.2	21.2	21.3	21.5	22.3	23.0	24.5	(30)	
	5%	WB	22.4	22.8	22.5	22.2	20.9	19.7	18.9	19.0	18.9	19.5	20.4	21.1	(31)	
		MCDB	25.2	26.2	25.7	24.9	22.7	21.7	20.8	20.9	21.0	21.7	22.6	24.0	(32)	
	10%	WB	22.0	22.4	22.1	21.7	20.3	19.1	18.4	18.5	18.3	18.7	19.7	20.7	(33)	
		MCDB	25.0	25.9	25.4	24.5	22.5	21.3	20.4	20.5	20.6	21.0	22.1	23.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.9	6.1	6.0	5.6	5.4	4.7	5.0	5.1	5.3	5.4	5.2	5.8	(35)	
		MCDBR	6.4	6.4	6.7	5.8	5.7	5.4	5.3	5.5	5.8	6.2	5.6	6.3	(36)	
	5% WB	MCWBR	3.2	3.0	3.2	2.9	3.6	3.4	3.4	3.5	3.5	3.4	2.9	3.3	(37)	
		MCWBR	5.7	6.0	6.0	5.2	4.9	4.7	4.5	4.4	4.5	4.8	4.7	5.5	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.337	0.338	0.336	0.337	0.333	0.329	0.329	0.332	0.334	0.332	0.337	0.334	(40)	
		taud	2.691	2.699	2.707	2.696	2.688	2.673	2.668	2.653	2.634	2.628	2.659	2.679	(41)	
	Ebn at Noon	Ebn at Noon	1005	989	961	915	875	856	870	907	948	983	999	1010	(42)	
		Edh at Noon	95	92	87	80	74	72	74	82	92	98	98	97	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	7.60	7.17	6.06	4.68	3.49	3.00	3.26	4.08	5.08	6.12	6.77	7.53	(44)	
	RadStd	RadStd	0.44	0.34	0.28	0.22	0.27	0.14	0.15	0.23	0.29	0.35	0.59	0.51	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page