

CURICO, Chile

WMO: 856290

Lat: 34.9664S

Lon: 71.2167W

Elev: 75

StdP: 14.66

Time Zone: -4.00 (CHL)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	30.8	33.0	29.8	23.9	33.6	31.7	26.1	35.8	22.6	50.8	18.3	51.9	2.4	60	0.451

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.7	89.4	65.9	87.3	65.7	85.1	65.1	68.5	84.8	67.3	83.7	66.2	82.4	8.6	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.7	82.4	76.9	60.4	78.5	75.4	59.1	75.0	73.2	32.7	85.1	31.7	84.4	30.8	82.5	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.4	13.3	11.8	DB	27.1	93.3	2.0	2.1	25.6	94.8	24.5	96.0	23.4	97.1	21.9	98.6	(4)
(5)			WB	27.0	73.0	2.0	4.2	25.5	76.0	24.4	78.4	23.3	80.8	21.9	83.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	58.0	70.2	69.9	65.0	56.9	50.9	47.4	45.9	48.8	52.5	57.6	63.1	67.9	(6)	
	DBStd	9.62	3.37	3.64	4.02	4.21	4.94	5.15	4.72	4.68	3.97	4.36	4.40	4.11	(7)	
	HDD50	406	0	0	0	3	51	110	143	77	19	3	0	0	(8)	
	HDD65	3070	4	7	50	243	436	527	592	501	374	232	85	19	(9)	
	CDD50	3308	627	556	464	211	79	32	15	41	95	238	394	556	(10)	
	CDD65	502	166	143	49	1	0	0	0	0	3	29	111		(11)	
	CDH74	6608	2040	1711	731	67	1	0	0	0	6	75	519	1458	(12)	
	CDH80	2121	742	638	162	8	0	0	0	0	8	107	456		(13)	
(14) Wind	WSAvg	5.3	6.1	5.5	5.0	4.3	4.3	4.6	4.7	5.0	5.3	5.7	6.2	6.4	(14)	
(15) Precipitation	PrecAvg	26.9	0.1	0.2	0.5	1.7	4.5	6.5	5.1	4.2	2.1	1.1	0.5	0.4	(15)	
	PrecMax	46.1	1.2	1.7	4.0	7.4	15.1	23.4	13.1	12.9	8.0	4.4	1.6	4.8	(16)	
	PrecMin	9.2	0.0	0.0	0.0	0.3	0.6	0.9	1.2	0.7	0.2	0.1	0.1	0.0	(17)	
	PrecStd	8.8	0.2	0.4	0.8	1.6	3.5	4.9	2.6	2.8	2.0	1.1	0.4	0.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.8	93.0	87.8	80.3	71.2	64.0	62.3	69.9	74.3	80.6	86.6	91.1	(19)	
		MCWB	65.9	66.9	65.4	62.4	59.0	56.2	54.6	58.6	59.2	63.7	65.0	65.7	(20)	
	2%	DB	89.2	89.3	84.1	75.5	66.2	60.6	59.1	64.2	69.3	75.6	82.8	87.7	(21)	
		MCWB	66.2	66.2	64.1	60.6	57.1	54.5	52.5	55.0	57.7	60.7	63.6	65.1	(22)	
	5%	DB	86.9	86.6	81.4	71.8	63.0	58.0	56.5	60.8	65.6	72.3	79.9	85.1	(23)	
		MCWB	65.8	65.8	63.3	59.0	56.1	53.5	51.4	53.5	55.5	58.9	62.4	64.7	(24)	
	10%	DB	84.4	84.2	78.6	68.0	60.2	55.6	54.0	57.6	62.3	69.4	76.6	82.3	(25)	
		MCWB	65.1	65.5	62.3	57.4	54.6	52.1	50.2	51.7	53.8	57.5	60.8	63.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.6	70.2	67.9	63.7	60.9	58.1	55.7	59.3	61.0	64.7	67.0	69.0	(27)	
		MCDB	85.1	86.0	82.4	75.6	65.3	61.0	59.6	68.0	70.6	77.8	83.2	84.5	(28)	
	2%	WB	68.5	68.4	66.0	61.6	58.5	55.6	53.7	56.2	58.4	61.7	64.8	67.2	(29)	
		MCDB	84.6	85.6	80.9	72.5	64.1	59.0	57.5	62.6	67.6	73.4	80.9	83.6	(30)	
	5%	WB	67.2	67.1	64.4	60.0	56.8	54.1	52.0	54.2	56.3	59.8	63.0	65.8	(31)	
		MCDB	83.5	84.2	78.7	69.2	62.1	57.1	55.4	59.4	63.6	70.4	78.0	82.3	(32)	
	10%	WB	65.9	65.9	62.9	58.3	55.1	52.5	50.6	52.5	54.6	58.1	61.3	64.3	(33)	
		MCDB	82.1	82.4	76.5	66.0	59.2	55.2	53.6	56.9	60.7	67.8	75.0	80.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	29.7	30.0	27.4	22.6	17.2	14.0	14.6	17.6	19.6	22.0	25.9	28.3	(35)	
		MCDBR	32.6	33.1	32.0	29.9	22.2	17.0	18.0	22.5	26.2	27.8	31.3	32.3	(36)	
		MCWBR	13.6	14.4	14.6	16.3	13.9	11.3	12.0	14.0	14.9	14.4	14.5	13.6	(37)	
	5% WB	MCDBR	30.0	31.1	29.2	26.3	19.1	14.1	15.4	20.6	23.6	25.5	29.7	30.6	(38)	
		MCWBR	14.1	14.8	14.7	15.2	12.6	9.9	10.9	13.2	14.1	14.0	14.5	14.2	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.349	0.346	0.338	0.343	0.353	0.339	0.326	0.343	0.359	0.345	0.330	0.339	(40)	
	taud		2.428	2.449	2.463	2.433	2.392	2.457	2.466	2.410	2.345	2.402	2.460	2.452	(41)	
	Ebn at Noon		313	307	297	276	252	249	260	272	285	304	317	318	(42)	
	Edh at Noon		39	36	33	30	28	25	26	31	37	38	37	38	(43)	
(44) All-Sky Solar Radiation	RadAvg		2732	2426	1938	1308	788	617	696	932	1375	1823	2386	2689	(44)	
	RadStd		127	89	102	120	85	89	82	111	132	134	137	121	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		+0.70	+0.92	N/A	+1.12	N/A	N/A	N/A	-151	+337	+189

Nomenclature: See separate page