

TEMUCO, Chile

WMO: 857430

Lat: 38.768S

Lon: 72.632W

Elev: 302

StdP: 14.54

Time Zone: -4.00 (CHL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.6	30.5	26.1	20.3	34.3	28.5	22.7	33.5	20.2	50.7	17.5	50.0	1.8	90	0.511

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	27.6	83.5	65.2	79.4	63.6	76.4	62.3	66.4	80.6	64.8	77.4	63.2	74.6	9.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
61.0	81.0	71.0	59.4	76.4	69.1	58.3	73.5	67.6	31.2	80.9	29.9	77.6	28.7	74.3	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.3	14.1	12.4	DB	24.4	94.0	2.1	4.1	22.9	97.0	21.6	99.4	20.5	101.7	18.9	104.7	(4)
(5)			WB	24.2	70.1	2.1	2.0	22.7	71.6	21.5	72.7	20.3	73.9	18.8	75.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.4	61.9	62.5	58.7	53.2	49.7	46.9	45.1	46.9	49.2	52.5	55.3	59.1
	DBStd	7.36	4.43	4.88	4.44	4.90	4.95	5.14	4.74	4.50	4.17	3.87	3.99	4.44
	HDD50	576	0	0	1	23	67	118	162	118	63	18	5	1
	HDD65	4303	115	97	200	355	475	542	616	561	473	389	292	188
	CDD50	1804	370	350	272	118	57	25	11	22	40	94	163	282
	CDD65	58	20	27	6	0	0	0	0	0	0	0	0	5
	CDH74	1300	405	514	165	20	0	0	0	0	3	10	21	162
	CDH80	346	103	173	33	2	0	0	0	0	1	3	3	31
Wind	WSAvg	4.9	5.6	5.1	4.3	3.9	4.2	5.3	5.1	5.3	4.6	4.9	5.4	5.5
Precipitation	PrecAvg	55.8	1.3	1.5	2.3	4.0	8.3	9.8	8.1	7.1	4.6	3.6	2.9	2.2
	PrecMax	69.3	3.8	5.6	5.9	8.2	17.1	20.4	12.3	13.7	7.7	11.5	6.8	5.8
	PrecMin	34.3	0.2	0.0	0.7	1.1	2.7	2.5	2.3	3.6	2.0	0.6	1.2	0.0
	PrecStd	9.5	1.0	1.2	1.1	1.9	3.7	3.7	2.6	2.2	1.7	2.3	1.4	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.0	93.7	84.3	76.9	67.3	60.8	61.1	64.3	71.9	74.4	76.8	83.6
		MCWB	67.5	65.7	65.6	61.0	57.6	55.3	53.8	53.3	55.6	59.7	62.0	65.2
	2%	DB	82.1	84.9	78.4	71.2	63.0	58.2	56.9	60.0	64.9	68.2	71.6	78.4
		MCWB	65.1	65.7	62.6	59.4	56.8	53.8	52.5	52.2	54.1	57.9	60.8	63.5
	5%	DB	78.3	80.3	74.5	66.8	60.5	56.6	55.1	57.3	61.5	64.8	68.2	74.2
		MCWB	63.5	64.0	61.2	57.7	55.5	52.6	51.1	51.2	53.1	55.7	58.6	62.0
	10%	DB	74.9	75.6	70.7	63.3	58.0	54.8	53.4	55.2	58.8	61.9	65.6	70.9
		MCWB	62.1	61.9	59.4	56.5	53.8	51.6	49.8	50.2	51.6	54.2	57.0	60.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.9	68.7	66.9	63.2	60.1	56.7	55.7	56.3	58.3	61.8	64.3	67.2
		MCDB	84.5	87.7	80.2	71.9	64.4	59.2	58.3	61.2	65.5	71.4	73.5	80.2
	2%	WB	66.1	66.4	64.1	60.7	57.8	54.6	53.3	53.9	55.8	58.6	61.2	64.6
		MCDB	79.9	81.6	75.5	68.2	61.6	57.2	56.0	58.1	62.7	67.2	69.7	76.2
	5%	WB	64.4	64.5	62.0	58.9	56.0	53.1	51.7	52.3	53.9	56.5	59.4	62.6
		MCDB	76.8	78.1	71.9	65.3	59.2	55.8	54.5	56.0	60.0	63.5	67.0	73.0
	10%	WB	62.5	62.6	60.2	57.1	54.4	51.9	50.2	50.9	52.2	54.7	57.5	60.6
		MCDB	73.6	74.4	68.6	62.4	57.5	54.5	52.7	54.3	57.7	60.8	64.3	69.5
Mean Daily Temperature Range	5% DB	MDBR	26.6	27.6	25.4	21.0	15.4	12.6	13.8	15.8	19.0	19.5	20.7	23.5
		MCDBR	33.2	35.7	32.2	27.3	18.4	13.2	15.7	19.6	25.1	25.4	26.1	29.7
		MCWBR	17.2	17.6	17.5	16.4	12.6	9.3	11.2	12.7	15.5	15.7	16.1	16.6
	5% WB	MCDBR	29.9	32.1	28.5	23.6	15.0	11.1	12.4	15.1	21.9	23.2	24.0	27.3
		MCWBR	16.7	16.4	16.3	14.8	10.7	8.4	9.4	10.5	14.1	14.8	15.5	16.1
Clear-Sky Solar Irradiance	taub	0.325	0.341	0.333	0.334	0.335	0.318	0.312	0.322	0.332	0.328	0.325	0.330	
	taud	2.530	2.475	2.493	2.472	2.467	2.536	2.548	2.506	2.447	2.478	2.495	2.497	
	Ebn at Noon	319	306	295	273	251	248	259	274	291	307	317	319	
	Edh at Noon	35	35	31	28	24	21	22	27	32	35	36	36	
All-Sky Solar Radiation	RadAvg	2471	2144	1608	1026	628	456	550	770	1230	1636	2071	2376	
	RadStd	122	108	105	69	69	65	63	84	107	145	149	197	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	+1.15	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page