

FARO EVANGELISTA, Chile

WMO: 859300

Lat: 52.387S

Lon: 75.097W

Elev: 171

StdP: 14.61

Time Zone: -3.00 (W03)

Period: 86-09

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.6	35.0	27.5	21.6	35.4	29.2	23.4	36.1	68.9	45.0	58.9	44.9	22.6	180	1.163

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.5	55.3	53.2	54.1	52.3	53.2	51.5	53.9	54.8	52.9	53.8	51.9	52.8	26.1	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
53.4	61.1	54.4	52.2	58.5	53.3	51.2	56.3	52.3	22.7	54.9	22.1	53.9	21.5	52.9	59.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.0	52.5	47.7		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
				30.7	55.5	1.6	2.1	29.5	57.1	28.6	58.3	27.7	59.5	26.6	61.1
			DB												
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.1	48.1	49.3	48.4	46.7	44.9	42.5	41.3	41.5	42.0	43.8	45.4	47.4
	DBStd	3.92	2.09	2.72	2.83	2.89	3.24	3.46	3.28	2.78	2.79	2.54	2.45	2.29
	HDD50	1854	65	40	66	103	162	226	271	263	239	193	139	87
	HDD65	7272	525	440	515	548	624	676	736	728	689	658	587	546
	CDD50	57	5	21	16	5	3	0	0	0	0	0	2	5
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	24.0	26.8	23.1	25.1	25.3	22.2	22.3	24.4	23.1	22.2	23.8	24.5	25.0
	PrecAvg	164.0	15.2	11.9	16.1	13.0	12.1	12.4	12.0	11.3	9.8	12.0	12.8	13.0
(15) Precipitation	PrecMax	220.7	32.0	18.9	27.6	23.9	25.1	38.0	31.4	26.9	19.4	30.3	27.3	23.2
	PrecMin	123.9	5.0	3.9	7.3	2.6	1.7	2.2	5.0	4.6	1.4	2.8	2.4	3.3
	PrecStd	27.4	7.1	4.1	4.8	5.2	6.5	7.8	6.4	5.2	4.0	5.7	6.0	5.8
	PrecStd	27.4	7.1	4.1	4.8	5.2	6.5	7.8	6.4	5.2	4.0	5.7	6.0	5.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	54.9	58.1	56.1	54.5	54.2	51.2	48.6	49.3	49.4	51.1	54.7	55.4	
	0.4% MCWB	52.7	55.4	53.8	52.6	51.2	49.6	47.0	47.5	47.2	48.1	51.9	52.2	
	2% DB	52.9	55.7	54.6	52.8	52.5	50.0	47.8	47.7	48.0	49.1	51.6	53.2	
	2% MCWB	51.2	54.0	52.7	51.0	50.7	48.7	46.3	46.4	46.2	47.2	49.6	51.0	
	5% DB	51.9	54.4	53.6	51.8	50.8	48.5	46.8	46.6	47.0	48.3	50.2	51.7	
	5% MCWB	50.5	53.0	52.0	50.3	49.2	46.9	45.4	45.3	45.4	46.8	48.6	49.7	
	10% DB	51.1	53.4	52.5	50.9	49.6	47.2	45.8	45.4	46.1	47.5	49.0	50.6	
	10% MCWB	49.8	52.0	50.9	49.5	48.1	45.6	44.5	44.1	44.6	46.1	47.5	49.0	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	53.5	56.2	54.4	53.1	52.1	50.3	47.9	48.3	48.5	48.8	52.1	53.0	
	0.4% MCDB	54.4	57.1	55.1	54.1	53.1	50.8	48.4	48.9	48.9	49.8	53.8	54.7	
	2% WB	51.8	54.6	53.3	51.6	50.9	48.9	46.7	46.8	46.7	47.9	50.1	51.3	
	2% MCDB	52.2	55.5	54.1	52.3	51.9	49.6	47.4	47.6	47.4	48.5	51.1	52.6	
	5% WB	51.0	53.5	52.3	50.7	49.6	47.3	45.9	45.6	45.7	47.1	48.9	50.3	
	5% MCDB	51.5	54.4	53.2	51.4	50.5	48.2	46.7	46.4	46.6	47.9	49.9	51.3	
	10% WB	50.2	52.2	51.3	49.8	48.3	45.9	44.7	44.4	44.9	46.3	47.8	49.4	
	10% MCDB	50.9	53.1	52.3	50.7	49.3	46.9	45.6	45.2	45.9	47.3	48.8	50.4	
(35) Mean Daily Temperature Range	MDBR	3.9	4.5	4.2	4.0	4.1	4.1	3.9	3.8	4.1	4.4	4.5	4.1	
	5% DB MCDBR	4.9	6.6	5.4	4.9	5.7	5.0	5.3	4.4	4.8	5.3	6.0	5.7	
	5% DB MCWBR	4.8	6.3	4.9	5.0	5.3	5.1	5.4	4.5	4.6	4.9	5.5	4.9	
	5% WB MCDBR	4.3	6.3	5.1	4.7	5.6	4.8	5.2	4.2	4.5	4.8	5.8	5.1	
	5% WB MCWBR	4.9	6.2	5.2	5.2	5.6	5.2	5.5	4.5	4.7	4.9	5.6	4.8	
(40) Clear-Sky Solar Irradiance	taub	0.361	0.344	0.335	0.345	0.324	0.319	0.327	0.341	0.336	0.343	0.342	0.353	
	taud	2.450	2.517	2.533	2.377	2.311	2.228	2.265	2.328	2.457	2.459	2.489	2.467	
	Ebn at Noon	298	293	276	233	197	171	190	230	270	290	303	304	
	Edh at Noon	35	30	26	24	19	17	19	25	28	32	34	35	
(44) All-Sky Solar Radiation	RadAvg	1222	1051	704	407	234	152	192	372	678	1015	1229	1342	
	RadStd	93	106	59	40	24	21	23	32	76	92	107	113	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page