

ISLA DIEGO RAMIREZ, Chile

WMO: 859720

Lat: 56.506S

Lon: 68.729W

Elev: 36

StdP: 14.68

Time Zone: -3.00 (W03)

Period: 86-09

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.8	29.7	23.9	18.1	29.3	26.6	20.5	31.9	62.0	39.4	57.5	40.5	17.4	270	1.096

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.2	53.4	50.1	51.5	49.1	50.2	48.3	50.8	52.4	49.7	51.0	48.7	49.8	14.9	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
49.9	53.3	51.1	48.8	51.1	50.1	47.9	49.4	49.3	20.8	52.4	20.3	51.2	19.7	50.1	62.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.5	47.8	45.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	41.8	45.3	45.9	45.3	43.2	40.8	39.0	38.1	38.4	39.1	40.5	42.0	44.0
	DBStd	4.38	2.76	2.94	3.34	3.44	3.73	3.85	3.92	3.47	4.01	2.94	2.95	3.14
	HDD50	3020	150	119	151	206	284	330	370	359	328	295	241	187
	HDD65	8477	611	534	611	655	749	780	835	824	778	760	690	650
	CDD50	17	4	5	5	1	0	0	0	0	0	0	0	2
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	21.0	22.2	21.4	21.6	21.5	19.3	18.8	20.3	21.5	21.4	21.4	21.5	21.5
	PrecAvg	40.6	3.4	3.1	4.3	4.2	3.5	3.0	3.0	3.2	3.1	3.3	3.5	3.1
(15) Precipitation	PrecMax	44.8	5.5	4.1	5.8	5.7	5.6	4.6	4.5	4.7	4.1	4.5	5.2	4.3
	PrecMin	34.6	2.3	1.5	3.0	2.7	1.0	1.9	2.0	1.9	1.4	2.4	2.2	1.9
	PrecStd	2.5	0.7	0.7	0.8	0.8	1.0	0.7	0.6	0.7	0.7	0.6	0.6	0.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.1	56.8	57.0	53.5	50.8	48.8	47.7	49.2	49.1	49.5	52.7	54.8
		MCWB	52.1	51.7	51.3	49.7	47.2	45.8	44.4	46.1	46.0	46.4	49.4	50.1
	2%	DB	51.3	52.1	52.3	50.3	48.5	47.0	45.8	45.7	46.7	47.5	49.3	51.1
		MCWB	49.1	49.9	50.0	48.0	46.7	45.1	43.2	43.5	44.3	45.5	47.3	48.7
	5%	DB	49.7	50.5	50.6	48.9	47.0	45.6	44.5	44.0	45.4	45.8	47.4	49.3
		MCWB	48.0	48.9	48.9	47.0	45.5	44.0	42.5	42.4	43.3	44.0	45.6	47.3
	10%	DB	48.4	49.4	49.5	47.5	45.9	44.3	43.4	42.6	44.3	44.6	45.9	48.1
		MCWB	47.1	48.0	47.9	46.0	44.5	42.9	41.7	41.1	42.5	43.1	44.3	46.3
	0.4%	WB	52.5	52.4	52.9	50.2	48.5	46.6	45.3	46.1	46.5	47.3	49.8	50.8
		MCDB	55.4	54.5	54.7	51.6	49.8	47.8	47.0	48.0	47.7	48.9	51.6	53.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	49.7	50.4	50.4	48.6	47.0	45.4	43.8	44.0	44.9	45.7	47.6	49.0
		MCDB	50.9	51.7	51.7	50.0	48.0	46.6	45.3	45.2	46.2	47.2	48.9	50.8
	5%	WB	48.4	49.3	49.4	47.3	45.9	44.3	42.8	42.8	43.7	44.5	45.9	47.6
		MCDB	49.2	50.3	50.6	48.5	46.9	45.5	44.1	43.9	45.0	45.5	46.9	49.0
	10%	WB	47.5	48.3	48.3	46.2	44.7	42.9	41.9	41.3	42.6	43.3	44.7	46.5
		MCDB	48.2	49.1	49.3	47.4	45.8	43.9	43.2	42.3	43.9	44.4	45.7	47.8
	5% DB	MDBR	5.4	5.2	5.5	5.3	5.0	4.7	5.1	5.1	5.2	4.9	5.3	5.5
		MCDBR	8.5	7.4	7.7	7.0	6.8	5.6	6.0	7.0	5.9	6.3	7.8	8.0
		MCWBR	6.8	6.1	6.2	5.8	5.6	4.8	5.3	5.8	5.1	5.2	6.5	6.2
		MCWBR	7.5	7.2	7.4	6.4	6.5	5.2	5.4	6.6	5.3	5.9	7.2	7.7
(35) Mean Daily Temperature Range	5% WB	MCWBR	6.5	6.1	6.3	5.9	5.7	5.0	5.1	6.0	4.9	5.3	6.5	6.3
(40) Clear-Sky Solar Irradiance	taub		0.346	0.336	0.327	0.344	0.308	0.297	0.322	0.336	0.338	0.340	0.332	0.338
	taud		2.486	2.520	2.528	2.290	2.233	2.116	2.145	2.263	2.390	2.443	2.502	2.497
	Ebn at Noon		300	290	271	214	171	135	156	213	259	285	303	306
	Edh at Noon		33	29	25	23	16	14	17	23	28	31	32	33
(44) All-Sky Solar Radiation	RadAvg		1504	1195	757	384	173	89	126	309	644	1052	1479	1640
	RadStd		74	92	45	22	11	9	11	15	53	71	104	100

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page