

ISLA DIEGO RAMIREZ, Chile

WMO: 859720

Lat: 56.506S

Lon: 68.729W

Elev: 11

StdP: 101.19

Time Zone: -3.00 (W03)

Period: 86-09

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) -2.3	(c) -1.3	(d) -4.5	(e) 2.6	(f) -1.5	(g) -3.0	(h) 2.9	(i) -0.1	(j) 27.7	(k) 4.1	(l) 25.7	(m) 4.7	(n) 7.8	(o) 270	(p) 1.096

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 2	(b) 2.9	(c) 11.9	(d) 10.0	(e) 10.8	(f) 9.5	(g) 10.1	(h) 9.0	(i) 10.4	(j) 11.3	(k) 9.8	(l) 10.6	(m) 9.3	(n) 9.9	(o) 6.7	(p) 320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 10.0	(b) 7.6	(c) 10.6	(d) 9.3	(e) 7.3	(f) 10.1	(g) 8.8	(h) 7.1	(i) 9.6	(j) 30.5	(k) 11.3	(l) 29.2	(m) 10.7	(n) 28.0	(o) 10.0	(p) 17.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 25.2	(b) 21.4	(c) 20.2	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.4	7.4	7.7	7.4	6.2	4.9	3.9	3.4	3.6	3.9	4.7	5.5	6.7
	DBStd	2.43	1.53	1.63	1.85	1.91	2.07	2.14	2.18	1.93	2.23	1.63	1.64	1.74
	HDD10.0	1678	83	66	84	114	158	183	206	199	182	164	134	104
	HDD18.3	4709	339	297	339	364	416	433	464	458	432	422	383	361
	CDD10.0	9	2	3	3	1	0	0	0	0	0	0	0	1
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	9.4	9.9	9.6	9.7	9.6	8.6	8.4	9.1	9.6	9.6	9.6	9.6	9.6
Precipitation	PrecAvg	1032	87	80	110	106	88	76	75	81	78	84	88	78
	PrecMax	1139	139	104	147	146	143	118	114	120	105	114	132	108
	PrecMin	878	59	38	76	69	26	49	50	49	36	62	57	47
	PrecStd	63	17	17	20	20	26	18	16	18	18	14	15	13
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.4	13.8	13.9	12.0	10.4	9.3	8.7	9.6	9.5	9.7	11.5	12.7
		MCWB	11.2	11.0	10.7	9.8	8.4	7.7	6.9	7.8	7.8	8.0	9.7	10.1
	2%	DB	10.7	11.2	11.3	10.2	9.1	8.3	7.7	7.6	8.2	8.6	9.6	10.6
		MCWB	9.5	9.9	10.0	8.9	8.2	7.3	6.2	6.4	6.8	7.5	8.5	9.3
	5%	DB	9.8	10.3	10.3	9.4	8.3	7.6	6.9	6.7	7.5	7.7	8.6	9.6
		MCWB	8.9	9.4	9.4	8.4	7.5	6.7	5.8	5.8	6.3	6.7	7.6	8.5
	10%	DB	9.1	9.7	9.7	8.6	7.7	6.8	6.3	5.9	6.8	7.0	7.7	8.9
		MCWB	8.4	8.9	8.9	7.8	6.9	6.0	5.4	5.0	5.8	6.2	6.8	7.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.4	11.3	11.6	10.1	9.2	8.1	7.4	7.8	8.1	8.5	9.9	10.5
		MCDB	13.0	12.5	12.6	10.9	9.9	8.8	8.4	8.9	8.7	9.4	10.9	12.1
	2%	WB	9.8	10.2	10.2	9.2	8.3	7.4	6.6	6.7	7.2	7.6	8.6	9.5
		MCDB	10.5	10.9	11.0	10.0	8.9	8.1	7.4	7.3	7.9	8.4	9.4	10.5
	5%	WB	9.1	9.6	9.7	8.5	7.7	6.8	6.0	6.0	6.5	6.9	7.7	8.6
		MCDB	9.6	10.1	10.3	9.2	8.3	7.5	6.7	6.6	7.2	7.5	8.3	9.4
	10%	WB	8.6	9.0	9.0	7.9	7.1	6.1	5.5	5.2	5.9	6.3	7.0	8.0
		MCDB	9.0	9.5	9.6	8.6	7.7	6.6	6.2	5.7	6.6	6.9	7.6	8.8
Mean Daily Temperature Range	5% DB	MDBR	3.0	2.9	3.1	2.9	2.8	2.6	2.8	2.8	2.9	2.7	3.0	3.1
		MCDBR	4.7	4.1	4.3	3.9	3.8	3.1	3.3	3.9	3.3	3.5	4.3	4.4
		MCWBR	3.8	3.4	3.4	3.2	3.1	2.6	2.9	3.2	2.9	2.9	3.6	3.4
	5% WB	MCDBR	4.2	4.0	4.1	3.6	3.6	2.9	3.0	3.7	3.0	3.3	4.0	4.3
		MCWBR	3.6	3.4	3.5	3.3	3.2	2.8	2.8	3.3	2.7	2.9	3.6	3.5
Clear-Sky Solar Irradiance	taub	0.346	0.336	0.327	0.344	0.308	0.297	0.322	0.336	0.338	0.340	0.332	0.338	
	taud	2.486	2.520	2.528	2.290	2.233	2.116	2.145	2.263	2.390	2.443	2.502	2.497	
	Ebn at Noon	946	915	853	676	539	426	493	671	817	899	955	964	
	Edh at Noon	104	92	79	74	51	43	54	74	88	99	102	105	
All-Sky Solar Radiation	RadAvg	4.74	3.77	2.39	1.21	0.55	0.28	0.40	0.97	2.03	3.32	4.66	5.17	
	RadStd	0.23	0.29	0.14	0.07	0.03	0.03	0.03	0.05	0.17	0.22	0.33	0.32	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page