

ARTIGAS, Uruguay

WMO: 863300

Lat: 30.398S

Lon: 56.510W

Elev: 398

StdP: 14.49

Time Zone: -3.00 (W03)

Period: 94-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.9	36.9	28.1	22.4	43.6	30.6	25.2	43.2	25.6	55.7	23.3	56.5	3.4	120	0.398

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.6	96.2	73.4	93.5	72.8	91.1	72.2	78.3	89.0	76.9	86.8	75.5	85.2	8.7	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.4	135.2	84.2	74.0	128.8	82.2	72.7	123.1	80.5	42.2	89.8	40.7	86.7	39.3	85.5	83.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
23.5	20.4	18.0	DB	28.3	100.5	2.5	2.3	26.5	102.2	25.0	103.5	23.6	104.8	21.8	106.5
			WB	27.7	80.9	2.5	1.6	25.9	82.0	24.4	82.9	23.0	83.8	21.2	84.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.9	78.2	76.5	73.5	67.1	60.7	56.7	55.7	59.2	61.7	66.9	71.1	75.8	(6)
	DBStd	10.23	4.64	4.98	5.60	6.48	6.94	7.91	8.91	8.93	7.76	5.63	5.52	5.34	(7)
	HDD50	90	0	0	0	0	5	23	41	17	4	0	0	0	(8)
	HDD65	1250	0	1	6	50	169	271	315	230	152	42	13	1	(9)
	CDD50	6249	873	742	730	513	337	224	217	301	355	525	633	799	(10)
	CDD65	1935	408	323	271	113	36	22	26	49	52	102	197	336	(11)
	CDH74	17509	4292	2901	2281	806	184	65	91	361	421	779	1836	3492	(12)
	CDH80	7058	2038	1197	852	226	29	3	5	92	124	216	672	1604	(13)
(14) Wind	WSAvg	7.5	7.2	7.2	6.9	6.6	6.2	6.7	7.5	8.3	9.4	8.8	8.2	7.5	(14)
(15) Precipitation	PrecAvg	56.2	5.4	5.4	4.7	7.6	4.8	3.1	2.4	1.9	4.1	5.8	5.4	5.6	(15)
	PrecMax	95.7	19.1	10.2	12.3	21.0	11.5	8.4	6.4	6.1	10.3	13.4	23.3	16.7	(16)
	PrecMin	32.7	0.7	0.5	1.3	1.3	0.3	0.2	0.1	0.1	0.2	0.3	0.0	0.4	(17)
	PrecStd	14.6	4.5	2.6	3.3	5.2	2.6	2.1	1.8	1.7	2.4	3.0	5.0	4.3	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.8	97.7	95.8	90.2	83.6	79.7	80.5	86.9	89.4	89.9	94.5	100.1	(19)
		MCWB	73.3	75.1	75.0	72.5	71.1	69.5	68.0	68.7	71.0	71.8	71.1	73.5	(20)
	2%	DB	96.3	93.5	91.6	85.9	78.8	75.6	76.9	82.6	83.6	85.5	90.2	95.2	(21)
		MCWB	73.2	74.4	73.8	71.5	67.8	67.8	66.8	67.1	68.8	70.3	70.3	71.8	(22)
	5%	DB	93.4	90.5	88.0	82.3	75.2	71.9	73.0	77.9	78.7	81.6	87.2	92.1	(23)
		MCWB	72.9	73.7	72.3	69.3	66.5	65.6	65.0	65.4	65.8	68.3	69.6	71.0	(24)
	10%	DB	90.4	87.3	84.6	78.7	71.8	68.6	69.1	73.6	74.5	78.0	83.9	88.7	(25)
		MCWB	72.3	72.7	71.1	68.1	64.6	63.6	62.7	63.5	63.6	66.2	68.1	70.6	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.9	80.1	79.6	76.7	73.5	71.5	70.3	70.9	73.6	75.7	77.7	79.6	(27)
		MCDB	91.1	91.2	90.5	85.6	80.8	77.3	76.8	82.1	84.2	85.9	86.3	90.7	(28)
	2%	WB	77.2	78.3	76.9	74.3	70.5	69.1	68.0	68.5	69.6	72.8	74.5	77.1	(29)
		MCDB	88.7	88.7	85.9	82.5	75.6	73.9	74.6	79.4	80.1	81.4	84.2	86.8	(30)
	5%	WB	75.9	76.6	75.0	72.1	67.9	66.7	65.9	66.5	67.4	70.3	72.4	74.8	(31)
		MCDB	87.2	85.8	83.2	78.7	73.0	70.8	71.9	76.2	76.3	78.1	82.0	85.4	(32)
	10%	WB	74.4	74.8	73.3	70.0	65.6	64.5	63.7	64.5	65.4	68.5	70.7	73.1	(33)
		MCDB	85.2	83.2	81.0	75.7	70.6	68.2	68.7	72.4	72.3	75.1	78.9	83.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	21.6	19.1	19.6	19.4	18.3	17.1	18.3	19.9	19.3	19.0	21.3	21.8	(35)
		MCDBR	26.0	23.6	23.5	23.7	21.5	18.4	19.1	23.9	24.3	24.5	26.2	27.3	(36)
	5% WB	MCWBR	8.6	8.5	9.1	10.8	11.2	10.7	10.4	11.4	12.0	11.5	10.3	9.8	(37)
		MCWBR	20.6	18.8	18.5	18.2	16.9	14.3	16.3	20.7	19.6	19.1	19.8	20.8	(38)
(40) Clear-Sky Solar Irradiance	taub		0.408	0.400	0.389	0.386	0.365	0.377	0.380	0.467	0.506	0.450	0.393	0.411	(40)
		taud	2.359	2.390	2.401	2.363	2.400	2.360	2.319	2.027	1.942	2.166	2.354	2.327	(41)
	Ebn at Noon		296	292	285	268	258	244	249	237	245	274	299	296	(42)
		Edh at Noon	42	39	37	34	30	30	32	47	57	49	42	43	(43)
(44) All-Sky Solar Radiation	RadAvg		2193	1974	1694	1280	935	791	889	1133	1402	1732	2126	2224	(44)
	RadStd		188	126	146	168	86	73	90	101	135	224	256	163	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	-1.48	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		N/A	N/A	N/A	N/A	+0.85	+0.97	N/A	N/A	N/A	N/A

Nomenclature: See separate page