

ARTIGAS, Uruguay

WMO: 863300

Lat: 30.398S

Lon: 56.510W

Elev: 121

StdP: 99.87

Time Zone: -3.00 (W03)

Period: 94-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.0	2.7	-2.2	3.2	6.4	-0.8	3.6	6.2	11.4	13.1	10.4	13.6	1.5	120	0.398

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.0	35.7	23.0	34.2	22.6	32.8	22.3	25.7	31.7	25.0	30.5	24.2	29.6	3.9	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.1	19.3	29.0	23.4	18.4	27.9	22.6	17.6	26.9	80.3	32.1	76.9	30.4	73.6	29.7	28.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.5	9.1	8.0	DB	-2.0	38.1	1.4	1.3	-3.0	39.0	-3.9	39.7	-4.6	40.5	-5.7	41.4	(4)
(5)			WB	-2.4	27.2	1.4	0.9	-3.4	27.8	-4.2	28.3	-5.0	28.8	-6.0	29.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.4	25.6	24.7	23.1	19.5	16.0	13.7	13.2	15.1	16.5	19.4	21.7	24.3	(6)	
	DBStd	5.69	2.58	2.77	3.11	3.60	3.86	4.40	4.95	4.96	4.31	3.13	3.06	2.96	(7)	
	HDD10.0	50	0	0	0	0	3	13	23	9	2	0	0	0	(8)	
	HDD18.3	694	0	1	3	28	94	151	175	128	84	23	7	1	(9)	
	CDD10.0	3472	485	412	406	285	187	124	121	167	197	292	352	444	(10)	
	CDD18.3	1075	227	179	151	63	20	12	14	27	29	57	109	187	(11)	
	CDH23.3	9727	2384	1612	1267	448	102	36	51	201	234	433	1020	1940	(12)	
(13)	CDH26.7	3921	1132	665	473	126	16	2	3	51	69	120	373	891	(13)	
(14)	Wind	WSAvg	3.4	3.2	3.2	3.1	3.0	2.8	3.0	3.4	3.7	4.2	4.0	3.7	3.4	(14)
(15) Precipitation	PrecAvg	1427	138	136	120	193	121	79	60	49	103	148	138	142	(15)	
	PrecMax	2430	484	259	313	533	293	214	162	156	262	340	593	425	(16)	
	PrecMin	831	18	13	32	33	8	6	2	2	5	7	0	9	(17)	
	PrecStd	370	114	67	83	132	66	54	45	43	62	76	126	110	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.1	36.5	35.4	32.3	28.7	26.5	26.9	30.5	31.9	32.2	34.7	37.8	(19)	
		MCWB	22.9	24.0	23.9	22.5	21.7	20.8	20.0	20.4	21.6	22.1	21.7	23.0	(20)	
	2%	DB	35.7	34.1	33.1	30.0	26.0	24.2	24.9	28.1	28.7	29.7	32.3	35.1	(21)	
		MCWB	22.9	23.6	23.2	22.0	19.9	19.9	19.3	19.5	20.4	21.3	21.3	22.1	(22)	
	5%	DB	34.1	32.5	31.1	27.9	24.0	22.2	22.8	25.5	25.9	27.6	30.6	33.4	(23)	
		MCWB	22.7	23.2	22.4	20.7	19.2	18.7	18.4	18.6	18.8	20.2	20.9	21.7	(24)	
	10%	DB	32.4	30.7	29.2	25.9	22.1	20.3	20.6	23.1	23.6	25.6	28.8	31.5	(25)	
		MCWB	22.4	22.6	21.7	20.1	18.1	17.5	17.0	17.5	17.6	19.0	20.1	21.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.1	26.7	26.4	24.9	23.1	21.9	21.3	21.6	23.1	24.3	25.4	26.4	(27)	
		MCDB	32.8	32.9	32.5	29.8	27.1	25.2	24.9	27.8	29.0	30.0	30.2	32.6	(28)	
	2%	WB	25.1	25.7	25.0	23.5	21.4	20.6	20.0	20.3	20.9	22.6	23.6	25.0	(29)	
		MCDB	31.5	31.5	29.9	28.1	24.2	23.3	23.7	26.3	26.7	27.5	29.0	30.4	(30)	
	5%	WB	24.4	24.8	23.9	22.3	19.9	19.3	18.8	19.2	19.7	21.3	22.5	23.8	(31)	
		MCDB	30.7	29.9	28.4	25.9	22.8	21.5	22.1	24.6	24.6	25.6	27.8	29.7	(32)	
	10%	WB	23.6	23.8	23.0	21.1	18.7	18.1	17.6	18.1	18.6	20.3	21.5	22.8	(33)	
		MCDB	29.6	28.5	27.2	24.3	21.4	20.1	20.4	22.4	22.4	23.9	26.1	28.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.0	10.6	10.9	10.8	10.2	9.5	10.2	11.1	10.7	10.6	11.9	12.1	(35)	
		MCDBR	14.4	13.1	13.0	13.2	11.9	10.2	10.6	13.3	13.5	13.6	14.6	15.2	(36)	
	5% WB	MCWBR	4.8	4.7	5.1	6.0	6.2	5.9	5.8	6.4	6.7	6.4	5.7	5.5	(37)	
		MCWBR	11.5	10.4	10.3	10.1	9.4	8.0	9.1	11.5	10.9	10.6	11.0	11.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.408	0.400	0.389	0.386	0.365	0.377	0.380	0.467	0.506	0.450	0.393	0.411	(40)	
		taud	2.359	2.390	2.401	2.363	2.400	2.360	2.319	2.027	1.942	2.166	2.354	2.327	(41)	
	Ebn at Noon		933	922	898	844	812	770	785	746	772	865	942	934	(42)	
		Edh at Noon	132	124	116	108	94	93	100	149	180	154	132	137	(43)	
(44) All-Sky Solar Radiation	RadAvg		6.91	6.22	5.34	4.04	2.95	2.49	2.80	3.57	4.42	5.46	6.70	7.01	(44)	
	RadStd		0.59	0.40	0.46	0.53	0.27	0.23	0.28	0.32	0.43	0.71	0.81	0.51	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	-0.82	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)		N/A	N/A	N/A	N/A	+0.47	+0.54	N/A	N/A	N/A	N/A

Nomenclature: See separate page