

RIVERA, Uruguay

WMO: 863500

Lat: 30.8965S

Lon: 55.5427W

Elev: 243

StdP: 98.44

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.3	3.8	-2.2	3.2	7.4	-0.7	3.7	6.7	11.1	14.7	9.9	15.9	2.4	230	0.393

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.1	34.6	23.0	33.1	22.7	31.6	22.1	25.0	31.1	24.3	29.9	23.6	28.9	4.0	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.4	18.7	27.8	22.7	18.0	27.0	22.1	17.3	26.3	77.9	31.1	74.8	30.0	72.1	28.9	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.5	8.3	7.3	DB	-0.1	37.2	1.0	1.3	-0.9	38.2	-1.5	38.9	-2.0	39.7	-2.8	40.6	(4)
(5)			WB	-0.9	26.3	1.0	1.0	-1.6	27.1	-2.2	27.7	-2.7	28.3	-3.5	29.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.6	24.7	23.8	22.2	18.8	15.7	13.2	12.7	14.2	15.5	18.4	21.0	23.3
	DBStd	5.48	2.60	2.67	2.88	3.50	3.66	4.13	4.51	4.70	4.01	3.19	3.11	3.03
	HDD10.0	54	0	0	0	0	3	14	22	11	3	0	0	0
	HDD18.3	784	0	1	4	35	98	163	184	146	103	38	11	2
	CDD10.0	3193	455	387	379	264	179	109	106	143	168	261	329	413
	CDD18.3	882	197	155	125	49	16	8	9	18	18	41	89	156
	CDH23.3	7248	1856	1267	919	298	67	23	39	137	148	283	750	1461
CDH26.7	2589	776	460	282	75	9	1	3	34	45	78	241	587	
Wind	WSAvg	3.3	3.4	3.2	3.0	2.9	2.8	3.1	3.4	3.5	3.9	3.8	3.6	3.3
Precipitation	PrecAvg	1492	122	158	116	178	127	94	87	75	110	156	130	139
	PrecMax	2499	334	314	380	530	379	200	231	209	294	324	484	481
	PrecMin	978	13	22	21	11	0	12	3	8	1	20	27	0
	PrecStd	353	75	78	90	125	82	48	56	47	62	69	94	115
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.3	35.1	34.8	31.7	27.9	26.0	26.7	30.0	31.3	31.8	33.7	36.1
		MCWB	23.3	24.1	23.3	22.7	21.3	20.1	19.2	20.2	21.2	21.6	21.6	22.8
	2%	DB	34.6	33.1	31.6	28.8	25.1	23.6	24.3	27.3	27.3	28.8	31.3	33.8
		MCWB	23.0	23.5	22.4	21.3	19.6	19.2	18.6	19.1	19.9	21.4	21.3	22.3
	5%	DB	32.9	31.3	29.7	26.7	23.1	21.6	21.9	24.4	24.5	26.3	29.5	31.9
		MCWB	22.7	22.6	22.1	20.0	18.7	18.4	17.7	17.9	18.3	19.6	20.6	21.6
	10%	DB	31.2	29.6	28.1	24.7	21.3	19.5	19.5	21.9	22.0	24.3	27.6	30.1
		MCWB	22.3	22.0	21.3	19.6	17.9	16.9	16.2	17.1	17.0	18.5	19.8	21.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.7	26.0	25.3	24.1	22.4	21.1	20.5	21.2	22.5	23.8	24.2	25.5
		MCDB	32.4	32.0	31.0	29.0	26.3	24.3	24.3	27.7	28.4	30.1	30.2	31.8
	2%	WB	24.7	25.0	24.2	22.7	20.7	19.8	19.2	19.7	20.6	22.2	22.9	24.4
		MCDB	30.9	30.8	29.0	27.2	23.5	22.6	23.0	25.0	25.6	26.7	28.5	30.4
	5%	WB	24.0	24.0	23.2	21.5	19.4	18.7	18.0	18.5	19.4	20.8	21.9	23.3
		MCDB	29.9	29.0	27.6	24.7	22.0	21.0	21.0	23.4	23.2	24.8	26.6	29.2
	10%	WB	23.3	23.2	22.4	20.4	18.2	17.5	16.8	17.5	18.0	19.7	21.0	22.3
		MCDB	29.0	27.3	26.4	23.1	20.6	19.4	19.4	21.3	21.1	23.0	25.3	27.8
Mean Daily Temperature Range	5% DB	MDBR	11.1	10.0	10.0	9.7	8.5	8.0	8.6	9.5	9.4	9.7	10.9	11.3
		MCDBR	13.5	12.3	12.0	12.4	10.7	9.7	10.8	12.5	12.6	13.1	13.8	14.0
		MCWBR	4.5	4.5	4.8	5.8	5.5	5.4	5.6	5.8	6.3	6.5	5.8	5.3
	5% WB	MCDBR	11.1	10.0	9.9	9.4	8.4	8.3	9.0	11.2	10.7	10.6	10.5	11.6
		MCWBR	4.7	4.6	4.6	5.1	5.0	4.9	5.3	6.0	5.9	5.9	5.6	5.2
Clear-Sky Solar Irradiance	taub	0.409	0.397	0.386	0.376	0.359	0.371	0.374	0.464	0.495	0.437	0.389	0.405	
	taud	2.357	2.399	2.415	2.396	2.421	2.380	2.341	2.030	1.971	2.200	2.365	2.340	
	Ebn at Noon	932	924	900	853	817	774	789	746	780	876	945	939	
	Edh at Noon	132	123	114	104	91	90	98	148	174	148	130	135	
All-Sky Solar Radiation	RadAvg	6.86	6.11	5.22	3.97	2.84	2.40	2.69	3.41	4.24	5.36	6.62	6.99	
	RadStd	0.56	0.40	0.47	0.50	0.28	0.25	0.27	0.33	0.42	0.69	0.82	0.54	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	-0.82	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page