

SALTO, Uruguay

WMO: 863600

Lat: 31.4381S

Lon: 57.9810W

Elev: 138

StdP: 14.62

Time Zone: -3.00 (W03)

Period: 94-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.7	36.7	28.7	22.8	42.8	30.9	25.2	44.5	22.7	56.7	20.7	61.3	2.5	120	0.389

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.4	96.2	74.7	93.5	73.9	91.0	73.0	78.7	89.8	77.2	88.3	75.7	86.2	8.9	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.4	133.9	85.0	74.0	127.3	82.8	72.7	121.8	81.0	42.3	89.9	40.7	88.2	39.4	86.2	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
21.3	18.6	16.8	DB	29.2	101.5	2.4	2.8	27.4	103.6	26.0	105.2	24.6	106.8	22.8	108.8
			WB	28.6	82.8	2.4	2.4	26.9	84.5	25.5	86.0	24.1	87.3	22.3	89.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.3	78.1	76.0	73.3	66.3	59.9	56.1	54.8	57.9	61.0	66.6	70.6	75.7	(6)
	DBStd	10.38	5.01	4.71	5.41	6.47	7.25	7.59	8.36	8.58	7.48	6.05	5.68	5.41	(7)
	HDD50	93	0	0	0	0	5	24	42	18	3	1	0	0	(8)
	HDD65	1369	0	1	5	59	194	282	335	259	165	52	16	1	(9)
	CDD50	6047	870	729	721	488	312	208	191	265	332	516	619	796	(10)
	CDD65	1847	405	310	261	97	35	16	19	40	44	102	186	332	(11)
	CDH74	17306	4410	2830	2248	694	204	43	84	317	431	862	1774	3409	(12)
	CDH80	7022	2119	1155	855	187	39	3	12	84	128	254	645	1541	(13)
(14) Wind	WSAvg	6.9	6.4	6.3	6.2	6.3	5.8	6.2	6.9	7.7	8.2	8.1	7.8	7.1	(14)
(15) Precipitation	PrecAvg	50.1	4.7	4.8	5.6	5.7	3.8	3.3	3.0	2.4	3.8	5.0	5.0	4.4	(15)
	PrecMax	71.5	22.0	17.7	16.5	20.0	14.8	14.6	10.2	13.2	10.1	12.0	15.0	14.6	(16)
	PrecMin	27.4	0.1	0.2	0.5	0.6	0.0	0.2	0.3	0.0	0.3	0.2	0.9	0.5	(17)
	PrecStd	10.7	3.9	3.8	3.9	4.2	3.1	2.8	2.2	2.1	2.3	2.9	2.9	3.3	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	100.4	96.0	95.3	89.7	84.7	78.5	81.7	87.5	89.7	90.6	95.0	100.0	(19)
		MCWB	75.6	74.5	77.5	73.8	72.5	69.1	69.8	70.7	71.4	71.9	73.2	74.8	(20)
	2%	DB	96.6	92.9	91.1	85.3	79.0	74.6	76.2	81.9	83.6	86.2	90.0	95.4	(21)
		MCWB	74.4	74.0	74.2	71.5	69.5	67.8	67.2	67.6	67.8	70.6	71.1	74.0	(22)
	5%	DB	93.5	90.0	88.0	81.4	75.4	71.1	71.9	77.1	78.9	82.5	86.7	91.8	(23)
		MCWB	74.5	73.4	72.7	69.4	67.5	65.8	64.2	65.2	66.1	67.9	69.3	71.8	(24)
	10%	DB	90.7	87.3	85.0	77.9	71.8	68.0	68.1	72.1	74.6	78.8	83.7	88.2	(25)
		MCWB	73.3	72.8	71.5	67.9	64.9	63.5	61.7	62.4	63.2	66.5	68.4	70.8	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.2	80.4	79.9	76.7	74.0	71.5	71.0	71.8	73.7	75.7	77.4	79.7	(27)
		MCDB	93.1	91.0	90.9	86.3	81.8	76.0	78.1	84.1	83.8	85.3	90.4	92.4	(28)
	2%	WB	78.0	78.2	77.7	74.1	71.6	69.1	67.6	68.7	70.1	73.0	74.3	77.2	(29)
		MCDB	90.8	88.5	87.0	81.6	76.7	72.4	74.0	80.1	80.7	82.5	85.2	90.4	(30)
	5%	WB	76.4	76.2	75.4	72.1	68.9	66.8	65.6	66.4	67.7	70.7	72.2	75.3	(31)
		MCDB	88.4	85.3	84.3	78.2	73.7	69.9	71.6	75.3	76.6	79.3	82.0	87.4	(32)
	10%	WB	75.1	74.3	73.6	70.1	66.0	64.8	63.0	63.9	65.0	68.7	70.4	73.4	(33)
		MCDB	86.4	82.9	80.9	75.2	70.3	68.1	67.1	70.4	71.4	75.8	79.2	84.0	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	22.4	20.3	20.3	19.0	18.5	17.0	18.8	20.4	20.9	20.5	22.4	22.6	(35)
		MCDBR	26.3	24.7	24.8	23.4	21.4	18.0	20.6	25.0	26.3	25.9	27.4	27.8	(36)
		MCWBR	10.1	9.8	10.4	11.4	11.9	11.5	12.1	12.6	13.1	12.6	11.9	11.3	(37)
	5% WB	MCDBR	22.4	20.0	20.5	18.7	18.0	14.7	18.1	21.2	21.0	21.6	22.2	22.2	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.415	0.403	0.388	0.383	0.365	0.377	0.373	0.448	0.497	0.444	0.400	0.408	(40)
		taud	2.343	2.393	2.417	2.387	2.410	2.363	2.346	2.088	1.970	2.190	2.340	2.342	(41)
		Ebn at Noon	294	291	284	268	256	242	250	241	246	275	296	297	(42)
	Edh at Noon	Edh at Noon	43	39	36	33	29	29	30	44	55	48	43	43	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2227	1945	1671	1256	907	776	861	1108	1428	1743	2156	2260	(44)
	RadStd	RadStd	191	136	147	158	83	80	89	101	141	203	198	158	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (4 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page