

MELO, Uruguay

WMO: 864400

Lat: 32.338S

Lon: 54.217W

Elev: 114

StdP: 99.96

Time Zone: -3.00 (W03)

Period: 01-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.1	1.5	-1.7	3.3	3.1	-0.5	3.7	4.1	10.1	10.6	8.7	15.1	0.1	N/A	0.371

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.6	33.7	22.6	32.1	22.3	30.5	22.0	24.9	29.8	24.1	28.8	23.3	27.9	3.2	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.5	18.6	27.5	22.8	17.7	26.2	22.0	16.9	25.3	76.5	29.7	73.0	29.0	70.1	27.8	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.2	6.1	-2.5	36.5	1.2	0.9	-3.3	37.2	-4.0	37.8	-4.7	38.3	-5.6	39.0		
(5)			-2.8	27.1	1.3	2.0	-3.8	28.5	-4.5	29.7	-5.3	30.8	-6.2	32.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.5	23.6	23.1	21.9	17.8	14.5	12.2	11.2	12.9	14.3	17.3	19.5	21.5
	DBStd	5.45	2.71	2.72	2.77	3.53	3.64	3.73	4.30	4.29	3.65	3.13	3.37	2.83
	HDD10.0	79	0	0	0	0	6	18	37	14	5	0	0	0
	HDD18.3	992	1	1	3	51	127	187	226	178	128	58	26	7
	CDD10.0	2803	422	367	369	234	146	84	74	105	135	225	285	356
	CDD18.3	674	165	135	113	36	9	3	4	11	8	24	61	104
	CDH23.3	5574	1569	1108	838	248	52	12	19	83	66	194	493	892
	CDH26.7	1860	628	391	258	64	9	0	2	18	19	47	141	285
(14) Wind	WSAvg	2.3	2.5	2.4	2.2	1.7	1.8	1.9	2.0	2.5	2.6	2.5	2.7	2.6
(15) Precipitation	PrecAvg	1320	82	146	105	146	114	106	103	88	110	121	103	93
	PrecMax	2054	194	470	313	419	352	233	330	211	289	259	373	297
	PrecMin	871	13	28	11	0	5	7	14	17	43	8	15	27
	PrecStd	272	46	101	81	104	84	56	86	51	62	61	74	59
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.9	35.2	34.1	31.2	27.8	25.4	26.0	28.8	29.4	30.6	32.6	33.7
		MCWB	24.0	23.9	23.2	22.6	21.5	20.1	19.6	19.8	21.7	22.7	22.8	21.5
	2%	DB	33.8	33.1	31.3	28.2	24.2	21.4	22.4	25.6	24.7	27.6	30.3	31.6
		MCWB	22.7	23.2	22.0	20.3	18.7	18.4	17.8	18.9	18.6	20.7	21.5	21.4
	5%	DB	32.1	30.9	29.4	26.1	22.1	19.1	19.9	22.5	22.4	25.2	28.2	29.6
		MCWB	22.4	22.5	21.8	19.7	17.7	16.9	16.5	17.4	17.0	19.2	20.6	21.0
	10%	DB	30.2	29.0	27.6	24.1	20.2	17.7	17.5	19.8	20.4	23.3	26.3	28.1
		MCWB	22.2	21.8	21.1	19.2	17.0	15.8	14.6	16.2	15.9	18.2	19.8	20.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.0	26.0	26.2	23.6	22.0	20.7	20.6	20.8	21.5	23.9	24.2	24.4
		MCDB	31.7	32.7	31.5	28.7	26.3	24.1	24.3	25.4	27.2	29.3	29.6	29.5
	2%	WB	24.5	24.8	24.4	22.2	19.7	18.8	18.4	19.2	19.5	21.8	22.9	23.3
		MCDB	30.5	29.3	28.0	26.3	22.6	21.0	22.1	24.5	24.0	25.8	28.2	28.1
	5%	WB	23.6	23.8	23.3	21.3	18.6	17.6	16.7	17.9	18.0	20.4	21.8	22.5
		MCDB	29.6	27.9	26.3	24.2	20.8	18.8	19.0	21.5	20.7	23.9	26.3	26.9
	10%	WB	22.9	22.9	22.3	20.1	17.7	16.3	15.4	16.5	16.8	19.2	20.7	21.6
		MCDB	28.6	26.4	25.4	22.4	19.4	17.3	17.0	19.5	19.0	21.9	24.3	25.7
(35) Mean Daily Temperature Range	5% DB	MDBR	12.6	11.3	11.1	12.1	11.0	9.3	10.3	10.4	10.1	11.0	11.4	12.0
		MCDBR	15.3	14.0	14.1	15.3	14.2	10.8	12.7	14.7	13.7	13.9	14.3	14.9
		MCWBR	5.8	5.0	5.7	7.6	8.1	6.7	7.3	7.6	7.3	7.3	6.3	5.9
	5% WB	MCDBR	12.8	10.5	10.0	10.5	10.5	8.5	11.1	13.0	10.9	11.4	11.3	11.4
		MCWBR	5.6	4.6	5.4	5.7	6.5	6.0	6.8	7.4	6.3	6.7	5.9	5.2
(40) Clear-Sky Solar Irradiance	taub		0.416	0.403	0.398	0.381	0.361	0.369	0.378	0.466	0.487	0.434	0.405	0.407
	taud		2.322	2.377	2.371	2.372	2.404	2.377	2.314	2.014	1.979	2.187	2.299	2.322
	Ebn at Noon		924	916	883	842	805	765	774	736	782	876	928	937
	Edh at Noon		137	125	118	106	91	88	98	149	172	150	139	137
(44) All-Sky Solar Radiation	RadAvg		6.93	6.07	5.12	3.88	2.78	2.35	2.54	3.20	4.14	5.32	6.67	7.07
	RadStd		0.56	0.45	0.44	0.45	0.25	0.22	0.22	0.32	0.37	0.59	0.71	0.50

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page