

PASO DE LOS TOROS, Uruguay

WMO: 864600

Lat: 32.800S

Lon: 56.517W

Elev: 246

StdP: 14.57

Time Zone: -3.00 (W03)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.6	37.3	29.4	23.6	42.3	31.5	26.1	43.0	26.2	53.3	23.5	53.3	2.3	280	0.421

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.6	94.3	71.6	91.3	71.1	88.6	70.5	76.4	86.9	74.8	84.5	73.5	82.8	8.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.5	125.9	81.3	72.1	119.8	79.0	70.8	114.5	77.9	40.1	86.4	38.5	84.7	37.3	82.6	86.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
24.1	19.9	17.7	DB	30.8	100.3	2.2	3.0	29.2	102.4	27.9	104.1	26.7	105.8	25.1	108.0
			WB	29.8	79.9	2.5	2.8	28.0	81.9	26.6	83.6	25.2	85.1	23.4	87.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.3	76.6	74.4	71.8	65.0	58.7	53.8	52.9	55.5	58.0	63.4	68.4	73.5	(6)
	DBStd	10.24	4.84	4.86	5.80	6.23	6.03	7.17	7.49	7.72	6.45	5.59	5.46	5.62	(7)
	HDD50	126	0	0	0	0	3	38	51	26	7	1	0	0	(8)
	HDD65	1694	0	2	11	74	210	346	384	315	226	95	27	4	(9)
	CDD50	5341	824	682	677	451	274	151	142	195	247	417	553	728	(10)
	CDD65	1434	359	264	223	76	16	8	10	19	15	47	130	267	(11)
	CDH74	12148	3479	2118	1681	446	76	32	40	150	131	322	1107	2566	(12)
	CDH80	4527	1525	748	543	121	12	2	4	41	38	81	347	1065	(13)
(14) Wind	WSAvg	7.5	7.7	7.7	7.0	6.4	5.6	6.5	7.3	7.8	8.8	8.5	8.3	8.0	(14)
(15) Precipitation	PrecAvg	51.8	4.7	5.4	4.6	5.4	4.5	3.7	4.2	3.5	3.8	4.6	4.4	4.3	(15)
	PrecMax	77.3	11.7	21.5	17.0	18.3	11.9	14.7	11.3	13.5	8.7	10.9	11.3	13.0	(16)
	PrecMin	26.9	0.2	0.1	0.7	0.8	0.1	0.2	0.3	0.7	1.0	0.5	0.2	0.0	(17)
	PrecStd	11.5	3.1	4.8	3.7	3.8	3.3	2.8	2.6	2.6	2.0	2.8	2.8	3.1	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.8	95.7	93.3	89.2	81.3	78.4	79.1	85.3	85.7	87.7	93.1	97.2	(19)
		MCWB	71.9	72.1	74.9	73.1	68.1	68.2	67.6	69.9	69.2	70.7	72.7	71.9	(20)
	2%	DB	94.4	90.8	88.8	83.4	75.2	71.7	73.2	78.0	76.9	81.5	87.9	93.2	(21)
		MCWB	71.4	71.2	71.7	70.4	66.1	65.6	64.6	66.5	65.0	67.4	68.9	69.5	(22)
	5%	DB	91.2	87.4	85.6	78.9	71.5	67.7	67.9	71.9	72.8	77.3	83.9	89.6	(23)
		MCWB	71.5	71.1	70.7	68.6	64.7	63.5	61.8	63.2	62.5	65.6	66.5	69.1	(24)
	10%	DB	88.2	84.4	82.6	75.4	68.0	64.4	63.6	67.1	68.9	73.8	80.3	85.9	(25)
		MCWB	70.5	70.1	69.6	66.7	62.6	60.8	59.0	60.4	60.0	64.0	65.9	68.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.3	77.8	79.6	75.1	70.7	69.9	69.4	71.1	72.1	73.4	75.0	77.3	(27)
		MCDB	91.0	88.9	90.4	84.1	76.5	74.5	74.5	83.6	83.0	81.9	87.8	88.8	(28)
	2%	WB	75.4	75.6	75.9	72.2	67.6	67.0	65.7	67.3	67.2	70.3	71.9	74.3	(29)
		MCDB	87.7	84.8	82.9	80.8	73.2	70.5	72.3	76.2	74.9	78.1	82.8	85.3	(30)
	5%	WB	74.1	73.8	73.8	70.2	65.6	64.4	62.9	64.4	64.2	67.9	69.8	72.7	(31)
		MCDB	85.2	82.1	80.1	76.5	70.1	67.3	67.0	70.8	70.4	73.8	78.9	82.8	(32)
	10%	WB	72.9	72.3	72.0	68.3	63.6	61.3	60.1	61.6	62.2	65.9	68.1	71.0	(33)
		MCDB	83.0	80.3	78.8	73.2	67.4	63.9	62.8	65.8	66.8	72.0	76.2	80.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	20.6	18.5	18.4	17.0	15.7	15.2	15.8	17.3	17.7	17.5	20.0	20.9	(35)
		MCDBR	24.9	22.5	21.9	21.1	20.1	18.1	20.2	24.0	23.0	23.3	26.0	26.1	(36)
	5% WB	MCWBR	7.5	7.8	8.3	9.9	11.1	12.2	11.6	12.9	12.2	11.0	10.4	8.7	(37)
		MCWBR	20.1	18.1	17.0	17.2	16.5	15.2	17.1	21.0	19.2	18.4	20.0	20.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.411	0.402	0.388	0.373	0.364	0.372	0.368	0.445	0.485	0.434	0.406	0.410	(40)
		taud	2.339	2.384	2.401	2.396	2.393	2.357	2.342	2.080	1.982	2.196	2.301	2.315	(41)
	Ebn at Noon		294	291	283	269	253	240	248	239	248	278	294	296	(42)
		Edh at Noon	43	39	36	32	29	28	30	44	54	47	44	44	(43)
(44) All-Sky Solar Radiation	RadAvg		2260	1942	1660	1232	867	747	804	1034	1374	1737	2154	2305	(44)
	RadStd		167	168	154	145	70	71	80	101	123	176	188	163	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(46) N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47) N/A

Nomenclature: See separate page