

PASO DE LOS TOROS, Uruguay

WMO: 864600

Lat: 32.800S

Lon: 56.517W

Elev: 75

StdP: 100.43

Time Zone: -3.00 (W03)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.4	2.9	-1.5	3.4	5.7	-0.3	3.7	6.1	11.7	11.8	10.5	11.8	1.0	280	0.421

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.4	34.6	22.0	33.0	21.7	31.5	21.4	24.7	30.5	23.8	29.2	23.1	28.2	3.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.1	18.0	27.4	22.3	17.1	26.1	21.6	16.4	25.5	75.4	30.2	71.7	29.3	69.0	28.1	30.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.8	8.9	7.9	-0.7	37.9	1.2	1.6	-1.5	39.1	-2.3	40.1	-3.0	41.0	-3.9	42.2
			-1.2	26.6	1.4	1.6	-2.2	27.7	-3.0	28.6	-3.8	29.5	-4.8	30.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.9	24.8	23.5	22.1	18.4	14.9	12.1	11.6	13.0	14.4	17.5	20.2	23.1
	DBStd	5.69	2.69	2.70	3.22	3.46	3.35	3.98	4.16	4.29	3.59	3.11	3.03	3.12
	HDD10.0	70	0	0	0	0	2	21	28	14	4	1	0	0
	HDD18.3	941	0	1	6	41	117	192	213	175	126	53	15	2
	CDD10.0	2967	458	379	376	251	152	84	79	108	137	232	307	404
	CDD18.3	797	199	147	124	42	9	4	6	11	8	26	72	148
	CDH23.3	6749	1933	1177	934	248	42	18	22	83	73	179	615	1426
	CDH26.7	2515	847	416	302	67	7	1	2	23	21	45	193	592
Wind	WSAvg	3.3	3.4	3.4	3.1	2.9	2.5	2.9	3.3	3.5	3.9	3.8	3.7	3.6
Precipitation	PrecAvg	1316	119	137	117	136	115	94	106	89	96	118	113	109
	PrecMax	1963	297	545	432	464	302	373	287	342	222	278	286	330
	PrecMin	684	4	2	17	20	3	5	8	17	26	12	5	0
	PrecStd	293	78	123	95	97	83	70	67	67	51	70	72	79
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.1	35.4	34.0	31.8	27.4	25.8	26.2	29.6	29.8	30.9	34.0	36.2
		MCWB	22.2	22.3	23.8	22.8	20.0	20.1	19.8	21.1	20.7	21.5	22.6	22.2
	2%	DB	34.7	32.6	31.5	28.5	24.0	22.0	22.9	25.5	25.0	27.5	31.1	34.0
		MCWB	21.9	21.8	22.1	21.3	18.9	18.7	18.1	19.2	18.3	19.7	20.5	20.8
	5%	DB	32.9	30.8	29.8	26.0	21.9	19.9	19.9	22.2	22.7	25.2	28.8	32.0
		MCWB	21.9	21.7	21.5	20.3	18.1	17.5	16.6	17.3	16.9	18.7	19.2	20.6
	10%	DB	31.2	29.1	28.1	24.1	20.0	18.0	17.6	19.5	20.5	23.2	26.9	29.9
		MCWB	21.4	21.1	20.9	19.3	17.0	16.0	15.0	15.8	15.6	17.8	18.8	20.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.2	25.4	26.5	24.0	21.5	21.1	20.8	21.7	22.3	23.0	23.9	25.2
		MCDB	32.8	31.6	32.4	28.9	24.7	23.6	23.6	28.6	28.4	27.7	31.0	31.6
	2%	WB	24.1	24.2	24.4	22.3	19.8	19.5	18.7	19.6	19.6	21.3	22.2	23.5
		MCDB	30.9	29.3	28.3	27.1	22.9	21.4	22.4	24.6	23.8	25.6	28.2	29.6
	5%	WB	23.4	23.2	23.2	21.2	18.7	18.0	17.2	18.0	17.9	20.0	21.0	22.6
		MCDB	29.6	27.9	26.7	24.7	21.2	19.6	19.5	21.6	21.3	23.2	26.0	28.2
	10%	WB	22.7	22.4	22.2	20.2	17.5	16.3	15.6	16.4	16.8	18.8	20.1	21.7
		MCDB	28.3	26.8	26.0	22.9	19.6	17.7	17.1	18.8	19.3	22.2	24.5	27.0
Mean Daily Temperature Range	5% DB	MDBR	11.4	10.3	10.2	9.4	8.7	8.5	8.8	9.6	9.8	9.7	11.1	11.6
		MCDBR	13.8	12.5	12.2	11.7	11.2	10.0	11.2	13.3	12.8	12.9	14.5	14.5
		MCWBR	4.2	4.3	4.6	5.5	6.1	6.8	6.5	7.2	6.8	6.1	5.8	4.8
	5% WB	MCDBR	11.2	10.0	9.4	9.6	9.2	8.4	9.5	11.7	10.7	10.2	11.1	11.4
		MCWBR	4.2	4.4	4.5	5.0	5.6	6.0	6.1	6.8	6.5	5.7	5.6	4.8
Clear-Sky Solar Irradiance	taub		0.411	0.402	0.388	0.373	0.364	0.372	0.368	0.445	0.485	0.434	0.406	0.410
	taud		2.339	2.384	2.401	2.396	2.393	2.357	2.342	2.080	1.982	2.196	2.301	2.315
	Ebn at Noon		928	916	892	848	798	758	783	755	782	876	927	933
	Edh at Noon		134	124	114	102	92	89	95	138	171	148	138	138
All-Sky Solar Radiation	RadAvg		7.12	6.12	5.23	3.88	2.73	2.35	2.54	3.26	4.33	5.48	6.79	7.26
	RadStd		0.53	0.53	0.48	0.46	0.22	0.22	0.25	0.32	0.39	0.56	0.59	0.52

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page