

TREINTA Y TRES, Uruguay

WMO: 865000

Lat: 33.217S

Lon: 54.383W

Elev: 46

StdP: 100.77

Time Zone: -3.00 (W03)

Period: 90-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.5	1.8	-1.4	3.4	3.6	-0.1	3.8	4.2	10.4	11.5	8.4	11.6	0.2	290	0.354

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.8	33.2	22.7	31.7	22.3	30.1	22.2	24.7	30.0	24.0	28.8	23.4	27.6	3.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.3	18.2	26.6	22.7	17.5	26.0	22.1	16.9	25.5	75.3	30.0	72.6	29.0	70.0	27.7	28.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.3	6.5	5.4	-2.2	37.5	0.8	1.6	-2.8	38.7	-3.3	39.7	-3.8	40.6	-4.4	41.8
			-2.2	26.3	1.3	1.1	-3.1	27.1	-3.9	27.8	-4.6	28.4	-5.6	29.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.4	23.6	22.7	21.3	18.2	14.8	11.6	11.0	13.0	13.9	17.3	19.5	22.0	(6)
	DBStd	5.48	2.90	2.87	2.89	3.12	3.68	3.72	3.98	4.27	3.66	3.34	3.12	2.85	(7)
	HDD10.0	84	0	0	0	0	3	24	34	16	7	0	0	0	(8)
	HDD18.3	1012	2	3	9	39	122	204	232	176	140	60	22	4	(9)
	CDD10.0	2776	423	354	351	247	151	72	65	108	124	226	286	371	(10)
	CDD18.3	661	166	124	101	36	12	2	4	9	8	27	57	116	(11)
	CDH23.3	5000	1463	890	633	184	47	5	21	84	63	194	463	953	(12)
	CDH26.7	1627	566	297	157	43	4	0	2	22	16	56	134	331	(13)
(14) Wind	WSAvg	2.1	2.4	2.2	1.8	2.0	1.6	1.8	1.9	2.0	2.4	2.4	2.6	2.5	(14)
(15) Precipitation	PrecAvg	1335	97	119	102	125	121	126	123	108	116	122	106	101	(15)
	PrecMax	1900	334	537	343	379	371	380	318	274	249	302	351	346	(16)
	PrecMin	792	1	5	4	10	5	3	21	25	28	21	12	16	(17)
	PrecStd	305	71	119	70	89	100	88	75	62	65	64	87	73	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.1	34.5	32.0	31.1	26.9	24.1	26.2	29.3	28.8	31.3	33.1	35.7	(19)
		MCWB	23.7	23.1	22.5	24.1	20.9	17.9	19.0	20.2	21.1	22.4	22.6	24.4	(20)
	2%	DB	33.4	32.1	29.9	27.3	24.5	21.2	21.6	25.4	24.7	28.0	30.1	32.1	(21)
		MCWB	22.4	22.3	22.2	20.9	20.1	17.4	17.3	18.9	18.9	20.8	21.0	22.1	(22)
	5%	DB	31.6	30.0	28.5	25.2	22.5	19.0	19.1	22.2	21.9	25.2	27.8	30.1	(23)
		MCWB	22.4	22.5	21.6	20.0	18.6	16.2	15.8	17.3	17.0	19.5	20.0	22.0	(24)
	10%	DB	29.8	28.2	27.0	23.4	20.4	17.2	16.8	19.4	19.8	23.1	25.9	28.1	(25)
		MCWB	22.1	21.8	21.1	19.2	17.3	15.2	14.3	15.6	15.4	18.4	19.7	21.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.8	25.5	24.7	24.2	22.4	19.1	19.5	21.5	21.9	23.8	24.9	24.8	(27)
		MCDB	31.9	30.8	28.5	30.2	25.2	21.5	24.3	27.7	27.5	29.1	30.9	31.4	(28)
	2%	WB	24.6	24.6	23.8	22.5	20.5	18.1	17.9	19.6	19.5	21.9	22.5	23.9	(29)
		MCDB	30.0	29.2	27.1	25.8	24.0	20.2	21.5	24.6	23.8	26.0	27.1	29.8	(30)
	5%	WB	23.8	23.8	22.9	21.3	19.3	17.0	16.4	18.0	17.8	20.5	21.3	23.1	(31)
		MCDB	28.7	27.6	26.0	23.8	21.7	19.0	18.5	21.4	20.5	24.0	25.3	27.5	(32)
	10%	WB	23.0	23.0	22.1	20.4	18.2	15.6	15.1	16.4	16.5	19.3	20.3	22.3	(33)
		MCDB	27.3	26.0	25.4	22.3	20.0	16.9	16.5	18.5	18.8	22.4	24.3	26.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	11.8	10.1	10.4	9.7	9.8	9.2	9.1	10.1	10.0	10.2	10.8	11.1	(35)
		MCDBR	13.9	12.8	12.2	12.2	11.1	10.9	11.9	13.6	12.6	13.0	14.0	14.3	(36)
	5% WB	MCWBR	4.8	4.7	5.0	6.5	6.4	6.6	7.1	7.1	6.8	6.5	6.4	6.0	(37)
		MCWBR	11.1	9.6	9.2	9.5	9.6	8.5	9.6	12.0	10.6	10.8	11.4	11.3	(38)
(40) Clear-Sky Solar Irradiance	taub		0.411	0.409	0.391	0.373	0.361	0.369	0.371	0.457	0.474	0.428	0.403	0.403	(40)
		taud	2.338	2.360	2.394	2.396	2.406	2.372	2.333	2.035	2.015	2.201	2.303	2.331	(41)
	Ebn at Noon		928	909	888	846	800	759	776	740	791	880	929	939	(42)
		Edh at Noon	134	127	115	102	90	88	95	144	165	147	138	136	(43)
(44) All-Sky Solar Radiation	RadAvg		7.01	6.02	5.13	3.87	2.74	2.33	2.46	3.13	4.19	5.41	6.73	7.14	(44)
	RadStd		0.56	0.51	0.45	0.45	0.22	0.22	0.22	0.33	0.38	0.56	0.66	0.49	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page