

FLORIDA, Uruguay

WMO: 865450

Lat: 34.083S

Lon: 56.233W

Elev: 68

StdP: 100.51

Time Zone: -3.00 (W03)

Period: 95-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-1.1	0.4	-2.7	3.0	1.5	-1.3	3.4	2.4	16.8	10.7	13.7	11.6	0.6	40	0.445

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.0	34.2	22.6	32.4	22.1	30.9	21.7	24.9	30.2	24.0	29.5	23.1	28.3	3.1	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.4	18.3	27.9	22.4	17.2	26.8	21.5	16.3	25.6	76.3	29.9	72.5	29.2	69.1	28.1	31.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.3	9.5	8.3	-3.7	38.3	1.4	2.5	-4.7	40.1	-5.5	41.6	-6.3	43.0	-7.3	44.8		
(5)			-3.8	26.9	1.7	2.0	-5.1	28.3	-6.1	29.5	-7.1	30.6	-8.3	32.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.5	23.4	22.6	20.8	16.8	13.5	10.4	9.8	11.5	12.9	16.0	18.8	21.3
	DBStd	5.80	2.79	2.80	2.98	3.71	3.72	3.64	4.05	4.31	3.48	3.16	3.55	3.00
	HDD10.0	137	0	0	0	1	8	35	53	29	11	1	0	0
	HDD18.3	1264	1	3	12	72	156	239	267	216	167	86	37	9
	CDD10.0	2494	416	353	334	206	117	49	47	77	97	186	262	350
	CDD18.3	579	158	122	88	27	6	2	3	6	4	13	49	101
	CDH23.3	5473	1741	1048	670	201	29	4	12	49	29	132	534	1024
	CDH26.7	1983	768	389	191	46	2	0	1	11	5	25	163	382
Wind	WSAvg	3.1	3.3	3.2	2.7	2.8	2.5	2.7	3.1	3.3	3.7	3.5	3.5	3.5
Precipitation	PrecAvg	1261	103	112	128	127	92	97	91	84	103	119	109	96
	PrecMax	1783	294	329	473	405	287	261	194	215	338	271	270	315
	PrecMin	700	2	0	34	19	12	23	11	9	16	22	28	14
	PrecStd	275	81	71	111	87	58	61	51	50	70	73	55	77
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.7	35.9	32.2	30.7	26.1	23.3	25.2	28.4	27.0	29.4	33.2	35.0
		MCWB	23.8	23.0	23.4	22.9	20.5	19.5	19.3	20.9	20.3	21.3	21.7	21.2
	2%	DB	34.8	33.0	30.2	27.7	23.5	20.1	20.8	24.1	23.6	26.6	30.7	33.0
		MCWB	22.9	22.6	22.5	21.1	18.5	18.0	17.1	18.7	17.8	19.9	21.0	21.0
	5%	DB	32.7	31.0	28.9	25.6	21.4	18.2	18.2	21.2	21.6	24.5	28.6	30.7
		MCWB	22.3	22.4	22.1	19.8	17.6	15.6	15.1	16.9	16.6	18.1	20.0	20.7
	10%	DB	31.0	29.2	27.2	23.5	19.6	16.4	16.0	18.6	19.6	22.7	26.6	28.8
		MCWB	21.7	21.6	21.4	19.0	16.8	14.1	13.3	15.2	15.3	17.1	19.2	20.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.7	26.9	25.5	23.7	21.2	20.2	20.4	21.2	20.9	23.4	24.1	24.0
		MCDB	32.4	32.0	30.4	28.9	24.9	22.1	23.6	26.8	25.2	27.7	29.0	28.9
	2%	WB	24.7	24.9	24.2	22.2	19.6	18.3	17.7	19.4	19.1	21.0	22.6	22.7
		MCDB	30.9	30.1	28.7	26.6	22.3	19.7	20.5	23.7	22.4	24.7	28.3	28.6
	5%	WB	23.8	23.8	23.0	21.0	18.5	16.3	15.8	17.5	17.5	19.3	21.2	22.0
		MCDB	30.4	28.6	27.0	24.1	20.4	18.0	17.5	20.4	20.2	22.8	26.0	28.0
	10%	WB	22.8	22.7	22.0	19.8	17.3	14.6	13.9	15.7	16.1	18.1	20.1	21.2
		MCDB	28.7	27.0	25.6	22.4	19.1	15.9	15.4	17.9	18.7	21.2	24.5	27.0
Mean Daily Temperature Range	5% DB	MDBR	14.0	11.9	11.4	11.7	11.0	10.1	10.2	10.9	11.0	12.0	12.8	13.0
		MCDBR	17.0	15.0	13.6	14.2	13.2	11.4	11.8	13.8	14.1	14.9	15.8	16.7
		MCWBR	6.7	6.4	6.7	7.6	8.4	8.0	7.2	8.1	8.4	8.3	7.1	6.3
	5% WB	MCDBR	13.7	12.7	11.8	11.6	10.8	9.2	9.5	12.5	11.2	12.0	12.7	12.7
		MCWBR	6.5	6.8	6.6	7.1	7.3	7.2	6.3	7.8	7.5	7.6	6.8	5.8
Clear-Sky Solar Irradiance	taub	0.406	0.403	0.381	0.370	0.361	0.368	0.356	0.446	0.463	0.422	0.392	0.411	
	taud	2.338	2.369	2.407	2.387	2.386	2.353	2.366	2.055	2.029	2.206	2.326	2.294	
	Ebn at Noon	932	913	895	844	793	752	788	746	798	883	939	931	
	Edh at Noon	134	125	113	102	90	88	91	140	161	146	135	141	
All-Sky Solar Radiation	RadAvg	7.30	6.24	5.26	3.86	2.70	2.28	2.40	3.17	4.33	5.61	6.88	7.47	
	RadStd	0.51	0.58	0.47	0.44	0.20	0.21	0.25	0.32	0.34	0.52	0.58	0.47	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	+0.48	+0.70	N/A	+0.69	+0.63	N/A	N/A	N/A	+125	+67

Nomenclature: See separate page