

MONTEVIDEO CARRASCO, Uruguay

WMO: 865800

Lat: 34.8333S

Lon: 56.0117W

Elev: 111

StdP: 14.64

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.8	37.4	28.2	22.2	43.8	30.3	24.6	44.2	27.1	48.6	23.9	51.2	4.3	320	0.496

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.6	89.3	71.2	86.1	70.7	83.3	70.1	75.7	83.4	74.1	81.0	72.7	79.0	11.6	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.5	125.2	79.3	71.9	118.2	77.4	70.7	113.5	76.1	39.3	83.3	37.7	80.4	36.5	79.3	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
23.9	21.2	19.0	DB	29.8	96.1	2.8	2.5	27.8	97.9	26.2	99.4	24.6	100.8	22.6	102.6
			WB	29.0	79.1	2.5	2.2	27.3	80.6	25.8	81.9	24.4	83.1	22.6	84.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	61.6	72.4	71.6	68.6	63.1	57.3	52.0	50.8	53.4	55.6	60.3	65.1	69.7	(6)
		DBStd	9.39	4.91	4.87	4.78	5.47	5.75	6.11	6.57	6.71	5.79	5.32	5.64	5.58	(7)
		HDD50	164	0	0	0	0	6	42	68	35	12	1	0	0	(8)
		HDD65	2115	4	6	20	99	247	392	442	367	288	164	66	20	(9)
		CDD50	4404	693	605	576	393	233	103	94	141	181	321	453	611	(10)
		CDD65	880	233	192	131	41	8	3	3	8	7	19	69	166	(11)
		CDH74	5440	1570	1113	600	160	36	9	13	60	45	139	511	1184	(12)
		CDH80	1488	473	295	119	25	2	0	14	8	27	137	388		(13)
(14)	Wind	WSAvg	9.6	10.3	9.9	9.3	8.9	8.2	8.7	9.2	9.5	10.3	10.2	10.4	10.4	(14)
(15)	Precipitation	PrecAvg	41.1	3.5	3.6	4.0	4.1	2.8	3.2	3.1	2.9	3.1	3.7	3.7	3.3	(15)
(16)		PrecMax	65.6	11.5	9.6	18.1	10.8	9.5	8.7	7.7	9.3	7.8	8.4	8.5	10.7	(16)
(17)		PrecMin	22.7	0.1	0.2	0.5	0.0	0.2	0.2	0.5	0.3	0.4	0.3	0.3	0.2	(17)
(18)		PrecStd	9.0	2.6	2.2	3.5	2.7	1.8	2.0	1.9	2.0	1.9	2.1	2.2	2.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	94.1	92.6	87.7	83.4	78.8	74.9	75.5	81.0	79.1	83.9	88.6	92.9		(19)
(20)		MCWB	72.9	73.9	72.0	69.2	66.3	66.7	65.3	67.3	67.2	67.0	69.4	70.8		(20)
(21)		DB	88.8	86.3	83.2	78.5	73.2	68.4	68.3	73.3	73.5	77.5	84.1	88.0		(21)
(22)		MCWB	71.7	72.6	70.1	66.9	63.9	62.4	61.2	63.0	62.7	64.5	67.8	70.1		(22)
(23)		DB	84.8	83.6	80.2	75.0	69.0	64.7	64.4	68.1	69.6	73.4	80.2	84.3		(23)
(24)		MCWB	71.0	72.1	69.5	65.8	62.4	59.6	58.9	60.3	59.6	62.1	66.4	69.1		(24)
(25)		DB	82.0	80.6	77.0	71.8	66.0	61.2	60.8	64.2	65.6	69.8	75.6	80.6		(25)
(26)		MCWB	70.8	70.4	69.1	65.5	61.4	56.9	56.3	57.9	58.1	61.6	64.8	68.1		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	77.9	77.9	76.4	72.8	68.8	68.2	66.0	68.6	69.9	70.7	73.3	76.3		(27)
(28)		MCDB	86.5	85.9	82.8	78.7	75.5	72.3	74.2	78.6	76.8	79.4	82.3	86.2		(28)
(29)		WB	75.4	75.6	73.5	70.1	65.7	64.6	62.9	65.1	65.1	67.3	70.4	73.6		(29)
(30)		MCDB	83.3	82.8	78.8	74.4	70.3	67.9	67.3	71.6	70.9	73.3	78.3	81.9		(30)
(31)		WB	73.8	73.8	71.9	68.5	63.8	61.1	60.3	62.0	62.1	65.3	68.6	71.8		(31)
(32)		MCDB	80.6	79.9	76.8	72.5	67.3	63.6	63.2	66.5	66.6	70.2	76.1	79.2		(32)
(33)		WB	72.5	72.3	70.5	66.8	62.1	58.4	57.3	59.1	59.4	63.3	66.7	70.2		(33)
(34)		MCDB	78.8	78.1	74.9	70.7	65.1	60.7	59.9	63.1	63.8	68.3	73.4	77.3		(34)
(35)	Mean Daily Temperature Range	MDBR	16.6	15.3	15.2	15.2	14.6	15.0	14.6	15.7	15.0	15.1	17.1	17.3		(35)
(36)		5% DB	22.5	20.7	20.5	20.0	19.2	17.9	18.7	22.2	22.5	22.9	24.7	24.6		(36)
(37)		MCWBR	11.1	10.3	10.5	11.0	11.4	12.1	11.9	13.1	13.0	12.5	12.3	11.6		(37)
(38)		5% WB	17.7	16.6	15.4	14.7	14.7	14.3	15.6	19.0	17.7	17.5	19.8	18.7		(38)
(39)		MCWBR	10.3	9.7	9.4	9.7	10.0	11.3	11.5	12.8	12.3	11.4	11.7	10.6		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.394	0.390	0.369	0.365	0.357	0.360	0.361	0.442	0.454	0.400	0.383	0.384		(40)
(41)		taud	2.424	2.456	2.502	2.460	2.451	2.430	2.396	2.109	2.096	2.326	2.405	2.427		(41)
(42)		Ebn at Noon	299	293	288	269	252	241	247	237	255	287	300	303		(42)
(43)		Edh at Noon	39	36	32	30	27	26	28	42	48	41	39	39		(43)
(44)	All-Sky Solar Radiation	RadAvg	2324	1993	1668	1211	839	705	736	980	1362	1778	2173	2389		(44)
(45)		RadStd	155	183	146	130	60	66	73	98	99	155	171	142		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+1.06	+1.53	N/A	+1.46	+0.99	N/A	N/A	-229	+299	+149	(46)
(47)	Regional (6 neighbors)	+0.86	+1.26	N/A	+1.24	+1.13	N/A	N/A	N/A	+225	+121	(47)

Nomenclature: See separate page