

LA QUIACA, Argentina

WMO: 870070

Lat: 22.1033S

Lon: 65.6008W

Elev: 11348

StdP: 9.59

Time Zone: -3.00 (W03)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.9	22.5	-26.5	1.9	39.4	-22.3	2.5	42.6	34.5	54.8	32.8	55.0	0.9	140	0.503

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	22.0	74.4	47.8	72.8	47.6	71.1	47.2	54.4	66.1	53.2	64.4	52.2	63.1	5.6	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
50.7	84.6	56.8	49.6	81.1	56.1	48.6	78.2	55.4	28.0	66.4	27.1	64.1	26.4	63.4	63.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.9	16.3	14.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.3	57.2	57.4	57.3	54.2	46.6	43.4	41.9	46.3	51.6	55.3	57.6	58.8
	DBStd	6.85	3.51	3.47	3.27	3.83	3.70	3.47	3.65	3.37	3.83	3.59	3.22	3.05
	HDD50	727	0	1	0	9	115	198	253	121	26	4	0	0
	HDD65	4643	242	213	237	324	569	647	717	579	402	299	222	192
	CDD50	1560	223	208	228	135	11	1	0	7	74	170	229	274
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	65	4	4	5	1	0	0	0	0	2	7	24	18
	CDH80	1	0	0	0	0	0	0	0	0	0	0	1	0
(14) Wind	WSAvg	4.2	4.2	4.4	4.1	3.5	3.5	3.1	4.2	4.0	5.0	5.0	4.9	4.6
(15) Precipitation	PrecAvg	12.6	3.5	2.6	1.7	0.3	0.0	0.0	0.0	0.0	0.1	0.7	0.9	2.9
	PrecMax	19.7	8.6	5.6	3.4	1.3	0.6	0.6	0.0	0.2	1.1	3.2	3.1	6.2
	PrecMin	6.8	0.0	0.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.4
	PrecStd	3.3	1.9	1.2	0.9	0.3	0.1	0.1	0.0	0.0	0.2	0.7	0.7	1.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.3	73.9	74.6	72.8	67.4	66.5	65.6	69.9	73.3	74.7	77.6	76.1
		MCWB	49.0	50.1	49.2	46.2	43.2	41.4	41.0	42.6	47.6	45.8	45.9	48.7
	2%	DB	71.6	70.9	72.0	70.2	65.1	63.8	63.2	66.9	70.1	72.5	73.7	73.5
		MCWB	48.8	49.8	48.5	44.9	40.6	40.3	38.7	40.1	43.0	45.5	46.5	49.2
	5%	DB	68.7	68.4	69.6	68.3	63.0	61.6	60.7	64.6	67.6	70.2	71.3	71.2
		MCWB	49.0	49.5	48.6	44.3	39.1	38.4	37.3	39.4	41.7	44.7	46.0	49.4
	10%	DB	66.0	66.1	67.1	66.1	60.9	59.4	58.0	62.3	65.1	68.0	68.8	68.8
		MCWB	48.9	49.5	48.6	43.7	38.5	37.3	36.0	38.1	41.1	44.1	45.9	49.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.4	54.5	55.9	52.2	47.3	46.3	45.2	45.8	52.3	53.5	54.7	56.0
		MCDB	64.8	65.9	68.1	65.3	61.6	59.3	62.6	61.4	67.7	66.6	67.2	69.4
	2%	WB	53.2	53.3	53.1	50.4	44.2	43.2	41.2	43.2	48.3	51.4	52.6	54.1
		MCDB	61.9	63.9	64.6	61.7	58.9	61.9	59.4	61.8	62.2	64.8	64.5	66.9
	5%	WB	52.0	52.2	51.8	49.2	42.2	40.1	38.3	41.3	46.1	49.7	50.9	52.7
		MCDB	61.6	61.9	63.0	59.9	57.3	57.8	57.5	59.8	58.9	62.1	62.5	64.6
	10%	WB	51.0	51.2	50.6	47.7	40.1	37.6	36.4	39.2	44.1	48.4	49.5	51.4
		MCDB	60.8	60.4	61.2	58.4	55.5	57.5	56.6	58.5	56.8	59.7	60.8	62.6
(35) Mean Daily Temperature Range	5% DB	MDBR	18.3	17.8	20.6	25.5	30.0	34.0	33.9	34.2	29.3	27.2	25.0	22.0
		MCDBR	21.7	21.0	23.6	27.4	32.1	35.9	37.3	37.2	31.9	29.5	27.5	25.0
		MCWBR	6.3	5.8	7.7	11.3	15.7	19.1	20.7	20.2	14.9	12.9	9.3	7.8
	5% WB	MCDBR	18.3	18.0	20.9	22.0	28.6	35.0	35.2	35.2	27.0	24.8	23.7	22.0
		MCWBR	6.5	5.8	7.9	8.8	15.8	21.4	21.0	20.4	14.0	11.2	9.4	8.3
(40) Clear-Sky Solar Irradiance	taub		0.314	0.309	0.296	0.267	0.225	0.204	0.206	0.235	0.282	0.320	0.312	0.322
	taud		2.451	2.477	2.520	2.589	2.636	2.684	2.669	2.538	2.399	2.312	2.380	2.391
	Ebn at Noon		327	324	320	318	322	324	326	325	320	317	325	324
	Edh at Noon		39	37	34	29	25	23	24	30	37	43	41	41
(44) All-Sky Solar Radiation	RadAvg		2205	2123	2086	1934	1706	1566	1654	1944	2246	2436	2550	2372
	RadStd		112	128	101	60	46	42	50	73	67	91	86	112

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	+1.01	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page