

LA QUIACA, Argentina

WMO: 870070

Lat: 22.1033S

Lon: 65.6008W

Elev: 3459

StdP: 66.11

Time Zone: -3.00 (W03)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-6.7	-5.3	-32.5	0.3	4.1	-30.2	0.4	5.9	15.4	12.7	14.7	12.8	0.4	140	0.503

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	12.2	23.5	8.8	22.6	8.7	21.7	8.4	12.5	19.0	11.8	18.0	11.2	17.3	2.5	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.4	12.1	13.8	9.8	11.6	13.4	9.2	11.2	13.0	47.4	19.1	45.2	17.9	43.4	17.5	17.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.3	7.3	6.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.3	14.0	14.1	14.1	12.3	8.1	6.4	5.5	8.0	10.9	13.0	14.2	14.9	(6)
	DBStd	3.81	1.95	1.93	1.82	2.13	2.05	1.93	2.03	1.87	2.13	2.00	1.79	1.69	(7)
	HDD10.0	404	0	1	0	5	64	110	141	67	14	2	0	0	(8)
	HDD18.3	2579	134	118	132	180	316	359	398	322	223	166	123	107	(9)
	CDD10.0	867	124	116	127	75	6	1	0	4	41	94	127	152	(10)
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
	CDH23.3	36	2	2	3	1	0	0	0	0	1	4	13	10	(12)
	CDH26.7	1	0	0	0	0	0	0	0	0	0	0	1	0	(13)
(14) Wind	WSAvg	1.9	1.9	2.0	1.8	1.6	1.6	1.4	1.9	1.8	2.3	2.2	2.2	2.0	(14)
(15) Precipitation	PrecAvg	319	88	67	44	7	1	0	0	0	3	18	24	73	(15)
	PrecMax	500	219	143	87	34	14	16	0	6	28	81	78	157	(16)
	PrecMin	173	0	16	0	0	0	0	0	0	0	0	0	10	(17)
	PrecStd	84	47	30	23	8	3	2	0	1	6	18	19	36	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.5	23.3	23.7	22.6	19.7	19.2	18.7	21.0	23.0	23.7	25.3	24.5	(19)
		MCWB	9.4	10.1	9.5	7.9	6.2	5.2	5.0	5.9	8.7	7.7	7.7	9.3	(20)
	2%	DB	22.0	21.6	22.2	21.2	18.4	17.6	17.3	19.4	21.1	22.5	23.2	23.1	(21)
		MCWB	9.4	9.9	9.2	7.2	4.8	4.6	3.7	4.5	6.1	7.5	8.0	9.6	(22)
	5%	DB	20.4	20.2	20.9	20.2	17.2	16.5	15.9	18.1	19.8	21.2	21.9	21.8	(23)
		MCWB	9.5	9.7	9.2	6.8	4.0	3.5	2.9	4.1	5.4	7.0	7.8	9.6	(24)
	10%	DB	18.9	18.9	19.5	19.0	16.1	15.2	14.4	16.8	18.4	20.0	20.5	20.4	(25)
		MCWB	9.4	9.7	9.2	6.5	3.6	3.0	2.2	3.4	5.1	6.7	7.7	9.5	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.0	12.5	13.3	11.2	8.5	8.0	7.3	7.6	11.3	11.9	12.6	13.3	(27)
		MCDB	18.2	18.8	20.0	18.5	16.5	15.2	17.0	16.3	19.8	19.2	19.6	20.8	(28)
	2%	WB	11.8	11.8	11.7	10.2	6.8	6.2	5.1	6.2	9.1	10.8	11.4	12.3	(29)
		MCDB	16.6	17.7	18.1	16.5	14.9	16.6	15.2	16.5	16.8	18.2	18.1	19.4	(30)
	5%	WB	11.1	11.2	11.0	9.6	5.7	4.5	3.5	5.2	7.9	9.9	10.5	11.5	(31)
		MCDB	16.5	16.6	17.2	15.5	14.1	14.3	14.2	15.4	14.9	16.7	16.9	18.1	(32)
	10%	WB	10.5	10.7	10.3	8.7	4.5	3.1	2.4	4.0	6.7	9.1	9.7	10.8	(33)
		MCDB	16.0	15.8	16.2	14.7	13.0	14.2	13.7	14.7	13.8	15.4	16.0	17.0	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	10.2	9.9	11.4	14.1	16.7	18.9	18.8	19.0	16.3	15.1	13.9	12.2	(35)
		MCDBR	12.1	11.7	13.1	15.2	17.8	19.9	20.7	20.7	17.7	16.4	15.3	13.9	(36)
	5% WB	MCWBR	3.5	3.2	4.3	6.3	8.7	10.6	11.5	11.2	8.3	7.2	5.2	4.4	(37)
		MCDWR	10.2	10.0	11.6	12.2	15.9	19.4	19.6	19.6	15.0	13.8	13.2	12.2	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.314	0.309	0.296	0.267	0.225	0.204	0.206	0.235	0.282	0.320	0.312	0.322	(40)
		taud	2.451	2.477	2.520	2.589	2.636	2.684	2.669	2.538	2.399	2.312	2.380	2.391	(41)
	Ebn at Noon	Ebn at Noon	1030	1022	1010	1002	1014	1022	1028	1023	1008	998	1025	1022	(42)
		Edh at Noon	122	116	106	91	79	72	76	94	118	135	130	129	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	6.95	6.69	6.58	6.10	5.38	4.94	5.21	6.13	7.08	7.68	8.04	7.48	(44)
	RadStd	RadStd	0.35	0.40	0.32	0.19	0.14	0.13	0.16	0.23	0.21	0.29	0.27	0.35	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	N/A	N/A	+0.56	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page