

ORAN, Argentina

WMO: 870160

Lat: 23.1547S

Lon: 64.3281W

Elev: 357

StdP: 97.11

Time Zone: -3.00 (W03)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.5	7.2	1.1	4.3	14.2	3.0	4.9	12.6	7.0	16.3	5.3	16.4	1.3	0	0.289

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	9.7	37.0	24.1	35.5	24.1	34.1	24.1	27.0	32.5	26.4	31.8	25.9	31.1	2.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.7	21.9	29.9	25.0	21.0	29.3	24.5	20.3	28.7	88.0	32.4	85.2	32.0	82.8	31.2	30.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.5	5.4	4.6	DB	3.9	40.6	2.1	1.7	2.4	41.8	1.2	42.8	0.0	43.7	-1.6	44.9	(4)
(5)			WB	3.2	28.6	1.9	1.1	1.8	29.4	0.7	30.0	-0.4	30.6	-1.8	31.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	22.4	26.9	26.3	24.3	22.2	18.9	16.1	15.7	18.9	21.3	24.8	26.2	27.0	(6)	
	DBStd	5.22	2.53	2.64	2.92	3.27	3.38	3.35	3.43	4.15	4.00	3.93	3.24	2.98	(7)	
	HDD10.0	3	0	0	0	0	0	1	2	0	0	0	0	0	(8)	
	HDD18.3	284	0	0	1	8	34	83	96	45	15	2	0	0	(9)	
	CDD10.0	4513	526	455	444	366	275	184	179	276	339	458	485	526	(10)	
	CDD18.3	1750	267	222	187	123	51	16	14	62	104	202	235	268	(11)	
	CDH23.3	14936	2536	1935	1266	618	163	44	83	476	873	1933	2322	2685	(12)	
(13)	CDH26.7	6233	1067	771	412	148	23	3	12	164	352	923	1104	1254	(13)	
(14)	Wind	WSAvg	1.7	1.9	1.8	1.6	1.4	1.2	1.3	1.4	1.6	1.9	2.1	2.1	1.9	(14)
(15) Precipitation	PrecAvg	955	197	166	153	80	19	9	6	4	11	51	97	156	(15)	
	PrecMax	1374	460	374	344	201	76	33	22	28	40	170	242	302	(16)	
	PrecMin	655	35	49	41	7	1	0	0	0	0	1	5	52	(17)	
	PrecStd	209	98	91	77	50	17	10	5	7	11	39	53	67	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.5	36.4	34.4	31.7	28.9	27.0	28.6	33.4	35.8	38.9	38.7	38.7	(19)	
		MCWB	25.9	25.1	25.9	24.5	22.2	20.2	19.9	21.3	21.4	23.5	23.3	24.7	(20)	
	2%	DB	34.7	34.2	32.4	30.0	26.9	24.7	25.9	30.8	33.1	36.2	36.5	36.4	(21)	
		MCWB	25.9	25.6	25.2	23.9	21.6	19.1	18.7	20.6	20.8	23.3	23.5	24.9	(22)	
	5%	DB	33.4	32.6	30.8	28.3	25.1	22.8	23.7	28.1	30.8	34.1	34.5	34.5	(23)	
		MCWB	25.7	25.2	25.0	23.3	20.9	18.3	17.1	19.3	19.9	22.4	23.1	24.7	(24)	
	10%	DB	32.0	31.2	29.1	26.7	23.5	21.1	21.7	25.8	28.5	32.0	32.6	32.7	(25)	
		MCWB	25.2	25.0	24.1	22.7	20.2	17.4	16.2	17.8	18.9	21.7	22.7	24.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.1	27.8	26.9	26.1	23.7	21.3	20.8	22.8	23.2	25.2	26.6	27.2	(27)	
		MCDB	32.7	32.5	31.5	30.2	26.9	25.4	26.9	30.6	32.1	34.9	34.4	33.3	(28)	
	2%	WB	27.1	26.7	26.1	25.1	22.6	20.0	19.4	21.3	22.0	24.3	25.5	26.3	(29)	
		MCDB	32.5	31.5	30.7	28.5	25.6	23.1	24.6	29.1	30.6	33.8	32.4	32.9	(30)	
	5%	WB	26.5	26.0	25.4	24.3	21.7	19.1	18.1	20.0	20.9	23.4	24.5	25.7	(31)	
		MCDB	31.7	30.9	29.5	27.1	24.3	21.8	22.5	26.1	28.3	31.9	31.1	32.1	(32)	
	10%	WB	25.8	25.4	24.7	23.5	20.7	18.1	17.0	18.9	19.7	22.5	23.8	25.1	(33)	
		MCDB	30.7	29.9	28.3	25.8	22.8	20.6	20.4	24.8	27.0	29.9	29.8	31.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.9	8.7	7.6	7.0	7.0	8.6	10.5	12.0	11.7	11.0	10.4	9.7	(35)	
		MCDBR	11.2	10.9	10.0	9.5	9.0	11.3	13.8	15.1	15.5	14.8	14.2	13.0	(36)	
	5% WB	MCWBR	3.9	3.9	3.9	3.9	3.9	5.8	6.5	5.8	5.5	4.7	4.4	4.2	(37)	
		MCWBR	10.1	9.9	8.9	7.9	7.6	9.1	12.3	13.7	13.6	13.2	11.5	11.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.426	0.424	0.417	0.400	0.364	0.331	0.334	0.398	0.487	0.494	0.441	0.435	(40)	
		taud	2.355	2.371	2.392	2.406	2.435	2.506	2.474	2.276	2.036	2.084	2.268	2.317	(41)	
	Ebn at Noon		920	909	887	859	850	865	875	846	810	836	901	914	(42)	
		Edh at Noon	134	129	121	110	98	87	93	123	170	170	145	139	(43)	
(44) All-Sky Solar Radiation	RadAvg		5.96	5.48	4.53	3.76	3.22	3.13	3.67	4.51	5.13	5.29	5.74	5.76	(44)	
	RadStd		0.49	0.35	0.42	0.39	0.35	0.28	0.28	0.36	0.47	0.46	0.56	0.41	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page