

JUJUY, Argentina

WMO: 870460

Lat: 24.3839S

Lon: 65.0956W

Elev: 905

StdP: 90.92

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.9	3.7	-5.0	2.8	9.0	-3.1	3.2	9.9	9.5	18.5	8.3	16.0	2.5	320	0.356

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	11.5	35.4	20.8	34.0	20.7	32.5	20.7	24.0	30.5	23.3	29.5	22.7	28.6	4.4	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.2	18.9	26.6	21.7	18.3	26.1	21.1	17.6	25.3	77.5	30.5	74.7	29.3	72.3	28.7	30.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.1	7.6	6.2	DB	-1.2	39.1	2.1	1.3	-2.7	40.1	-4.0	40.8	-5.1	41.5	-6.6	42.5	(4)
(5)			WB	-2.2	25.7	1.8	1.3	-3.5	26.7	-4.6	27.4	-5.6	28.2	-6.9	29.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.6	24.4	23.4	21.8	19.1	15.9	13.5	13.2	15.9	18.7	22.0	23.3	24.2	(6)	
	DBStd	5.29	2.43	2.57	2.59	3.30	3.49	3.47	3.99	4.51	4.58	3.82	3.37	2.87	(7)	
	HDD10.0	30	0	0	0	0	2	8	14	4	1	0	0	0	(8)	
	HDD18.3	609	1	1	4	30	92	147	164	104	51	11	3	1	(9)	
	CDD10.0	3532	445	374	367	273	183	115	114	187	262	372	398	442	(10)	
	CDD18.3	1068	187	142	113	53	16	3	6	28	61	124	151	184	(11)	
	CDH23.3	9484	1552	1016	651	296	103	53	105	409	762	1321	1522	1696	(12)	
(13)	CDH26.7	3792	633	359	178	62	14	10	24	153	322	597	692	749	(13)	
(14)	Wind	WSAvg	2.5	2.5	2.3	2.1	2.0	2.1	2.5	3.0	3.2	3.1	3.0	2.7	(14)	
(15) Precipitation	PrecAvg	787	163	164	143	45	16	5	4	5	8	29	62	144	(15)	
	PrecMax	1019	286	252	328	104	59	15	13	18	37	124	119	232	(16)	
	PrecMin	560	38	46	52	4	2	0	0	1	2	2	14	62	(17)	
	PrecStd	115	63	52	55	24	14	4	3	4	8	27	27	52	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.2	34.1	32.2	30.2	28.4	27.9	29.7	33.2	35.9	37.5	37.5	36.8	(19)	
		MCWB	22.3	22.6	22.9	21.7	20.1	16.5	16.8	18.0	18.8	20.0	20.9	21.9	(20)	
	2%	DB	33.3	32.1	30.1	28.3	26.0	24.8	26.1	30.8	33.0	34.9	34.7	34.4	(21)	
		MCWB	22.2	22.6	22.4	20.9	19.0	17.1	16.3	17.5	18.3	20.0	20.7	21.6	(22)	
	5%	DB	32.0	30.6	28.8	26.8	24.1	22.2	23.8	28.0	30.7	32.3	32.7	32.8	(23)	
		MCWB	21.9	22.4	22.0	20.6	17.8	15.8	15.5	16.8	17.7	19.5	20.0	21.2	(24)	
	10%	DB	30.2	29.0	27.0	24.9	22.0	20.1	21.1	25.1	28.0	30.0	30.8	30.9	(25)	
		MCWB	21.8	21.9	21.2	19.8	17.0	14.3	13.8	15.3	16.4	18.6	19.4	21.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.8	24.8	24.2	23.3	21.5	18.9	18.9	20.0	21.0	22.4	23.6	24.2	(27)	
		MCDB	31.3	30.9	29.6	28.2	26.4	24.8	26.6	30.1	32.0	32.2	32.6	31.7	(28)	
	2%	WB	23.7	23.8	23.3	22.3	19.9	17.6	17.2	18.3	19.5	21.3	22.2	23.3	(29)	
		MCDB	30.2	29.6	28.5	26.5	24.5	23.1	24.4	28.4	29.9	30.9	30.3	30.5	(30)	
	5%	WB	23.1	23.1	22.5	21.4	18.6	16.4	15.8	17.0	18.4	20.4	21.4	22.6	(31)	
		MCDB	29.2	28.5	27.2	25.1	22.6	21.2	22.5	27.0	28.3	29.5	29.3	29.5	(32)	
	10%	WB	22.4	22.4	21.7	20.4	17.5	15.2	14.4	15.7	17.1	19.5	20.6	21.9	(33)	
		MCDB	28.2	27.4	25.7	23.8	21.3	19.2	20.0	24.3	26.3	27.9	28.1	28.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.8	9.9	9.0	9.2	9.6	11.5	13.1	14.1	14.1	12.7	12.2	11.5	(35)	
		MCDBR	13.6	12.6	11.8	12.0	12.9	15.3	17.1	18.7	17.9	17.0	15.6	14.9	(36)	
	5% WB	MCWBR	4.8	4.9	5.3	5.8	6.9	8.6	9.2	9.0	7.5	6.5	5.4	5.0	(37)	
		MCWBR	11.5	11.1	10.2	10.1	11.4	13.5	15.4	17.2	15.8	14.4	13.4	12.4	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.437	0.423	0.421	0.390	0.326	0.302	0.307	0.359	0.424	0.475	0.423	0.431	(40)	
		taud	2.291	2.337	2.333	2.377	2.497	2.546	2.503	2.333	2.157	2.069	2.267	2.293	(41)	
	Ebn at Noon	Ebn at Noon	910	908	881	864	887	893	899	881	863	851	916	917	(42)	
		Edh at Noon	142	133	128	112	91	82	89	115	149	172	145	142	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	6.21	5.76	5.06	4.42	3.80	3.64	4.07	4.96	5.81	6.18	6.59	6.32	(44)	
	RadStd	RadStd	0.46	0.41	0.33	0.29	0.28	0.22	0.19	0.29	0.34	0.37	0.47	0.41	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	-14	N/A	N/A	N/A
	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page