

SALTA, Argentina

WMO: 870470

Lat: 24.8444S

Lon: 65.4758W

Elev: 4006

StdP: 12.69

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	30.2	33.4	19.8	17.2	54.0	23.9	21.0	49.6	16.9	66.7	14.7	65.6	1.4	270	0.362

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.3	91.7	65.4	89.2	65.9	86.3	65.8	72.0	82.9	71.0	81.3	70.0	79.8	10.3	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.2	124.6	76.1	68.1	120.1	75.2	67.2	116.3	74.2	38.7	82.9	37.7	81.9	36.8	79.9	80.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.5	14.0	12.1	DB	24.8	97.7	3.4	1.6	22.3	98.9	20.4	99.8	18.5	100.7	16.0	101.9	(4)
(5)			WB	24.1	75.2	3.3	2.1	21.8	76.7	19.9	77.9	18.0	79.1	15.6	80.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.5	71.7	70.4	67.9	63.4	57.4	53.6	52.7	56.6	60.9	67.0	69.4	71.5	(6)	
	DBStd	9.03	4.10	4.49	4.38	5.63	5.95	6.24	6.98	7.67	7.69	6.37	5.68	4.83	(7)	
	HDD50	136	0	0	0	2	10	34	53	25	11	1	0	0	(8)	
	HDD65	1621	4	9	22	94	242	343	383	277	164	52	23	8	(9)	
	CDD50	5062	674	571	556	403	239	142	136	229	339	527	581	665	(10)	
	CDD65	1075	213	160	113	45	6	1	2	16	42	114	154	209	(11)	
	CDH74	9503	1452	925	528	244	89	84	153	524	812	1390	1584	1718	(12)	
(13)	CDH80	3056	422	226	87	28	12	16	39	181	301	558	587	599	(13)	
(14)	Wind	WSAvg	4.7	4.5	4.2	4.0	3.9	4.1	4.4	5.0	5.4	5.8	5.5	5.0	(14)	
(15) Precipitation	PrecAvg	29.2	7.3	6.0	4.5	1.5	0.3	0.1	0.1	0.1	0.2	1.0	2.3	5.5	(15)	
	PrecMax	47.8	14.7	13.7	10.0	7.3	1.3	0.8	1.1	1.2	1.4	4.0	9.5	12.4	(16)	
	PrecMin	17.2	2.2	1.9	1.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.3	(17)	
	PrecStd	5.5	2.8	2.7	2.2	1.3	0.3	0.2	0.2	0.2	0.3	0.9	1.6	2.2	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.5	89.0	85.8	82.8	81.4	82.3	85.6	91.2	93.6	95.3	94.9	93.2	(19)	
		MCWB	70.6	71.0	71.0	67.2	61.3	56.1	56.9	57.8	61.7	64.5	66.4	68.5	(20)	
	2%	DB	87.3	85.6	82.4	79.4	76.1	75.6	78.2	85.2	87.9	90.8	90.0	89.5	(21)	
		MCWB	69.5	70.5	69.4	66.5	62.0	56.9	57.0	58.3	60.6	64.5	66.7	68.2	(22)	
	5%	DB	84.5	82.6	79.3	76.8	72.3	71.3	73.0	80.3	83.1	86.4	86.2	86.2	(23)	
		MCWB	69.0	69.4	68.2	65.8	60.7	56.8	55.4	57.7	60.2	63.8	65.0	67.4	(24)	
	10%	DB	82.1	80.1	76.8	73.6	68.4	66.6	67.9	74.8	78.6	82.1	82.7	82.9	(25)	
		MCWB	68.5	68.6	67.1	64.3	59.2	54.7	53.7	56.0	58.4	63.0	64.0	67.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.3	73.6	72.8	70.6	66.8	62.1	61.6	63.7	66.3	69.6	71.7	72.4	(27)	
		MCDB	85.4	84.6	82.0	79.0	74.5	72.8	76.2	80.8	84.0	85.9	87.4	85.3	(28)	
	2%	WB	71.8	71.9	70.8	68.9	64.2	60.0	59.1	61.0	63.8	67.3	69.3	70.9	(29)	
		MCDB	82.4	81.9	79.2	75.9	71.3	69.8	72.2	78.1	81.2	81.8	82.6	82.7	(30)	
	5%	WB	70.6	70.6	69.4	67.3	62.0	58.3	57.0	58.8	61.8	65.8	67.7	69.7	(31)	
		MCDB	80.7	79.7	76.8	73.6	69.4	66.9	69.2	76.6	78.0	80.7	79.4	81.2	(32)	
	10%	WB	69.5	69.4	68.3	65.6	60.2	56.3	54.9	56.6	59.7	64.2	66.4	68.5	(33)	
		MCDB	78.8	77.3	74.7	71.7	67.5	64.6	65.7	72.3	74.7	78.1	78.1	78.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	18.3	17.0	15.8	17.8	19.5	25.2	28.4	30.1	28.3	24.4	22.4	20.4	(35)	
		MCDBR	23.5	21.8	21.0	23.2	27.0	34.0	38.4	40.8	37.3	34.1	29.5	26.8	(36)	
	5% WB	MCWBR	8.7	8.8	9.8	11.0	13.4	17.1	18.3	17.2	14.7	12.2	10.1	8.8	(37)	
		MCWBR	20.4	19.7	18.4	19.1	23.6	28.0	32.5	36.1	30.6	27.1	24.1	22.1	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.416	0.413	0.398	0.355	0.311	0.284	0.283	0.320	0.384	0.430	0.402	0.417	(40)	
		taud	2.347	2.354	2.384	2.459	2.522	2.579	2.555	2.425	2.250	2.180	2.307	2.319	(41)	
	Ebn at Noon		295	291	286	285	286	289	293	292	285	283	297	295	(42)	
		Edh at Noon	43	42	38	33	28	25	27	33	43	49	44	44	(43)	
(44) All-Sky Solar Radiation	RadAvg		1973	1834	1649	1474	1276	1223	1345	1632	1932	2063	2162	2039	(44)	
	RadStd		142	136	90	79	84	62	49	75	87	104	129	122	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page