

SALTA, Argentina

WMO: 870470

Lat: 24.8444S

Lon: 65.4758W

Elev: 1221

StdP: 87.49

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-1.0	0.8	-6.8	2.5	12.2	-4.5	3.0	9.8	7.5	19.3	6.6	18.7	0.6	270	0.362

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.2	33.1	18.6	31.8	18.8	30.1	18.8	22.2	28.3	21.7	27.4	21.1	26.5	4.6	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.6	17.8	24.5	20.1	17.2	24.0	19.6	16.6	23.5	72.2	28.3	69.8	27.7	67.6	26.6	27.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.4	6.3	5.4	-4.0	36.5	1.9	0.9	-5.4	37.2	-6.5	37.7	-7.5	38.2	-8.9	38.9		
			-4.4	24.0	1.8	1.1	-5.7	24.9	-6.7	25.5	-7.8	26.2	-9.1	27.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.5	22.1	21.3	20.0	17.4	14.1	12.0	11.5	13.7	16.1	19.4	20.8	21.9
	DBStd	5.02	2.28	2.50	2.43	3.13	3.30	3.46	3.88	4.26	4.27	3.54	3.16	2.68
	HDD10.0	76	0	0	0	1	6	19	29	14	6	1	0	0
	HDD18.3	901	2	5	12	52	134	191	213	154	91	29	13	4
	CDD10.0	2812	374	317	309	224	133	79	76	127	188	293	323	369
	CDD18.3	597	118	89	63	25	3	1	1	9	23	63	86	116
	CDH23.3	5279	807	514	293	136	49	47	85	291	451	772	880	954
	CDH26.7	1698	234	126	48	16	7	9	22	101	167	310	326	333
Wind	WSAvg	2.1	2.0	1.9	1.8	1.8	1.7	1.8	2.0	2.2	2.4	2.6	2.5	2.2
Precipitation	PrecAvg	741	186	152	115	37	8	3	3	5	26	59	140	
	PrecMax	1214	374	347	254	185	34	21	29	30	35	101	242	316
	PrecMin	438	55	48	32	1	0	0	0	0	0	0	32	
	PrecStd	139	70	69	57	32	8	4	5	7	23	41	57	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.5	31.6	29.9	28.2	27.4	27.9	29.8	32.9	34.2	35.2	34.9	34.0
		MCWB	21.4	21.7	21.7	19.6	16.3	13.4	13.8	14.3	16.5	18.0	19.1	20.3
	2%	DB	30.7	29.8	28.0	26.3	24.5	24.2	25.6	29.5	31.0	32.7	32.2	31.9
		MCWB	20.9	21.4	20.8	19.2	16.7	13.8	13.9	14.6	15.9	18.0	19.3	20.1
	5%	DB	29.2	28.1	26.3	24.9	22.4	21.8	22.8	26.8	28.4	30.2	30.1	30.1
		MCWB	20.6	20.8	20.1	18.8	16.0	13.8	13.0	14.3	15.6	17.7	18.3	19.7
	10%	DB	27.8	26.7	24.9	23.1	20.2	19.2	19.9	23.8	25.9	27.8	28.2	28.3
		MCWB	20.3	20.3	19.5	17.9	15.1	12.6	12.1	13.4	14.7	17.2	17.8	19.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.0	23.1	22.7	21.5	19.4	16.7	16.4	17.6	19.0	20.9	22.1	22.4
		MCDB	29.7	29.2	27.8	26.1	23.6	22.7	24.5	27.1	28.9	30.0	30.8	29.6
	2%	WB	22.1	22.2	21.6	20.5	17.9	15.6	15.1	16.1	17.7	19.6	20.7	21.6
		MCDB	28.0	27.7	26.2	24.4	21.8	21.0	22.3	25.6	27.3	27.7	28.1	28.2
	5%	WB	21.4	21.5	20.8	19.6	16.7	14.6	13.9	14.9	16.5	18.8	19.8	21.0
		MCDB	27.0	26.5	24.9	23.1	20.8	19.4	20.6	24.8	25.6	27.1	26.3	27.3
	10%	WB	20.8	20.8	20.2	18.7	15.7	13.5	12.7	13.7	15.4	17.9	19.1	20.3
		MCDB	26.0	25.2	23.7	22.1	19.7	18.1	18.7	22.4	23.7	25.6	25.6	26.0
Mean Daily Temperature Range	5% DB	MDBR	10.2	9.4	8.8	9.9	10.9	14.0	15.8	16.7	15.7	13.6	12.4	11.3
		MCDBR	13.1	12.1	11.7	12.9	15.0	18.9	21.3	22.7	20.7	18.9	16.4	14.9
		MCWBR	4.8	4.9	5.4	6.1	7.4	9.5	10.1	9.6	8.1	6.8	5.6	4.9
	5% WB	MCDBR	11.3	10.9	10.2	10.6	13.1	15.5	18.1	20.0	17.0	15.1	13.4	12.3
MCWBR		4.6	4.7	4.9	5.3	6.7	8.1	8.9	8.7	7.1	6.0	5.2	4.6	
Clear-Sky Solar Irradiance	taub		0.416	0.413	0.398	0.355	0.311	0.284	0.283	0.320	0.384	0.430	0.402	0.417
	taud		2.347	2.354	2.384	2.459	2.522	2.579	2.555	2.425	2.250	2.180	2.307	2.319
	Ebn at Noon		930	917	902	898	902	912	925	920	900	891	936	930
	Edh at Noon		135	131	121	103	88	79	84	104	136	154	139	139
All-Sky Solar Radiation	RadAvg		6.22	5.78	5.20	4.65	4.02	3.86	4.24	5.14	6.09	6.50	6.82	6.43
	RadStd		0.45	0.43	0.28	0.25	0.26	0.19	0.16	0.24	0.27	0.33	0.41	0.38

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+44
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page