

RESISTENCIA, Argentina

WMO: 871550

Lat: 27.4389S

Lon: 59.0461W

Elev: 52

StdP: 100.70

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.0	3.9	-1.2	3.4	8.7	0.2	3.9	9.5	9.6	20.5	8.7	19.7	1.3	230	0.369

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.5	37.2	24.2	36.0	24.5	34.8	24.4	27.2	32.7	26.6	32.0	26.1	31.5	4.9	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.9	21.4	30.2	25.1	20.4	29.5	24.7	19.8	29.2	86.7	32.7	83.8	32.3	81.3	31.6	35.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.9	7.5	6.7	-1.4	39.9	1.5	1.6	-2.5	41.1	-3.4	42.0	-4.2	42.9	-5.3	44.0		
(5)			-1.7	28.9	1.6	1.5	-2.8	30.0	-3.8	30.9	-4.6	31.8	-5.8	32.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.6	27.2	26.5	24.8	21.8	18.1	16.1	15.6	17.4	19.4	22.3	23.8	26.0
	DBStd	5.75	2.52	2.88	3.06	3.87	4.41	5.01	5.45	5.58	5.01	3.97	3.22	2.89
	HDD10.0	19	0	0	0	0	1	5	9	4	1	0	0	0
	HDD18.3	446	0	0	1	12	61	103	124	89	46	8	2	0
	CDD10.0	4237	534	461	459	353	251	189	182	233	282	383	413	497
	CDD18.3	1622	276	228	201	116	53	37	38	59	77	133	165	239
	CDH23.3	16246	3161	2418	1886	908	347	204	284	618	798	1272	1701	2650
CDH26.7	7321	1605	1151	822	335	94	46	86	264	349	553	732	1284	
Wind	WSAvg	3.0	2.8	2.8	2.6	2.7	2.6	2.8	3.0	3.4	3.7	3.6	3.2	3.0
Precipitation	PrecAvg	1351	165	149	164	168	83	58	38	45	59	122	154	141
	PrecMax	2218	441	474	485	529	248	267	132	152	215	337	612	320
	PrecMin	733	35	13	12	31	2	3	0	0	0	23	20	11
	PrecStd	298	89	85	108	126	64	52	28	33	44	62	98	81
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.2	38.2	37.1	34.2	32.0	30.1	31.0	35.0	37.2	38.4	37.4	38.1
		MCWB	24.6	24.7	23.8	24.7	23.5	22.0	20.6	21.0	21.8	24.1	24.6	23.8
	2%	DB	36.8	36.2	34.9	32.5	29.2	28.0	29.1	32.2	34.0	34.9	34.2	36.1
		MCWB	24.6	24.9	24.8	24.3	22.6	21.7	20.6	20.9	21.6	24.1	23.9	24.9
	5%	DB	35.2	34.5	33.0	30.7	27.0	25.9	27.0	29.9	30.8	32.1	32.7	34.6
		MCWB	24.7	24.9	24.4	23.5	21.6	20.8	20.0	20.4	20.9	23.1	23.3	24.5
	10%	DB	33.8	32.8	31.1	28.2	25.0	23.3	23.9	26.8	27.9	29.5	30.9	32.9
		MCWB	24.5	24.5	23.7	22.4	20.7	19.8	18.8	19.3	19.9	21.8	22.5	24.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.1	28.0	27.2	26.6	24.9	23.5	22.7	23.4	24.5	26.6	27.3	27.7
		MCDB	33.8	33.3	32.6	31.4	29.3	27.8	28.3	31.0	32.3	33.1	32.6	33.8
	2%	WB	27.1	26.9	26.3	25.5	23.6	22.4	21.6	22.1	23.2	25.2	25.8	26.7
		MCDB	32.6	31.9	31.6	30.2	27.6	26.4	27.0	29.7	30.4	32.2	31.5	32.4
	5%	WB	26.4	26.2	25.6	24.6	22.5	21.4	20.4	20.9	22.1	24.1	24.8	26.1
		MCDB	31.8	31.3	30.7	29.0	25.9	24.9	25.3	27.9	28.6	31.0	30.3	31.7
	10%	WB	25.8	25.5	24.8	23.5	21.5	20.4	19.3	19.7	20.9	23.0	23.8	25.4
		MCDB	31.0	30.6	29.2	27.0	24.3	23.2	23.5	26.1	26.4	28.0	28.7	30.5
Mean Daily Temperature Range	5% DB	MDBR	11.5	10.7	10.6	10.1	10.2	10.1	11.6	12.9	12.6	11.2	11.6	11.4
		MCDBR	13.8	13.2	13.2	12.4	11.4	10.7	12.7	15.1	15.7	14.6	14.5	14.0
		MCWBR	4.4	4.3	4.8	5.2	5.5	5.3	5.7	6.1	6.3	6.1	5.5	4.8
	5% WB	MCDBR	10.7	10.2	10.6	10.2	9.4	9.7	11.7	13.7	13.0	12.4	10.9	10.8
		MCWBR	4.4	4.5	4.9	4.9	4.9	5.4	6.2	6.3	6.2	6.0	5.4	4.9
Clear-Sky Solar Irradiance	taub	0.411	0.409	0.397	0.393	0.375	0.390	0.384	0.476	0.545	0.478	0.403	0.413	
	taud	2.394	2.406	2.427	2.412	2.421	2.366	2.363	2.052	1.885	2.143	2.372	2.373	
	Ebn at Noon	933	918	898	850	819	776	799	753	749	845	934	934	
	Edh at Noon	128	123	115	106	96	96	100	150	194	159	130	131	
All-Sky Solar Radiation	RadAvg	6.79	6.20	5.33	4.12	3.23	2.66	3.17	3.89	4.70	5.47	6.56	6.77	
	RadStd	0.56	0.42	0.37	0.44	0.40	0.23	0.28	0.35	0.57	0.58	0.48	0.48	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	+0.40	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	+0.43	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page