

CORRIENTES, Argentina

WMO: 871660

Lat: 27.4497S

Lon: 58.7597W

Elev: 203

StdP: 14.59

Time Zone: -3.00 (W03)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	40.0	42.8	29.1	23.2	50.6	32.3	26.9	51.2	25.0	67.9	21.4	66.8	4.9	160	0.388

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.2	98.5	76.1	96.3	76.4	93.6	75.8	81.0	90.6	80.0	89.4	79.0	88.2	11.8	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.7	150.3	86.8	77.3	143.1	85.3	76.6	139.7	84.6	45.1	91.1	43.8	89.6	42.7	88.8	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.9	19.0	16.6	34.5	102.9	2.5	2.3	32.7	104.5	31.2	105.9	29.8	107.2	27.9	108.8		
(5)			32.7	83.2	2.9	1.4	30.6	84.2	29.0	85.0	27.3	85.8	25.3	86.9	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	71.3	81.1	80.3	77.1	72.0	65.2	62.0	60.9	64.0	67.1	72.5	75.1	78.8	(6)
(7)		DBStd	9.87	4.57	5.22	5.50	6.59	7.35	8.34	9.03	9.25	8.18	6.79	5.58	5.19	(7)
(8)		HDD50	18	0	0	0	0	1	4	9	4	0	0	0	0	(8)
(9)		HDD65	678	0	0	1	15	90	158	193	138	69	11	3	0	(9)
(10)		CDD50	7792	963	848	840	661	473	365	348	437	512	699	753	893	(10)
(11)		CDD65	2978	498	428	376	227	97	69	67	106	131	245	306	428	(11)
(12)		CDH74	28506	5565	4604	3455	1711	555	321	398	930	1227	2191	2962	4587	(12)
(13)		CDH80	12480	2740	2198	1502	616	129	61	88	343	488	918	1226	2171	(13)
(14)	Wind	WSAvg	7.8	7.5	7.5	7.1	6.9	6.8	6.9	7.6	8.7	9.2	9.3	8.4	7.8	(14)
(15)	Precipitation	PrecAvg	57.5	6.6	5.8	6.4	7.4	3.4	2.6	1.7	2.1	2.9	5.7	6.3	6.0	(15)
(16)		PrecMax	85.2	22.1	11.1	18.7	20.3	12.1	8.5	4.7	8.2	10.3	13.8	19.3	16.7	(16)
(17)		PrecMin	35.9	1.6	0.7	1.2	1.3	0.2	0.2	0.1	0.0	0.2	1.1	0.6	1.2	(17)
(18)		PrecStd	14.0	4.0	2.8	3.6	4.9	2.6	2.0	1.1	1.6	2.2	3.1	3.3	3.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	100.3	100.4	98.8	93.6	88.2	85.6	86.1	92.2	97.0	99.8	97.3	100.2	(19)
(20)			MCWB	76.9	76.3	75.4	76.0	74.3	71.9	69.4	70.7	72.9	76.4	76.5	74.7	(20)
(21)		2%	DB	97.0	97.0	94.8	90.0	83.8	81.6	82.6	88.0	91.0	93.6	93.1	96.6	(21)
(22)			MCWB	76.8	76.9	76.1	75.6	72.5	71.1	68.4	69.8	71.4	75.8	75.2	75.9	(22)
(23)		5%	DB	94.8	94.4	91.3	86.7	79.8	77.4	78.9	84.0	85.7	89.1	89.9	93.5	(23)
(24)			MCWB	76.8	76.9	76.0	74.0	70.4	69.6	67.3	68.6	69.6	74.1	73.5	75.4	(24)
(25)		10%	DB	91.7	91.2	88.0	83.2	76.7	73.8	74.6	79.0	80.7	84.6	86.9	90.8	(25)
(26)			MCWB	76.1	75.9	74.8	72.2	68.9	67.6	66.0	66.6	66.9	70.9	72.2	74.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.5	82.4	81.1	79.9	76.4	74.3	72.9	74.3	76.1	80.0	81.0	81.4	(27)
(28)			MCDWB	92.4	91.5	89.9	88.7	84.0	82.1	81.4	87.4	89.6	91.1	90.1	92.4	(28)
(29)		2%	WB	80.8	80.6	79.6	78.0	74.1	72.0	70.4	71.6	73.7	77.6	78.6	79.9	(29)
(30)			MCDWB	90.8	89.2	88.3	86.5	81.1	78.7	78.3	83.7	86.3	89.7	88.1	90.1	(30)
(31)		5%	WB	79.6	79.3	78.3	76.3	72.0	70.2	68.3	69.5	71.4	75.6	76.7	78.7	(31)
(32)			MCDWB	89.1	88.2	86.7	84.1	78.1	76.2	76.4	81.5	81.5	87.0	85.8	88.2	(32)
(33)		10%	WB	78.5	78.1	76.9	74.5	70.2	68.5	66.5	67.4	69.3	73.5	74.8	77.3	(33)
(34)			MCDWB	87.4	86.9	84.8	80.8	75.2	73.6	74.0	77.9	78.7	82.5	83.3	86.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	19.2	18.3	18.3	17.1	16.0	15.6	18.0	20.1	20.8	18.7	19.4	19.5	(35)
(36)			MCDBR	23.1	21.9	23.2	21.3	18.7	17.4	20.4	24.6	26.2	24.6	23.8	23.8	(36)
(37)			MCWBR	7.7	7.3	8.4	9.1	9.2	8.9	9.8	10.7	11.3	10.5	9.5	8.3	(37)
(38)		5% WB	MCDWR	18.6	17.0	17.8	17.8	15.6	16.4	19.0	22.8	22.6	21.7	18.7	18.2	(38)
(39)			MCWBR	8.1	7.4	8.3	8.7	8.4	9.0	10.8	11.1	11.1	10.7	9.6	8.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.410	0.408	0.396	0.393	0.374	0.392	0.386	0.479	0.544	0.477	0.403	0.412	(40)	
(41)		taud	2.400	2.411	2.428	2.415	2.426	2.362	2.360	2.044	1.889	2.148	2.376	2.376	(41)	
(42)		Ebn at Noon	296	292	285	270	260	246	253	238	238	268	296	296	(42)	
(43)		Edh at Noon	40	39	36	34	30	31	32	48	61	50	41	42	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2150	1969	1689	1310	1024	841	1000	1218	1475	1723	2075	2147	(44)	
(45)		RadStd	178	134	119	139	128	73	89	109	181	188	156	158	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	+0.77	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page