

CORRIENTES, Argentina

WMO: 871660

Lat: 27.4497S

Lon: 58.7597W

Elev: 62

StdP: 100.58

Time Zone: -3.00 (W03)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.5	6.0	-1.6	3.3	10.3	0.2	3.8	10.7	11.2	19.9	9.6	19.3	2.2	160	0.388

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.6	36.9	24.5	35.7	24.6	34.2	24.3	27.2	32.6	26.6	31.9	26.1	31.2	5.3	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	21.5	30.4	25.2	20.4	29.6	24.8	20.0	29.2	86.9	32.8	84.1	32.0	81.4	31.5	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.5	7.4	DB	1.4	39.4	1.4	1.3	0.4	40.3	-0.4	41.0	-1.2	41.8	-2.3	42.7	(4)
(5)			WB	0.4	28.4	1.6	0.8	-0.8	29.0	-1.7	29.5	-2.6	29.9	-3.7	30.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	21.8	27.3	26.8	25.1	22.2	18.5	16.7	16.1	17.8	19.5	22.5	24.0	26.0	(6)
(7)		DBStd	5.48	2.54	2.90	3.06	3.66	4.08	4.64	5.02	5.14	4.54	3.77	3.10	2.88	(7)
(8)		HDD10.0	10	0	0	0	0	1	2	5	2	0	0	0	0	(8)
(9)		HDD18.3	377	0	0	1	8	50	88	107	77	38	6	2	0	(9)
(10)		CDD10.0	4329	535	471	467	367	263	203	193	243	284	388	418	496	(10)
(11)		CDD18.3	1654	277	238	209	126	54	38	37	59	73	136	170	238	(11)
(12)		CDH23.3	15837	3092	2558	1919	951	308	178	221	517	682	1217	1646	2548	(12)
(13)	CDH26.7	6933	1522	1221	834	342	72	34	49	191	271	510	681	1206	(13)	
(14)	Wind	WSAvg	3.5	3.3	3.4	3.2	3.1	3.0	3.1	3.4	3.9	4.1	4.2	3.8	3.5	(14)
(15)	Precipitation	PrecAvg	1460	168	147	162	189	87	65	43	54	74	144	160	153	(15)
(16)		PrecMax	2165	562	281	475	515	307	215	120	209	262	350	489	423	(16)
(17)		PrecMin	913	40	17	30	33	4	4	3	0	5	29	16	30	(17)
(18)		PrecStd	356	102	72	92	125	66	52	29	41	55	78	85	99	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.0	38.0	37.1	34.2	31.2	29.8	30.1	33.4	36.1	37.6	36.3	37.9	(19)
(20)			MCWB	24.9	24.6	24.1	24.4	23.5	22.2	20.8	21.5	22.7	24.7	24.7	23.7	(20)
(21)		2%	DB	36.1	36.1	34.9	32.2	28.8	27.6	28.1	31.1	32.8	34.2	33.9	35.9	(21)
(22)			MCWB	24.9	25.0	24.5	24.2	22.5	21.7	20.2	21.0	21.9	24.3	24.0	24.4	(22)
(23)		5%	DB	34.9	34.7	32.9	30.4	26.5	25.2	26.1	28.9	29.8	31.7	32.1	34.2	(23)
(24)			MCWB	24.9	24.9	24.4	23.4	21.3	20.9	19.6	20.3	20.9	23.4	23.0	24.1	(24)
(25)		10%	DB	33.2	32.9	31.1	28.4	24.8	23.2	23.7	26.1	27.1	29.2	30.5	32.7	(25)
(26)			MCWB	24.5	24.4	23.8	22.4	20.5	19.8	18.9	19.2	19.4	21.6	22.3	23.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.1	28.0	27.3	26.6	24.6	23.5	22.7	23.5	24.5	26.7	27.2	27.5	(27)
(28)			MCDWB	33.6	33.1	32.2	31.5	28.9	27.8	27.4	30.8	32.0	32.8	32.3	33.5	(28)
(29)		2%	WB	27.1	27.0	26.4	25.6	23.4	22.2	21.3	22.0	23.2	25.3	25.9	26.6	(29)
(30)			MCDWB	32.7	31.8	31.3	30.3	27.3	26.0	25.7	28.7	30.2	32.1	31.2	32.3	(30)
(31)		5%	WB	26.4	26.3	25.7	24.6	22.2	21.2	20.1	20.9	21.9	24.2	24.8	26.0	(31)
(32)			MCDWB	31.7	31.2	30.4	29.0	25.6	24.5	24.6	27.5	27.5	30.6	29.9	31.2	(32)
(33)		10%	WB	25.8	25.6	24.9	23.6	21.2	20.3	19.2	19.6	20.7	23.1	23.8	25.2	(33)
(34)			MCDWB	30.8	30.5	29.3	27.1	24.0	23.1	23.3	25.5	26.0	28.1	28.5	30.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.6	10.2	10.2	9.5	8.9	8.6	10.0	11.2	11.6	10.4	10.8	10.8	(35)
(36)			MCDBR	12.9	12.2	12.9	11.8	10.4	9.6	11.3	13.7	14.5	13.6	13.2	13.2	(36)
(37)			MCWBR	4.3	4.1	4.7	5.0	5.1	4.9	5.4	6.0	6.3	5.8	5.3	4.6	(37)
(38)		5% WB	MCDWB	10.4	9.5	9.9	9.9	8.7	9.1	10.6	12.7	12.5	12.1	10.4	10.1	(38)
(39)			MCWBR	4.5	4.1	4.6	4.9	4.6	5.0	6.0	6.1	6.2	5.9	5.4	4.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.410	0.408	0.396	0.393	0.374	0.392	0.386	0.479	0.544	0.477	0.403	0.412	(40)	
(41)		taud	2.400	2.411	2.428	2.415	2.426	2.362	2.360	2.044	1.889	2.148	2.376	2.376	(41)	
(42)		Ebn at Noon	934	919	898	851	820	774	798	750	750	846	934	934	(42)	
(43)		Edh at Noon	127	123	114	106	95	97	100	151	193	158	130	131	(43)	
(44)	All-Sky Solar Radiation	RadAvg	6.78	6.21	5.33	4.13	3.23	2.65	3.15	3.84	4.65	5.43	6.54	6.77	(44)	
(45)		RadStd	0.56	0.42	0.38	0.44	0.40	0.23	0.28	0.34	0.57	0.59	0.49	0.50	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	N/A	N/A	N/A	+0.43	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page