

POSADAS, Argentina

WMO: 871780

Lat: 27.3911S

Lon: 55.9669W

Elev: 410

StdP: 14.48

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	41.3	44.6	30.6	25.1	48.2	33.9	28.9	50.5	19.2	65.9	17.1	65.1	4.9	140	0.338

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.3	97.0	75.2	95.2	75.1	93.4	75.0	79.9	90.7	79.0	89.7	78.0	88.4	8.8	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.0	142.8	86.0	75.6	136.1	84.5	75.1	133.9	84.0	43.9	90.9	42.8	90.1	41.8	88.9	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.0	15.2	13.2	DB	36.0	100.8	2.5	1.5	34.2	101.9	32.8	102.8	31.4	103.7	29.6	104.8
			WB	33.5	82.4	2.7	1.6	31.6	83.5	30.0	84.4	28.5	85.3	26.6	86.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	72.5	81.7	80.7	78.1	73.1	66.3	63.5	62.7	66.0	68.6	73.3	76.3	79.9
	DBStd	9.36	3.92	4.39	4.90	6.56	6.94	8.14	8.94	9.11	7.95	5.89	5.08	4.68
	HDD50	15	0	0	0	0	1	3	8	3	0	0	0	0
	HDD65	527	0	0	0	14	70	125	156	104	51	5	2	0
	CDD50	8216	982	860	870	692	506	409	401	499	558	723	788	928
	CDD65	3255	517	440	406	256	110	81	85	135	159	263	340	463
	CDH74	30277	5704	4509	3761	1986	599	394	465	1068	1357	2211	3241	4982
	CDH80	12992	2727	2044	1621	742	148	75	98	366	532	885	1391	2363
Wind	WSAvg	6.1	5.9	5.8	5.5	5.6	5.5	5.9	6.2	6.8	6.9	7.0	6.6	6.2
Precipitation	PrecAvg	69.1	6.5	5.6	6.1	6.5	5.2	5.2	3.8	3.9	5.4	8.3	6.4	6.5
	PrecMax	119.1	14.1	18.3	18.2	16.9	22.7	15.3	15.9	9.8	15.5	21.6	21.2	18.3
	PrecMin	20.9	0.2	0.8	0.9	0.0	0.0	0.2	0.2	0.7	0.8	0.6	0.7	0.5
	PrecStd	18.0	3.7	3.5	3.6	4.3	4.1	3.2	2.9	2.3	2.9	4.5	4.4	4.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.7	98.9	97.0	93.5	88.4	85.6	86.1	91.6	95.4	96.7	96.8	99.0
		MCWB	75.2	76.0	75.0	75.8	73.3	70.7	69.7	70.6	72.1	76.0	75.2	74.3
	2%	DB	96.4	95.3	93.6	91.1	84.2	82.3	82.7	87.9	91.2	92.3	93.6	96.3
		MCWB	75.6	75.7	75.7	74.8	71.3	69.9	68.6	69.3	71.7	74.6	73.7	74.7
	5%	DB	94.6	93.1	91.4	87.9	80.5	78.9	79.2	84.3	86.2	88.5	91.1	93.5
		MCWB	75.6	75.9	75.1	73.9	69.6	68.8	67.6	68.3	70.1	72.5	72.8	74.7
	10%	DB	91.7	90.9	88.4	84.4	76.9	75.1	75.5	80.3	81.9	85.1	87.9	91.2
		MCWB	75.6	75.5	74.2	72.4	68.1	67.3	66.3	66.9	67.9	71.0	71.7	74.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.9	81.2	80.0	79.1	75.2	73.0	72.6	73.1	75.9	78.7	79.3	80.6
		MCDB	91.6	90.8	91.1	89.5	84.5	81.2	81.1	86.5	89.5	91.7	90.2	92.0
	2%	WB	79.6	79.5	78.7	77.2	73.0	71.0	70.2	70.9	73.4	76.5	77.4	79.1
		MCDB	90.4	89.6	89.4	86.6	80.8	79.3	79.1	84.2	86.5	89.1	88.1	90.3
	5%	WB	78.6	78.3	77.3	75.8	71.1	69.5	68.6	69.2	71.3	74.6	75.9	77.8
		MCDB	89.1	88.2	87.2	84.7	77.8	77.2	77.0	81.5	82.3	85.7	86.1	88.3
	10%	WB	77.4	77.2	76.0	74.1	69.4	67.9	67.0	67.5	69.5	72.7	74.1	76.6
		MCDB	87.4	86.6	85.1	82.0	75.2	74.1	74.8	78.5	79.2	82.2	83.7	86.3
Mean Daily Temperature Range	5% DB	MDBR	18.3	18.0	18.0	17.5	16.1	15.6	17.3	19.1	18.7	18.2	19.6	19.0
		MCDBR	21.6	20.7	21.4	20.8	19.6	18.0	19.5	22.6	24.1	23.2	23.9	22.6
		MCWBR	7.8	7.6	8.3	8.7	9.4	9.1	9.7	10.2	10.8	10.7	10.2	9.1
	5% WB	MCDBR	18.0	17.6	18.1	18.3	16.1	16.6	18.1	20.7	20.5	20.2	19.5	18.7
MCWBR		7.9	8.0	8.3	8.7	8.7	9.2	10.2	10.4	10.7	10.4	10.0	8.9	
Clear-Sky Solar Irradiance	taub	0.409	0.407	0.398	0.394	0.371	0.393	0.392	0.490	0.553	0.467	0.406	0.411	
	taud	2.407	2.414	2.422	2.404	2.434	2.372	2.352	2.025	1.876	2.183	2.366	2.380	
	Ebn at Noon	297	292	285	270	261	246	251	235	235	271	296	297	
	Edh at Noon	40	39	36	34	30	30	32	49	62	49	42	41	
All-Sky Solar Radiation	RadAvg	2097	1943	1684	1340	996	838	965	1165	1387	1661	2027	2127	
	RadStd	157	141	115	130	129	71	104	91	150	223	202	193	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+133
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+133

Nomenclature: See separate page