

CERES, Argentina

WMO: 872570

Lat: 29.8756S

Lon: 61.9361W

Elev: 289

StdP: 14.54

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.9	37.0	23.1	17.6	46.6	27.0	21.2	49.3	34.2	67.0	28.1	56.9	2.2	0	0.418

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.0	97.8	75.2	95.1	74.8	92.5	73.9	80.1	90.5	78.8	88.9	77.4	87.1	12.7	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.6	144.8	85.4	76.1	137.6	84.0	74.7	131.1	82.6	44.1	90.2	42.6	89.1	41.2	87.2	87.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
27.8	26.0	20.3	DB	28.5	102.5	2.7	3.3	26.5	104.9	25.0	106.8	23.4	108.7	21.5	111.0
			WB	27.1	82.9	2.7	1.9	25.2	84.3	23.6	85.4	22.0	86.4	20.1	87.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.2	78.4	76.7	73.1	67.3	61.3	56.3	55.3	58.6	62.9	68.5	72.4	76.3	(6)
	DBStd	10.46	5.26	5.57	5.65	6.89	7.22	7.56	8.17	8.64	7.92	6.79	5.78	5.49	(7)
	HDD50	71	0	0	0	0	2	21	31	14	3	0	0	0	(8)
	HDD65	1248	0	1	6	52	164	280	324	243	131	38	8	1	(9)
	CDD50	6352	882	746	715	519	352	211	195	281	389	574	672	816	(10)
	CDD65	2054	417	327	257	121	49	20	23	44	67	147	230	352	(11)
	CDH74	20462	4552	3221	2221	903	295	92	160	505	798	1542	2417	3756	(12)
	CDH80	8915	2244	1464	870	293	66	16	39	198	300	624	1043	1758	(13)
(14) Wind	WSAvg	8.0	7.3	7.4	6.8	7.1	6.8	7.1	8.0	9.2	9.9	9.8	8.9	8.1	(14)
(15) Precipitation	PrecAvg	36.5	5.4	4.5	5.5	3.5	1.1	0.8	0.6	0.7	1.6	3.1	4.2	5.4	(15)
	PrecMax	55.4	16.5	15.2	15.6	11.9	4.3	5.0	4.1	3.5	6.0	9.1	10.8	17.7	(16)
	PrecMin	17.7	0.5	0.2	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.2	0.6	0.6	(17)
	PrecStd	8.5	3.6	2.7	3.3	2.6	1.1	0.9	0.8	0.7	1.4	2.0	2.2	3.7	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	101.3	99.8	95.7	91.7	86.6	82.3	85.6	92.2	95.6	97.1	97.4	101.5	(19)
		MCWB	76.4	76.5	76.7	74.6	72.7	68.7	67.5	69.9	70.4	72.4	73.5	76.4	(20)
	2%	DB	97.0	95.6	92.0	87.4	81.3	75.6	78.6	85.6	88.1	91.1	93.5	96.4	(21)
		MCWB	75.8	76.7	75.0	72.7	69.8	67.4	66.4	67.5	67.7	71.6	71.2	74.7	(22)
	5%	DB	94.0	92.1	88.6	83.4	77.1	71.5	73.1	79.3	83.1	86.7	89.8	92.7	(23)
		MCWB	74.9	75.4	73.3	70.7	68.6	64.3	62.4	64.6	65.7	69.0	70.4	74.0	(24)
	10%	DB	90.9	88.7	85.2	79.2	73.0	67.9	68.4	73.6	78.2	82.5	86.4	89.3	(25)
		MCWB	74.0	74.2	72.2	69.5	65.8	60.9	59.5	61.5	63.0	67.0	69.4	72.9	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.1	82.1	80.3	78.1	76.0	71.4	70.5	72.3	73.8	78.0	78.4	81.3	(27)
		MCDB	93.2	92.4	91.0	86.6	82.5	76.9	80.7	86.5	87.3	90.0	91.1	91.6	(28)
	2%	WB	79.8	79.8	78.3	75.5	72.4	68.8	67.1	69.0	70.7	74.5	75.5	78.9	(29)
		MCDB	90.2	89.7	86.9	82.9	78.4	74.2	76.2	82.1	83.5	85.9	86.3	89.3	(30)
	5%	WB	78.4	78.0	76.2	73.5	69.6	66.0	64.5	66.2	68.0	72.2	73.3	77.1	(31)
		MCDB	88.7	87.8	83.7	79.9	75.2	70.6	71.3	77.6	79.4	82.7	83.8	87.8	(32)
	10%	WB	76.8	76.4	74.4	71.2	67.0	63.0	61.7	62.9	65.4	69.6	71.5	75.3	(33)
		MCDB	86.3	85.5	81.6	76.8	71.9	66.6	67.2	72.0	75.0	79.0	81.4	84.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	21.0	19.6	19.5	18.0	17.6	18.2	20.8	23.5	23.4	21.9	22.7	21.6	(35)
		MCDBR	25.3	24.6	24.0	23.3	21.3	20.8	25.2	30.6	30.6	28.6	28.8	27.1	(36)
	5% WB	MCWBR	8.5	9.3	9.5	10.6	11.0	11.7	13.2	14.6	13.6	12.5	11.1	10.2	(37)
		MCWBR	20.1	20.0	18.9	18.1	17.7	16.9	20.8	26.9	24.3	23.5	22.4	21.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.406	0.397	0.385	0.382	0.361	0.360	0.362	0.433	0.497	0.449	0.403	0.400	(40)
		taud	2.375	2.407	2.434	2.415	2.431	2.415	2.379	2.125	1.958	2.177	2.334	2.375	(41)
	Ebn at Noon		297	294	287	270	260	252	257	248	248	275	296	300	(42)
		Edh at Noon	41	39	36	33	29	28	30	43	56	48	43	42	(43)
(44) All-Sky Solar Radiation	RadAvg		2208	1968	1636	1232	949	835	967	1273	1583	1850	2189	2243	(44)
	RadStd		153	125	120	154	89	98	90	98	150	142	128	122	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.95	+1.40	-2.92	+1.33	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page