

PASO DE LOS LIBRES, Argentina

WMO: 872890

Lat: 29.6894S

Lon: 57.1486W

Elev: 230

StdP: 14.57

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	37.2	39.8	30.2	24.5	48.2	33.5	28.3	46.9	32.8	58.2	29.7	60.9	3.3	180	0.448

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.8	97.0	76.7	94.7	75.5	91.7	74.7	80.1	91.2	78.9	89.4	77.5	87.1	12.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.2	142.8	86.0	75.8	135.9	84.1	74.9	131.9	83.1	44.0	92.1	42.6	89.6	41.2	87.2	86.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
29.9	26.0	22.9	31.5	101.5	3.0	2.4	29.3	103.2	27.5	104.6	25.8	105.9	23.6	107.6
			30.8	83.1	3.2	1.9	28.5	84.5	26.6	85.6	24.8	86.7	22.5	88.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	68.5	79.5	77.9	74.6	69.0	62.3	58.7	57.6	60.9	63.7	68.8	72.5	77.0
	DBStd	9.98	4.50	4.95	5.53	6.59	6.83	8.18	8.73	8.77	7.51	5.71	5.19	5.14
	HDD50	51	0	0	0	0	2	15	23	9	2	0	0	0
	HDD65	997	0	1	3	33	135	224	267	191	110	26	7	0
	CDD50	6802	913	780	762	570	385	277	259	346	413	583	676	838
	CDD65	2272	448	361	300	153	52	36	37	63	71	144	233	374
	CDH74	20036	4635	3375	2517	1016	243	143	189	494	583	1029	2035	3777
	CDH80	8274	2196	1468	994	335	41	17	31	150	209	330	765	1738
Wind	WSAvg	9.3	9.0	8.6	8.2	8.1	7.6	8.3	9.2	10.2	11.6	11.4	10.1	9.4
Precipitation	PrecAvg	58.7	5.2	5.8	6.0	6.3	4.7	3.4	3.3	2.9	4.4	6.4	5.2	5.6
	PrecMax	91.5	21.7	14.8	14.0	22.1	12.7	13.9	9.6	7.4	11.0	15.8	20.7	20.5
	PrecMin	26.9	0.6	1.1	0.6	0.9	0.2	0.2	0.2	0.1	0.6	0.9	0.4	0.7
	PrecStd	14.1	3.7	3.4	3.5	4.6	3.3	2.5	2.5	2.0	2.3	3.7	4.0	4.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	100.0	99.0	97.5	91.8	84.6	82.4	83.5	89.2	93.2	93.2	95.1	99.3
		MCWB	77.2	78.3	77.0	76.2	72.8	70.9	69.1	70.7	74.1	76.3	74.6	76.0
	2%	DB	96.8	95.2	92.9	88.0	80.2	78.6	79.5	84.4	86.2	87.7	91.0	95.5
		MCWB	76.3	76.0	76.5	75.1	69.7	69.6	68.2	69.4	71.5	72.4	72.7	75.5
	5%	DB	93.5	91.7	89.1	83.9	76.5	73.9	74.9	79.2	80.7	83.5	87.7	92.9
		MCWB	75.1	75.4	74.5	72.6	68.6	67.7	66.7	67.0	68.1	70.8	70.6	74.1
	10%	DB	91.0	88.3	85.7	79.9	73.0	70.3	70.2	75.0	75.6	79.4	84.4	89.5
		MCWB	74.3	74.0	73.1	70.7	67.1	65.5	63.9	65.5	65.7	68.5	69.9	73.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.9	81.1	80.4	78.8	74.8	72.6	71.1	73.3	76.2	78.2	78.5	81.5
		MCDB	92.4	92.3	91.9	87.8	81.0	79.2	78.1	85.6	87.9	89.5	90.1	92.9
	2%	WB	79.9	79.2	78.5	76.4	72.1	70.5	69.3	70.5	72.7	75.6	75.7	79.7
		MCDB	90.9	90.3	88.6	85.1	77.3	76.3	77.2	80.9	83.4	84.3	85.3	90.0
	5%	WB	78.3	77.8	76.7	74.6	69.8	68.5	67.3	68.4	70.1	72.7	73.9	77.6
		MCDB	88.6	87.7	84.9	81.5	74.4	73.4	73.8	77.9	78.6	80.1	82.8	86.9
	10%	WB	76.7	76.3	75.1	72.5	67.5	66.4	65.0	66.1	67.6	70.5	72.1	75.6
		MCDB	86.1	84.9	82.4	77.6	72.0	70.4	70.3	74.3	74.0	77.2	80.3	84.8
Mean Daily Temperature Range	5% DB	MDBR	19.8	18.8	18.9	17.4	16.5	16.4	17.6	19.7	19.1	17.7	19.9	20.3
		MCDBR	24.4	23.9	23.7	22.1	20.1	18.4	20.8	24.7	25.7	23.7	25.8	25.6
		MCWBR	8.9	8.6	9.6	10.3	11.0	10.6	11.0	12.1	12.4	11.8	10.7	9.8
	5% WB	MCDBR	20.1	19.7	19.4	19.1	16.1	16.4	19.1	21.9	22.2	19.9	19.8	20.9
MCWBR		9.3	8.7	9.3	9.9	9.8	10.1	11.0	11.7	12.0	11.6	10.5	10.5	
Clear-Sky Solar Irradiance	taub	0.408	0.402	0.393	0.394	0.371	0.385	0.385	0.476	0.519	0.458	0.396	0.411	
	taud	2.377	2.398	2.406	2.365	2.406	2.359	2.332	2.025	1.929	2.169	2.362	2.347	
	Ebn at Noon	296	292	284	266	257	243	249	235	242	272	298	296	
	Edh at Noon	41	39	37	35	30	30	32	48	58	49	42	43	
All-Sky Solar Radiation	RadAvg	2175	1963	1696	1286	948	802	912	1153	1416	1727	2111	2206	
	RadStd	201	124	146	162	98	72	95	102	156	213	243	169	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	+1.04	+1.10	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	+0.85	+0.97	N/A	N/A	N/A	N/A

Nomenclature: See separate page