

SAN JUAN, Argentina

WMO: 873110

Lat: 31.5747S

Lon: 68.4225W

Elev: 598

StdP: 94.34

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-2.1	-0.5	-14.2	1.2	17.1	-11.3	1.5	13.1	13.6	17.3	11.4	15.7	1.1	0	0.500

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.8	38.1	19.8	36.7	19.7	35.2	19.3	22.4	33.7	21.7	32.7	21.0	31.9	4.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.0	14.8	26.9	18.1	14.0	26.8	17.2	13.2	26.4	69.0	33.7	66.2	32.7	63.6	31.9	25.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.1	11.1	9.7	-5.1	42.2	1.7	1.7	-6.3	43.4	-7.3	44.4	-8.2	45.3	-9.4	46.5		
(5)			-6.2	23.8	1.5	0.9	-7.3	24.4	-8.1	25.0	-9.0	25.5	-10.1	26.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.4	27.4	25.8	23.0	17.9	13.1	9.2	8.5	11.5	15.3	19.7	23.3	26.1		
	DBStd	7.34	2.86	3.32	3.24	3.50	3.24	2.90	3.19	3.63	3.93	3.70	3.48	3.22		
	HDD10.0	153	0	0	0	1	8	48	67	23	6	1	0	0		
	HDD18.3	1152	1	1	4	49	163	275	306	214	106	27	5	1		
	CDD10.0	3207	538	442	404	239	105	23	19	71	164	302	399	500		
	CDD18.3	1163	280	210	149	37	2	0	1	3	14	71	154	243		
	CDH23.3	14364	3529	2434	1509	401	52	14	19	98	311	947	1919	3130		
(13)	CDH26.7	7169	1954	1268	658	114	10	4	4	33	99	386	931	1708		
(14)	Wind	WSAvg	3.7	4.7	4.3	3.8	3.2	2.6	2.7	2.8	3.3	3.8	4.4	4.8		
(15) Precipitation	PrecAvg	101	18	25	12	4	3	2	2	3	5	3	8	15		
	PrecMax	225	44	155	27	21	24	19	14	33	45	19	24	50		
	PrecMin	35	0	1	0	0	0	0	0	0	0	0	0	0		
	PrecStd	46	14	31	8	6	6	5	3	6	9	4	8	14		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.1	39.0	36.3	32.2	27.6	25.2	26.2	30.8	33.2	36.3	37.9	40.1		
		MCWB	21.1	19.8	20.6	18.7	15.2	10.3	11.3	12.6	14.8	16.2	18.2	19.7		
	2%	DB	38.0	36.8	34.1	29.7	24.5	20.1	21.0	26.0	29.5	33.1	35.8	37.7		
		MCWB	20.4	20.5	19.8	17.4	14.4	10.8	9.8	12.1	13.6	16.6	18.0	19.6		
	5%	DB	36.4	35.1	32.3	27.7	22.2	18.1	18.5	22.8	26.8	30.7	33.8	36.1		
		MCWB	20.4	19.9	19.3	16.6	13.5	10.0	9.0	11.0	12.6	15.6	17.7	19.2		
	10%	DB	34.8	33.5	30.6	25.5	20.3	16.3	16.3	20.3	24.5	28.5	31.9	34.3		
		MCWB	19.9	19.6	18.8	15.8	12.6	9.1	8.1	9.7	11.9	14.7	17.1	18.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.3	23.2	22.6	19.7	16.9	12.9	12.4	14.6	16.0	19.4	21.3	22.7		
		MCDB	36.0	34.1	32.8	28.4	24.9	20.3	21.6	27.2	28.8	31.8	33.4	34.7		
	2%	WB	22.3	22.3	21.2	18.6	15.6	11.7	10.8	12.6	14.6	17.8	19.8	21.6		
		MCDB	34.4	32.7	31.1	26.9	22.5	18.6	19.5	23.9	26.8	29.7	31.9	33.5		
	5%	WB	21.6	21.5	20.3	17.5	14.4	10.7	9.6	11.4	13.4	16.5	18.7	20.7		
		MCDB	33.2	31.7	29.5	25.7	20.8	17.1	17.3	21.7	24.8	27.8	30.8	32.4		
	10%	WB	20.8	20.7	19.4	16.6	13.2	9.6	8.5	10.1	12.3	15.4	17.7	19.8		
		MCDB	31.9	30.7	28.4	24.4	19.2	15.5	15.6	19.7	22.9	26.5	29.7	31.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.8	13.3	12.8	12.9	12.8	14.0	14.9	15.5	15.3	14.8	15.1	14.6		
		MCDBR	16.0	16.0	15.7	16.4	16.0	17.1	18.6	20.1	19.7	18.6	18.2	17.4		
	5% WB	MCWBR	4.6	4.8	5.2	6.8	8.1	9.5	9.9	9.6	8.3	6.9	6.3	5.5		
		MCWBR	14.2	13.6	13.7	14.0	14.3	15.4	16.9	18.4	17.5	16.2	15.8	14.7		
(40) Clear-Sky Solar Irradiance	taub		0.393	0.386	0.364	0.350	0.315	0.291	0.290	0.312	0.356	0.356	0.371	0.386		
	taud		2.383	2.402	2.457	2.461	2.505	2.567	2.533	2.461	2.335	2.371	2.361	2.369		
	Ebn at Noon		947	933	920	879	864	869	886	907	912	953	962	957		
	Edh at Noon		129	122	109	97	82	73	79	95	120	125	131	131		
(44) All-Sky Solar Radiation	RadAvg		7.93	7.10	5.94	4.63	3.44	3.17	3.45	4.45	5.70	7.03	8.09	8.42		
	RadStd		0.43	0.38	0.30	0.33	0.35	0.21	0.18	0.24	0.36	0.39	0.40	0.41		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	+0.45	+0.43	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	+0.36	N/A	N/A	N/A	N/A	N/A	+63

Nomenclature: See separate page