

CHAMICAL, Argentina

WMO: 873200

Lat: 30.3478S

Lon: 66.2961W

Elev: 1512

StdP: 13.91

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	35.6	38.9	18.0	14.4	50.5	21.8	17.3	50.3	24.3	55.4	20.7	59.3	2.3	140	0.375

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.5	100.8	74.4	97.9	73.4	95.1	72.3	78.0	93.7	76.4	91.7	75.2	89.7	11.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.8	133.5	85.3	72.2	126.0	84.0	70.9	120.3	83.0	42.8	94.4	41.2	91.8	39.9	89.5	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.7	22.3	18.8	30.4	105.2	4.6	3.7	27.1	107.8	24.4	110.0	21.8	112.0	18.5	114.7
			26.6	80.3	3.9	2.8	23.8	82.3	21.5	84.0	19.3	85.5	16.5	87.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.7	82.2	79.0	74.3	67.3	60.1	54.8	54.2	59.4	65.2	72.3	76.2	80.0	(6)
	DBStd	11.57	6.00	6.01	6.16	6.38	6.11	4.99	6.48	7.56	7.85	7.10	6.73	6.17	(7)
	HDD50	59	0	0	0	1	3	15	29	9	2	0	0	0	(8)
	HDD65	1200	0	0	7	46	178	308	339	207	92	18	4	1	(9)
	CDD50	6883	999	812	753	520	315	157	160	300	459	692	786	930	(10)
	CDD65	2552	534	393	295	115	25	1	5	34	100	244	340	466	(11)
	CDH74	26496	6404	4098	2304	709	110	6	41	348	913	2455	3701	5407	(12)
	CDH80	12483	3462	1911	854	184	19	0	7	106	295	1048	1806	2791	(13)
(14) Wind	WSAvg	5.7	6.7	5.9	4.7	4.7	3.7	3.3	4.0	5.4	6.7	8.1	8.0	7.5	(14)
(15) Precipitation	PrecAvg	17.4	3.8	3.0	2.8	0.8	0.3	0.1	0.2	0.2	0.5	0.9	2.2	3.3	(15)
	PrecMax	24.8	7.4	9.1	8.5	3.3	1.7	0.8	1.0	1.2	1.8	6.8	7.0	9.4	(16)
	PrecMin	11.7	1.3	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	(17)
	PrecStd	4.1	1.6	1.9	1.7	0.7	0.4	0.2	0.3	0.3	0.6	1.3	1.6	2.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	104.5	100.3	96.5	89.8	82.4	74.3	79.6	88.7	92.9	99.8	100.7	103.4	(19)
		MCWB	76.3	77.2	76.2	71.9	67.6	62.0	63.1	66.4	68.5	71.0	71.7	74.2	(20)
	2%	DB	101.4	96.8	92.0	84.7	76.9	69.6	73.9	82.5	87.2	94.7	96.7	99.3	(21)
		MCWB	75.3	75.9	74.0	70.0	64.7	58.4	59.9	62.0	64.7	69.0	70.3	73.3	(22)
	5%	DB	97.9	93.4	88.6	81.1	73.1	67.2	69.6	77.4	83.1	90.2	93.3	95.9	(23)
		MCWB	74.4	74.2	72.6	67.6	62.5	56.6	56.5	59.9	62.8	67.1	69.0	72.0	(24)
	10%	DB	94.3	90.5	85.0	77.9	70.0	64.6	66.0	73.1	79.2	86.2	89.9	92.5	(25)
		MCWB	73.5	73.2	71.2	66.5	60.8	55.5	54.0	56.8	60.7	65.2	67.9	71.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.1	82.4	77.9	74.2	68.8	63.0	65.1	67.5	71.2	74.7	75.6	78.0	(27)
		MCDB	97.7	95.3	92.1	83.9	78.2	69.9	77.2	85.1	87.2	94.0	93.3	96.7	(28)
	2%	WB	78.0	78.0	76.0	72.1	66.6	60.5	61.7	64.4	67.1	71.5	73.3	76.2	(29)
		MCDB	95.7	90.8	88.0	80.3	74.8	66.9	71.1	79.3	82.8	88.6	89.9	93.4	(30)
	5%	WB	76.2	76.1	74.4	70.3	64.5	58.6	59.0	61.4	64.6	69.2	71.5	74.4	(31)
		MCDB	93.4	89.1	85.1	78.0	70.9	65.1	66.5	74.3	79.5	85.7	87.9	91.3	(32)
	10%	WB	74.7	74.6	72.8	68.6	62.6	56.7	56.3	58.5	62.2	67.1	69.6	72.8	(33)
		MCDB	90.4	86.9	82.5	75.8	68.3	62.6	64.0	70.9	76.9	82.8	86.3	89.0	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	20.5	18.7	16.9	17.2	16.0	17.5	20.3	22.8	22.2	21.7	21.9	21.2	(35)
		MCDBR	24.7	21.8	20.8	21.5	19.3	21.2	24.1	27.4	26.3	26.5	26.4	25.7	(36)
	5% WB	MCWBR	8.6	8.1	8.6	10.3	9.9	12.0	13.1	13.4	12.6	11.5	10.4	9.2	(37)
		MCWBR	22.3	19.2	18.4	16.3	16.2	17.7	20.5	25.5	23.9	23.1	22.5	22.7	(38)
(40) Clear-Sky Solar Irradiance	taub		0.391	0.380	0.368	0.360	0.331	0.316	0.312	0.348	0.389	0.382	0.382	0.386	(40)
		taud	2.424	2.459	2.492	2.472	2.504	2.526	2.502	2.387	2.274	2.356	2.396	2.421	(41)
	Ebn at Noon		301	299	292	277	271	268	274	277	280	295	302	304	(42)
		Edh at Noon	39	37	34	31	27	25	26	33	41	40	40	40	(43)
(44) All-Sky Solar Radiation	RadAvg		2342	2057	1702	1319	1032	952	1083	1413	1777	2102	2368	2432	(44)
	RadStd		132	145	136	135	102	90	62	80	109	155	123	132	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page