

VILLA DOLORES, Argentina

WMO: 873280

Lat: 31.9514S

Lon: 65.1492W

Elev: 1867

StdP: 13.73

Time Zone: -3.00 (W03)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.4	35.5	14.0	12.0	49.6	18.1	14.7	50.8	26.7	67.7	23.4	64.0	3.5	90	0.370

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.6	97.4	69.8	94.9	69.3	92.4	68.9	75.4	89.4	73.9	87.6	72.5	85.9	11.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
71.4	124.1	82.4	69.8	117.6	81.0	68.4	111.7	79.8	40.4	89.5	38.9	88.4	37.6	85.9	88.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
24.7	21.1	17.8	DB	26.7	103.9	3.1	3.1	24.5	106.1	22.7	107.9	20.9	109.7	18.7	111.9
			WB	24.6	79.3	2.7	3.0	22.7	81.4	21.1	83.2	19.6	84.8	17.6	87.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.3	78.9	76.3	71.8	65.8	59.0	53.4	52.5	57.6	62.4	68.7	73.4	76.8	(6)
	DBStd	11.25	5.72	6.00	6.00	6.88	6.82	6.10	7.27	8.11	8.18	7.16	6.95	6.15	(7)
	HDD50	126	0	0	0	2	8	34	55	19	8	0	0	0	(8)
	HDD65	1499	1	3	13	71	211	350	393	258	141	44	12	2	(9)
	CDD50	6084	896	736	676	476	286	135	132	255	380	579	703	830	(10)
	CDD65	1982	432	319	224	94	24	2	5	28	64	158	265	367	(11)
	CDH74	20638	4937	3192	1847	675	136	14	53	323	700	1661	2975	4125	(12)
	CDH80	9019	2484	1416	660	172	15	0	9	99	221	630	1338	1975	(13)
(14) Wind	WSAvg	5.4	5.9	4.9	4.7	4.5	4.3	4.2	4.6	5.9	5.9	6.2	7.1	6.3	(14)
(15) Precipitation	PrecAvg	24.1	4.7	3.6	3.0	1.5	0.5	0.4	0.3	0.3	1.0	1.5	2.8	4.8	(15)
	PrecMax	34.6	13.0	7.1	8.8	4.2	2.1	2.2	1.9	2.1	3.9	4.5	8.3	9.8	(16)
	PrecMin	16.0	2.2	0.9	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.4	1.8	(17)
	PrecStd	4.9	2.2	1.5	1.8	1.2	0.5	0.6	0.4	0.5	0.9	1.2	1.6	1.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	101.5	97.6	94.4	89.1	81.9	75.9	79.2	89.0	91.4	95.2	97.7	101.1	(19)
		MCWB	70.3	72.8	70.5	69.5	65.8	61.4	61.9	65.1	63.0	66.8	67.1	69.6	(20)
	2%	DB	97.7	94.2	89.9	84.8	77.8	71.4	73.9	82.0	86.2	90.6	94.4	96.4	(21)
		MCWB	70.8	72.4	70.5	67.4	64.0	57.7	59.0	60.3	61.8	65.2	66.2	69.0	(22)
	5%	DB	94.5	91.3	86.6	81.3	74.1	68.1	69.6	76.8	82.1	86.9	91.3	93.3	(23)
		MCWB	70.1	71.8	69.2	66.1	61.6	55.7	55.5	57.2	60.1	63.4	65.7	68.9	(24)
	10%	DB	91.3	88.2	83.5	77.8	70.3	64.9	65.5	72.0	77.8	83.4	87.8	89.9	(25)
		MCWB	69.8	70.9	68.1	64.9	59.2	53.6	52.4	54.5	57.8	61.8	64.8	68.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.7	77.2	74.4	73.2	68.1	63.5	64.3	66.5	67.5	70.9	71.4	75.4	(27)
		MCDB	92.3	89.6	86.8	82.9	79.2	74.1	76.6	86.6	82.6	89.1	89.4	92.8	(28)
	2%	WB	75.5	75.6	72.6	70.5	65.5	60.0	60.8	62.7	64.0	68.1	69.6	73.3	(29)
		MCDB	89.6	88.7	84.5	79.4	74.7	68.6	71.7	79.5	82.0	85.4	87.6	89.1	(30)
	5%	WB	73.7	74.1	71.2	68.4	63.3	57.5	57.6	59.0	61.7	65.8	68.0	71.6	(31)
		MCDB	87.6	87.2	82.0	77.0	71.2	65.8	66.9	72.8	78.2	82.2	85.2	87.2	(32)
	10%	WB	72.2	72.4	69.7	66.4	61.2	55.1	54.3	55.7	59.3	63.8	66.5	70.0	(33)
		MCDB	86.0	84.9	80.2	75.9	68.6	62.8	63.0	69.6	74.8	79.0	82.8	85.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	22.6	21.1	20.0	18.9	18.6	20.5	21.9	23.8	23.9	23.8	24.1	23.5	(35)
		MCDBR	24.8	23.6	22.8	22.3	21.2	23.1	25.3	27.3	27.6	26.7	26.7	26.6	(36)
	5% WB	MCWBR	8.4	8.7	9.2	10.2	10.7	12.7	13.3	13.3	12.5	11.2	9.7	9.6	(37)
		MCWBR	21.9	21.2	19.8	18.8	18.8	20.6	23.4	25.8	24.7	24.0	23.6	22.9	(38)
(40) Clear-Sky Solar Irradiance	taub		0.379	0.368	0.362	0.343	0.329	0.309	0.314	0.347	0.394	0.384	0.372	0.384	(40)
		taud	2.433	2.468	2.481	2.497	2.476	2.535	2.475	2.372	2.236	2.328	2.395	2.393	(41)
	Ebn at Noon		305	302	292	281	268	268	271	274	277	293	305	304	(42)
		Edh at Noon	39	36	34	30	27	24	26	33	42	41	40	41	(43)
(44) All-Sky Solar Radiation	RadAvg		2331	2017	1688	1255	961	902	1001	1320	1686	2003	2295	2386	(44)
	RadStd		143	141	144	144	109	92	66	93	125	159	127	132	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (5 neighbors)	N/A	N/A	N/A	+1.06	+0.72	+1.04	N/A	N/A	N/A	N/A

Nomenclature: See separate page