

MONTE CASEROS, Argentina

WMO: 873930

Lat: 30.2617S

Lon: 57.6389W

Elev: 177

StdP: 14.60

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	38.3	40.9	30.3	24.6	46.1	33.0	27.7	46.5	26.3	62.3	23.4	58.6	2.5	270	0.332

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.9	95.5	75.0	92.8	74.5	90.4	73.9	79.0	89.1	77.8	87.4	76.7	85.9	7.1	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.2	137.7	84.4	75.2	132.8	83.4	74.1	128.1	82.2	42.7	89.3	41.5	87.6	40.4	85.9	82.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
24.2	20.4	16.8	33.0	100.8	1.8	1.3	31.7	101.7	30.6	102.5	29.6	103.2	28.3	104.1		
			32.3	81.1	2.4	0.9	30.5	81.8	29.1	82.3	27.7	82.8	25.9	83.5		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	68.7	79.9	78.5	74.8	69.1	62.5	58.7	57.7	61.2	63.7	68.5	73.0	77.3
	DBStd	10.02	4.67	5.07	5.64	6.57	6.23	8.23	8.25	8.32	7.65	5.72	4.98	5.51
	HDD50	38	0	0	0	0	0	14	18	5	1	0	0	0
	HDD65	970	0	0	3	31	124	226	260	180	113	29	4	0
	CDD50	6857	928	799	768	572	389	275	256	352	411	572	689	846
	CDD65	2313	463	379	306	153	48	37	33	61	73	136	243	381
	CDH74	18628	4695	3332	2247	801	149	104	128	374	524	835	1789	3650
	CDH80	7069	2060	1310	795	212	18	9	16	99	173	234	581	1562
Wind	WSAvg	5.7	4.8	4.9	4.8	5.1	4.7	5.3	6.1	7.1	7.3	6.9	5.9	5.6
Precipitation	PrecAvg	57.7	5.6	6.1	6.2	6.1	4.3	3.0	3.1	2.6	3.9	5.6	5.7	5.4
	PrecMax	81.4	16.9	17.0	14.0	19.2	12.2	7.9	10.9	8.6	12.4	13.9	15.4	14.9
	PrecMin	34.5	0.3	0.5	0.9	0.9	0.0	0.6	0.1	0.4	0.6	1.4	0.7	1.3
	PrecStd	11.5	3.7	4.1	3.1	4.7	2.9	1.9	2.5	1.8	2.2	3.3	3.1	3.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	99.1	97.5	95.2	90.1	82.4	81.5	82.1	87.8	91.7	91.0	93.6	98.7
		MCWB	76.0	75.7	76.1	75.9	71.6	71.0	68.7	70.0	72.8	72.6	73.2	75.7
	2%	DB	95.4	93.2	91.0	85.4	78.1	77.1	77.7	82.9	84.6	85.6	89.5	94.5
		MCWB	74.6	75.7	74.8	73.3	69.1	69.0	67.6	67.9	69.9	70.5	71.8	74.7
	5%	DB	92.3	90.1	87.6	81.8	74.9	73.5	73.2	78.0	79.7	81.8	86.4	91.2
		MCWB	74.2	74.7	73.8	71.7	67.7	67.8	65.8	66.3	67.7	69.0	70.3	73.7
	10%	DB	89.6	87.3	84.4	78.4	71.6	70.3	69.2	73.7	75.4	78.4	83.3	87.8
		MCWB	73.8	74.0	72.8	70.2	66.3	65.6	63.1	64.5	65.6	67.1	69.1	72.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.5	80.1	79.6	77.6	74.0	72.6	71.2	71.7	74.5	75.5	77.3	80.0
		MCDB	91.4	89.3	89.9	86.6	79.4	78.7	77.7	83.3	85.8	86.4	88.1	90.9
	2%	WB	78.6	78.4	77.8	75.3	71.4	70.5	68.4	69.3	71.6	73.3	74.4	78.3
		MCDB	88.7	88.3	86.4	82.5	75.5	75.4	75.8	79.8	81.7	81.9	84.2	88.3
	5%	WB	77.3	77.1	76.3	73.5	69.0	68.3	66.3	67.4	69.1	71.1	72.8	76.5
		MCDB	87.0	86.3	83.6	79.7	73.3	72.6	72.3	76.7	77.8	78.8	81.6	86.9
	10%	WB	76.2	75.9	74.8	71.6	66.9	66.2	64.1	65.3	66.8	69.1	71.3	74.9
		MCDB	85.4	84.2	81.7	76.3	70.9	70.2	69.1	72.7	74.2	75.9	79.3	84.8
Mean Daily Temperature Range	5% DB	MDBR	17.9	16.9	17.3	15.1	14.7	15.2	15.9	18.1	17.6	17.0	18.5	18.5
		MCDBR	21.9	20.2	21.0	18.9	17.9	16.6	19.5	23.1	23.7	22.6	23.1	22.7
		MCWBR	6.7	6.5	7.9	8.1	9.3	9.0	9.9	10.2	10.7	9.9	8.9	7.7
	5% WB	MCDBR	16.6	17.3	17.0	15.2	13.9	14.7	17.1	20.3	20.1	18.6	17.6	18.5
MCWBR		6.8	7.1	7.6	7.4	8.0	8.2	9.5	9.8	10.6	9.6	9.1	8.3	
Clear-Sky Solar Irradiance	taub	0.407	0.401	0.392	0.391	0.370	0.376	0.384	0.465	0.513	0.460	0.401	0.414	
	taud	2.374	2.398	2.406	2.364	2.401	2.376	2.317	2.046	1.934	2.154	2.345	2.332	
	Ebn at Noon	297	292	284	266	256	245	248	238	243	272	296	295	
	Edh at Noon	41	39	36	35	30	29	32	47	58	49	42	43	
All-Sky Solar Radiation	RadAvg	2196	1960	1693	1274	936	797	898	1146	1425	1741	2126	2230	
	RadStd	203	135	142	171	92	79	94	103	155	207	237	156	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	+0.85	+0.97	N/A	N/A	N/A	N/A

Nomenclature: See separate page